

TELEPHONE: (02) 43998122
EMAIL: wbutson@ausgrid.com.au
REFERENCE: TRIM 2017/11/234

ATTN: Clay Logan

49 Mann St
Gosford NSW 2250



24-28 Campbell St
Sydney NSW 2000
All mail to
GPO Box 4009
Sydney NSW 2001
T +61 2 131 525
ausgrid.com.au

Re: DA 22/11444 - 60 and 62-64 Showground Rd Gosford - Mixed use development consisting of a health services facility, retail premises, and a residential care facility.

I refer to Central Coast Council development application DA 22/11444.

This letter is Ausgrid's response under clause 45(2) of the State Environmental planning Policy (Infrastructure) 2007.

The assessment and evaluation of environmental impacts for a new development consent (or where a development consent is modified) is undertaken in accordance with requirements of Section 79C of the Environmental Planning and Assessment Act 1979. One of the obligations upon consent authorities, such as local councils, is to consider the suitability of the site for the development which can include a consideration of whether the proposal is compatible with the surrounding land uses and the existing environment.

In this regard, Ausgrid requires that due consideration be given to the compatibility of proposed development with existing Ausgrid infrastructure, particularly in relation to risks of electrocution, fire risks, Electric & Magnetic Fields (EMFs), noise, visual amenity and other matters that may impact on Ausgrid or the development.

With Regard to: Mixed use development consisting of a health services facility, retail premises, and a residential care facility at 60 and 62-64 Showground Rd Gosford

Ausgrid consents to the above mentioned development subject to the following conditions:-

Method of Electricity Connection

The method of connection will be in line with Ausgrid's Electrical Standard (ES)1 – 'Premise Connection Requirements.

Supply of Electricity

It is recommended for the nominated electrical consultant/contractor to provide a preliminary enquiry to Ausgrid to obtain advice for the connection of the proposed development to the adjacent electricity network infrastructure. An assessment will be carried out based on the enquiry which may include whether or not:

- The existing network can support the expected electrical load of the development
- A substation may be required on-site, either a pad mount kiosk or chamber style and;
- site conditions or other issues that may impact on the method of supply.

Please direct the developer to Ausgrid's website, www.ausgrid.com.au about how to connect to Ausgrid's network.

Proximity to Existing Network Assets **Overhead Powerlines**

There are existing overhead electricity network assets in Showground Rd.

Safework NSW Document – Work Near Overhead Powerlines: Code of Practice, outlines the minimum safety separation requirements between these mains/poles to structures within the development throughout the construction process. It is a statutory requirement that these distances be maintained throughout construction. Special consideration should be given to the positioning and operating of cranes and the location of any scaffolding.

The “as constructed” minimum clearances to the mains should also be considered. These distances are outlined in the Ausgrid Network Standard, NS220 Overhead Design Manual. This document can be sourced from Ausgrid’s website, www.ausgrid.com.au

Should the existing overhead mains require relocating due to the minimum safety clearances being compromised in either of the above scenarios, this relocation work is generally at the developers cost.

It is also the responsibility of the developer to ensure that the existing overhead mains have sufficient clearance from all types of vehicles that are expected be entering and leaving the site.

Underground Cables

There are existing underground electricity network assets in Showground Rd.

Special care should also be taken to ensure that driveways and any other construction activities within the footpath area do not interfere with the existing cables in the footpath. Ausgrid cannot guarantee the depth of cables due to possible changes in ground levels from previous activities after the cables were installed. Hence it is recommended that the developer locate and record the depth of all known underground services prior to any excavation in the area.

Safework Australia – Excavation Code of Practice, and Ausgrid’s Network Standard NS156 outlines the minimum requirements for working around Ausgrid’s underground cables.

Please do not hesitate to contact Warren Butson on Ph: (02) 43998122 (please quote our ref: Trim 2017/11/234) should you require any further information.

Yours faithfully,



Warren Butson
Engineer - Design Sydney North & Central Coast
Ausgrid - Asset Management
Ph: (02) 43998122