

6th September 2022

Level 4, 66 Clarence Street
Sydney, New South Wales
Australia 2000

T: +61 2 9699 3088

E: contact.nsw@meinhardtgroup.com

www.meinhardt.com.au

Proposed Water supply for 204-210 Parramatta Road, Auburn, NSW 2144

AS per the Cumberland Local Environmental Plan 2021 section 6.4 (a) please see below design intent for the potable water supply (a)

Water supply

As per the Dial before you dig Sydney water map the proposed connection will be from the 150mm C1CL Sydney water main located in the southern side of Parramatta Road, to serve the building for domestic water and firefighting water requirements that the building may need. The building will be served by a master water meter and a containment back flow prevention device in the form of an RPZD.

Sydney Water Requirements

An application for notice of requirements (NOR) from Sydney water will be obtained after the DA approval.



Kind regards

Assad Shuhaiber- Associate

NER 925927