



**accessible  
building  
solutions**

ABN 58 006 628 812

124 Upper Washington Drive  
Bonnet Bay NSW 2226

**P** (office) 0415 255 163  
**P** (Howard) 0414 876 539  
**P** (Michael) 0450 334 995  
**E** michael@absaccess.com.au

Re; 680-688 East St East Albury

To whom it may concern,

I can confirm that the BCA requires access to each unit door only. The requirements for an 850mm clear door opening and AS1428.1 circulation spaces only applies to adaptable units, and common area doors required to be accessible.

A handwritten signature in black ink, appearing to read 'Michael Moutrie'.

**Michael Moutrie**  
ACAA Accredited Access Consultant No 581