

BUILDING CODE OF AUSTRALIA 2019 AMENDMENT 1 FINAL REPORT

PROPOSED NEW LAHC RESIDENTIAL PROJECT

13 LATTY STREET, FAIRFIELD NSW 2165

Report prepared for: NSW Land and Housing Corporation
Locked Bag 4009
Ashfield NSW 1800

Attention: Phei Ding Lee

Report prepared by: Philip Chun Building Code Consulting
Suite 22.02, Level 22, Australia Square, Tower Building
264 George Street, Sydney, NSW 2000

Contact: Frank De Pasquale / Matt Shahidi

Report Ref: 021-217800_13 Latty Street, Fairfield_FinalBCA2019Amdt1_R03_20221027

Job Number: 021-217800

Date: 27 October 2022

DOCUMENT ACCEPTANCE

	Name	Signed	Date
Verified by	Frank De Pasquale		27/10/22

REVISION HISTORY

Revision No.	Prepared by	Description	Date
R01	Emrys Jones Coles	Draft BCA 2019 Amdt 1 Capability Report for Part 5 Activity Determination	27/01/22
R02	Emrys Jones Coles	Final BCA 2019 Amdt 1 Capability Report for Part 5 Activity Determination	13/05/22
R03	Matt Shahidi	Final BCA 2019 Amdt 1 Capability Report for Part 5 Activity Determination (based on revision 03 of architectural plans)	27/10/22



1.0 Introduction and Documentation

At the request of NSW Land and Housing Corporation, we offer comments and recommendations in respect to Building Code of Australia 2019 Amendment 1 compliance for the proposed social affordable housing development located at 13 Latty Street, Fairfield NSW 2165.

We have made every attempt to cover the main issues under Parts A, B, C, D, E, F, G and J of Volume One of the Building Code of Australia. Areas of the design are still being refined so that resolution will be possible prior to the issue of a Crown Design Verification Certificate (S6.28 CDVC) in accordance with S6.28 of the Environmental Planning and Assessment Act 1979 for the works.

This report does not assess the impact of the Disability Discrimination Act (DDA) which is outside the scope of the BCA nor does it include compliance with Part D3 of the BCA. Refer relevant Accessibility Report. Any Access design amendments or additional information is to be addressed prior to the issue of a Crown Design Verification Certificate (S6.28 CDVC).

This report is for the exclusive use of the client and cannot be used for any other purpose without prior permission from Philip Chun Building Code Consulting. The report is valid only in its entire form. "Philip Chun Building Code Consulting accepts no responsibility for any loss suffered as a result of any reliance upon such assessment or report other than as being accurate at the date of issue of the report".

Documentation available and assessed:

The drawings assessed are those issued by Studio Johnston Architects:

Drawing No.	Titled	Dated
A-001-001/03	Cover	27/10/22
A-100-001/03	Site Plan	27/10/22
A-100-002/03	Block Analysis	27/10/22
A-100-003/03	Site Analysis	27/10/22
A-100-004/03	Demolition Plan	27/10/22
A-100-005/03	Cut and Fill Plan	27/10/22
A-110-001/03	Ground Level	27/10/22
A-110-002/03	Level 1	27/10/22
A-110-003/03	Roof	27/10/22
A-200-001/03	East & South Elevation	27/10/22
A-200-002/03	West & North Elevation	27/10/22
A-300-001/03	Section AA & BB	27/10/22
A-420-001/03	Adaptable Unit	27/10/22

This report must be read in conjunction with plan mark ups issued by Philip Chun BC Pty Ltd.



2.0 Building Code of Australia 2019 Amendment 1 Comments

Section A – Governing Requirements

1. Compliance with the NCC (BCA) is achieved by complying with –

1. The Governing Requirements of the NCC; and
2. The Performance Requirements.

This development will comply with the Governing Requirements and adopt Performance Solutions to satisfy the Performance Requirements of the NCC (BCA). Performance Solutions are identified in the body of this report.

2. Building Assessment (applies to both two storey buildings)

Building Classification(s)	Class 2 - Residential Sole-Occupancy Units (SOU)
Rise in Storeys	2
Type of Construction	Type B
Effective Height (m)	Less than 12m

3. Building Classifications

The building is classified as follows:

Class 2 buildings

- (1) A Class 2 building is a building containing two or more sole-occupancy units.
(2) Each sole-occupancy unit in a Class 2 building is a separate dwelling.

Section B – Structure

4. Structural Provisions

The structural design engineers will need to complete the design for the proposed works in accordance with the Building Code of Australia including but not limited to:

- Compliance with the requirements of BCA B1.2, B1.4 & Specification B1.2;
- All adopted Australian Standards relevant to the design;
- Individual actions including permanent actions, imposed actions and wind, snow, ice and earthquake actions i.e. the following standards AS1170.1, AS1170.2 and AS1170.4;
- BCA Table 4 of Specification C1.1;

Structural Engineer to provide structural drawings and design statement for further assessment prior to issue of **S6.28** CDVC.

Section C – Fire Resistance / Compartmentation / Separation

5. **Type of Construction** – The building is required to comply with BCA Table 4 for Type B Construction. The Structural engineer will need to confirm and provide structural drawings and design certification prior to issue of **S6.28** DVC confirming the FRL's of the columns, slabs and load bearing walls against Table 4 of Spec C1.1.
6. **Fire Compartmentation** – Not applicable for (SOU) buildings.



7. Lightweight construction (C1.8) –

- (a) Lightweight construction must comply with Specification C1.8 if it is used in a wall system—
 - (i) that is required to have an FRL; or
 - (ii) for a lift shaft, stair shaft or service shaft or an external wall bounding a public corridor including a non fire-isolated passageway or non fire-isolated ramp, in a spectator stand, sports stadium, cinema or theatre, railway station, bus station or airport terminal.
- (b) If lightweight construction is used for the fire-resisting covering of a steel column or the like, and if—
 - (i) the covering is not in continuous contact with the column, then the void must be filled solid, to a height of not less than 1.2 m above the floor to prevent indenting; and
 - (ii) the column is liable to be damaged from the movement of vehicles, materials or equipment, then the covering must be protected by steel or other suitable material.

Details to be provided prior to issue of CDVC should lightweight construction be utilised for the internal bounding walls.

8. Non-Combustible materials (C1.9) –

- a) In a building required to be of Type A or B construction, the following building elements and their components must be non-combustible:
 - i. External walls and common walls, including all components incorporated in them including the facade covering, framing and insulation.
 - ii. The flooring and floor framing of lift pits.
 - iii. Non-loadbearing internal walls where they are required to be fire-resisting.
- b) A shaft, being a lift, ventilating, pipe, garbage, or similar shaft that is not for the discharge of hot products of combustion, that is non-loadbearing, must be of non-combustible construction in—
 - i. a building required to be of Type A construction; and
 - ii. a building required to be of Type B construction, subject to C2.10, in—
 - (A) a Class 2, 3 or 9 building; and
 - (B) a Class 5, 6, 7 or 8 building if the shaft connects more than 2 storeys.
- c) A loadbearing internal wall and a loadbearing fire wall, including those that are part of a loadbearing shaft, must comply with Specification C1.1.
- d) The requirements of (a) and (b) do not apply to gaskets, caulking, sealants and damp-proof courses.
- e) The following materials may be used wherever a non-combustible material is required:
 - i. Plasterboard.
 - ii. Perforated gypsum lath with a normal paper finish.
 - iii. Fibrous-plaster sheet.
 - iv. Fibre-reinforced cement sheeting.
 - v. Pre-finished metal sheeting having a combustible surface finish not exceeding 1mm thickness and where the Spread-of-Flame Index of the product is not greater than 0.
 - vi. Bonded laminated materials where—
 - (A) each lamina, including any core, is non-combustible and
 - (B) each adhesive layer does not exceed 1 mm in thickness and the total thickness of the adhesive layers does not exceed 2 mm; and
 - (C) the Spread-of-Flame Index and the Smoke-Developed Index of the bonded laminated material as a whole do not exceed 0 and 3 respectively.

Architect and structural engineer to note. An external wall design system certificate is to be provided prior to issue of a S6.28 CDVC.

9. Fire Hazard Properties (C1.10) – All new surface finishes, assemblies and linings are to comply with BCA Clause C1.10 (Specification C1.10) with regard to Fire Hazard Properties - **Compliance achievable. Test data sheets are to be provided prior to issue of an Occupation Verification Certificate (OVC).**

10. Ancillary Elements (C1.14) – An ancillary element must not be fixed, installed or attached to the internal parts or external face of an external wall that is required to be non-combustible unless it is one of the following;

- An ancillary element that is non-combustible.
- A gutter, downpipe or other plumbing fixture or fitting.



- A flashing.
- A grate or grille not more than 2m² in area associated with building service.
- An electrical switch, socket-outlet, cover plate or the like.
- A light fitting.
- A required sign etc.

Architect and structural engineer to note. An external wall design system certificate is to be provided prior to issue of a S6.28 CDVC.

- 11. Separation of equipment (C2.12)** – Equipment comprising of lift motors, lift control panels, emergency generators, central smoke control plant, boilers or ant battery or batteries installed in the building that have a voltage exceeding 24 volts and a capacity exceeding 10 ampere hours must be constructed with an FRL in accordance with Table 4 and Specification C1.1 BCA. **Do not appear to be proposed – Services engineer or architect to confirm.**
- 12. Electricity supply system (C2.13)** – Where emergency equipment is required in a building, all switchboards in the electrical distribution system, which sustain the electricity supply to the emergency equipment, must provide full segregation by way of enclosed metal partitions designed to prevent the spread of any fault from non-emergency equipment switchgear to the emergency equipment switchgear. **Compliance achievable. Further details required prior to the issuance of a S6.28 CDVC.**
- 13. Public corridors in Class 2 and 3 buildings (C2.14)** – In a Class 2 or 3 building, a public corridor, if more than 40m in length, must be divided at intervals of not more than 40 m with smoke-proof walls complying with Clause 2 of Specification C2.5. – **Complies.**
- 14. Protection of openings in external walls (C3.2)** – Openings within 3m of a side and rear boundary or 6m of the far boundary or from another building on the same allotment must be protected in accordance with Part C3.4 and if used, wall-wetting sprinklers are to be externally fitted. – **Complies.**
- 15. Bounding construction: Class 2 and 3 buildings (C3.11)** - SOU doors to be self-closing, tight fitting, solid core door, not less than 35mm thick. The bounding walls between residential sole occupancy units to be not less than 60/60/60 Fire Resistance Level (FRL) or -/60/60 if non-loadbearing. **Wall and door schedule to be provided prior to issue of S6.28 CDVC.**
- 16. Openings in floors and ceilings for services (C3.12)** –
 - Where a service passes through—
 - a floor that is required to have an FRL with respect to integrity and insulation; or
 - a ceiling required to have a resistance to the incipient spread of fire, the service must be installed in accordance with (b)
 - A service must be protected—
 - in a building of Type A construction, by a shaft complying with Specification C1.1; or
 - in a building of Type B or C construction, by a shaft that will not reduce the fire performance of the building elements it penetrates; or
 - in accordance with C3.15.
 - Where a service passes through a floor which is required to be protected by a fire-protective covering, the penetration must not reduce the fire performance of the covering.**Compliance achievable. Details to be provided prior to issue of S6.28 CDVC.**
- 17. Openings for service installations (C3.15)** – Electrical, electronic, plumbing, mechanical ventilation, air-conditioning or other service penetrations that are required to have an FRL with respect to integrity or insulation or a resistance to the incipient spread of fire, must be fire sealed, fire rated or otherwise comply with listed standards. **Compliance achievable. Details to be provided prior to issue of S6.28 CDVC.**



Section D – Access and Egress

18. Access and Egress - Residential Apartments (Class 2)

- Every building must have at least one exit from each storey. (D1.2) – **Complies.**
- The entrance doorway of any sole-occupancy unit must be not more than 6m from an exit or from a point from which travel in different directions to 2 exits is available or 20m from a single exit serving the storey at the level of egress to a road or open space (D1.4) – **Complies.**
- Widths of exits and corridors must be sufficient to provide safe passage for occupant egress. The unobstructed width of each exit or path of travel to an exit, except for doorways, must be not less than 1m (D1.6) – **Complies.**
- The distance between the doorway of a SOU and the point of egress to a road or open space by a way of a non-fire-isolated stairway must not exceed 60m (D1.9) – **Complies.**
- Electrical Distribution Boards (EDBs) must be enclosed by non-combustible construction or a fire protective covering with doorways and openings to be suitably smoke sealed (D2.7) – **Architect to note. Details to be provided prior to issue of S6.28 CDVC.**
- The space below a required non-fire-isolated stairway must not be enclosed to form a cupboard or similar enclosed space unless the enclosing walls and ceilings have an FRL of not less than 60/60/60 and access doorway is a self-closing -/60/30 fire door (D2.8) – **Architect to note. Details to be provided on the wall and door schedules prior to issue of S6.28 CDVC.**
- The construction of stairs, landings, thresholds, barriers, balustrades and handrails must meet the requirements of the BCA. **Detailed elevations to be provided prior to issue of S6.28 CDVC.**
- Signage should be provided to ground floor exits. The signage should be in accordance with D3.6 of the BCA. **Details to be provided prior to issue of S6.28 CDVC.**
- Fall protection needed to unit bedroom window openings located less than 1.7m high required in accordance with Clause D2.24 - **Compliance readily achievable. Details to be provided prior to issue of S6.28 CDVC.**

Section E – Services and Equipment

19. **Smoke Detection and Alarm (Spec E2.2a)** – An automatic smoke detection and alarm system complying with Specification E2.2a must be provided throughout the building. Note Spec E2.2a also requires a Building Occupant Warning System in accordance with Clause 7 of Spec E2.2a. **Fire services consultant to provide details prior to issue of S6.28 CDVC.**
20. **Extinguishers (E1.6)** – Fire extinguishers are required to be installed to the class 2 buildings parts in lieu of fire hose reels. Extinguishers are to be of an ABE type and distributed throughout the floors so that the travel distance from the entrance doorway of any sole occupancy unit is not more than 10m from a fire extinguisher. Fire extinguishers must be provided to all locations which are deemed a potential risk to the occupants of the building, i.e. areas such as main switchboards – **Fire services consultant to provide details prior to issue of S6.28 CDVC.**
21. **Exit and emergency lighting** – Emergency lighting must be installed in every passageway corridor, hallway or the like having a length of more than 6m from the entrance doorway of any sole-occupancy unit to the doorway opening directly to a road or open space. **Electrical consultant to provide details prior to issue of S6.28 CDVC.**



Section F – Health and Amenity

22. **Damp and Weatherproofing (FP1.4)** - The roofing and external wall systems shall be designed using materials and methods to prevent unhealthy or dangerous conditions or loss of amenity for occupants and undue dampness or deterioration of building element – ***Performance solution to be provided for the wall construction and weatherproofing to ensure compliance. Assessment by the architects and designers is required to validate that the walls will meet the performance requirements of the BCA.***

In particular, the performance solution must consider masonry construction in respect to finished floor levels on the outside and inside and how required clearances below the damp proof course and weepholes will be maintained. Also, installation of the termite management system (if required) and the manufacturer's specifications to be considered. Details to be provided prior to issue of S6.28 CDVC.

23. **Condensation and water vapour management (FP6.1)** - Condensation must be managed to help deal with potential health risks and amenity issues – ***Details to be provided prior to issue of S6.28 CDVC.***
24. **Stormwater drainage (F1.1)** - Stormwater drainage must comply with AS/NZS 3500.3. ***Compliance achievable. Details to be provided prior to issue of S6.28 CDVC.***
25. **External above ground membranes (F1.4)** - Waterproofing membranes for external above ground use must comply with AS 4654.1 and AS 4654.2. ***Compliance achievable. Details to be provided prior to issue of S6.28 CDVC.***
26. **Waterproofing of wet areas in buildings (F1.7)** - (a) In a Class 2 building, building elements in wet areas must— (i) be water resistant or waterproof in accordance with Table F1.7; and (ii) comply with AS 3740. ***Compliance achievable. Details to be provided prior to issue of S6.28 CDVC.***
27. **Provision of floor wastes (F1.11)** In a Class 2 building, a bathroom or laundry located at any level above a sole-occupancy unit or public space must have—(a) a floor waste; and (b) the floor graded to the floor waste to permit drainage of water. ***Compliance achievable. Details to be provided prior to issue of S6.28 CDVC.***
28. **Sanitary Facilities (F2.1)** – Sanitary and other facilities for Class 2 building and a must be provided in accordance with Table F2.1.
Within each sole-occupancy unit, provide—
- a) a kitchen sink and facilities for the preparation and cooking of food; and
 - b) a bath or shower; and
 - c) a closet pan and washbasin.
- Laundry facilities, provide either—
- a) in each sole-occupancy unit—
 - (i) clothes washing facilities, comprising at least one washtub and space for a washing machine; and
 - (ii) clothes drying facilities comprising—
 - A. clothes line or hoist with not less than 7.5 m of line; or
 - B. space for one heat-operated drying cabinet or appliance in the same room as the clothes washing facilities; or
- Note: A kitchen sink or washbasin must not be counted as a laundry washtub.
Compliance achievable.
29. **Construction for sanitary facilities (F2.5)** - Doors to fully enclosed sanitary compartments are to open outwards, or slide or have 1.2 metres clear space between door and closet pan or be readily removable from the outside of the sanitary compartment. ***Details to be provided prior to issue of S6.28 CDVC.***



30. **Room Sizes** - The minimum ceiling height of 2.4m is required to all habitable rooms excluding kitchens. All other rooms are required to have a minimum height of 2.1m. Note that SEPP 65 will require 2.7m minimum ceiling height to habitable rooms. – **Complies.**

31. **Light** - Natural light must be provided to all habitable rooms within each SOU in accordance with Clause F4.2 of the BCA. The windows should have an aggregate light transmitting area of not less than 10% of the floor area of the room. Window schedule required for compliance. **Window schedule to include % calculations for assessment. Details to be provided prior to issue of S6.28 CDVC.**

Artificial lighting must comply with Clause F4.4 of the BCA and AS/NZS 1680.0-2009.

32. **Ventilation** - Natural ventilation be provided to all habitable rooms, sanitary compartment, bathroom, shower room, laundry and any other room occupied by a person for any purpose in accordance with Clause F4.6 of the BCA. The openings must consist of windows, doors or other devices which can be opened with a ventilating area not less than 5% of the floor area of the room required to be ventilated. Mechanical ventilation to AS1668.2 must be provided where natural ventilation cannot be provided. **Window schedule to include % calculations for assessment. Details to be provided prior to issue of S6.28 CDVC.**

33. **Sound Insulation** - The proposal will need to meet the sound insulation requirements of Part F5 of the BCA – Compliance readily achievable. **Acoustic Consultant to provide a detailed report for compliance prior to issue of S6.28 CDVC.**

Section G - Ancillary Provisions

34. **Window Cleaning NSW (G1.101)**

- a) A building must provide for a safe manner of cleaning any windows located 3 or more storeys above ground level.
- b) A building satisfies (a) where—
 - (i) the windows can be cleaned wholly from within the building; or
 - (ii) provision is made for the cleaning of the windows by a method complying with the Work Health and Safety Act 2011 and regulations made under that Act.

Does not apply as the building is less than 3 stories above the ground level.

35. **Occupiable Outdoor Areas – Fire Hazard Properties (G6.2) –**

- (a) Subject to (b), a lining, material or assembly in an occupiable outdoor area must comply with C1.10 as for an internal element.
- (b) The following fire hazard properties of a lining, material or assembly in an occupiable outdoor area are not required to comply with C1.10:
 - (i) Average specific extinction area.
 - (ii) Smoke-Developed Index.
 - (iii) Smoke development rate.
 - (iv) Smoke growth rate index (SMOGR_{RC}).

Does not apply to private residential balconies.

Section J – Energy Efficiency

36. **Energy Efficiency (Part J) –** Energy efficiency requirements as prescribed by NSW Parts J(A)1 to J(A)5 must be complied with.

37. **BASIX –** A BASIX certificate is to accompany the Development Application hence, BASIX certificate to be submitted by others.



Conclusion

We have assessed the drawings with respect to the Building Code of Australia 2019 Amendment 1. We are confident that the design is generally capable of meeting the Deemed-to-Satisfy and Performance Requirements of the Building Code of Australia 2019 Amendment 1. Areas of the design are still being developed but are unlikely to impact on the Part 5 Activity Submission, these areas of the design will be addressed prior to issue of S6.28 CDVC.