



### Custance Associates Australia Proposed Residential Development

To be built at 17-27 Hardwicke Street, Riverwood NSW 2210

Issue	File Ref	Description	Author	Date
A	23-4669R	NatHERS and BASIX Assessment – Draft report	MF	15/12/23
B	23-4669R	NatHERS and BASIX Assessment – Draft report	MF	16/07/24
C	23-4669R	NatHERS and BASIX Assessment	MF	07/08/24

This report has been prepared by Efficient Living Pty Ltd on behalf of our client Custance Associates Australia. Efficient Living prepares all reports in accordance with the BASIX Thermal Comfort Protocol and is backed by professional indemnity insurance. This report takes into account our Client's instructions and preferred building inclusions.



Report Contact: Mariana Foganhole  
Email: [mariana@efficientliving.com.au](mailto:mariana@efficientliving.com.au)

License Holder: Stefanie Simpson  
Accreditation Number: HERA10035

---

#### Prepared For:

Custance Associates Australia  
Richard Wilkinson  
[richard@custance.com.au](mailto:richard@custance.com.au)

Mezzanine Level, 50 Carrington Street,  
Sydney, NSW 2000  
+61 406 278 219

---

#### Introduction

Efficient Living has investigated the estimated thermal comfort, water and energy usage of the proposed development to be built at 17-27 Hardwicke Street, Riverwood.

Heating and cooling loads for the development have been determined using Hero v3.1 thermal comfort simulation software. The report is based on the architectural drawings provided by Custance Associates Australia. For further details refer to the individual BASIX Certificate(s) and Efficient Living's inclusions summary respectively.

This report is based on the floor plans, elevations and sections prepared by Custance Associates Australia received on 03/07/2024 – DA-001 to DA-007, DA-011 to DA-013 and DA-025

---

#### Analysis

The BASIX Assessment is divided into three sections; Water, Thermal Comfort and Energy, each independently measuring the efficiency of the development.

BASIX requires a minimum target of 40% for the water section, a pass or fail for the thermal comfort section, and a minimum required target of 25% for the energy section.

---

#### Water

The proposed Development has achieved the BASIX Water Target of 40%.

The water usage of the development is calculated based on the number and efficiency of permanent fixtures and appliances such as taps, showerheads and toilet, the dish washer and clothes washing machine.

The size of the rainwater tank and number of connections may have a significant impact on your water score as does the area of gardens and lawns whether or not low water plant species are incorporated.

---

#### Thermal Comfort

Thermal Comfort targets are set by the Department of Planning in the form of heating and cooling caps. The buildings thermal physics are measured using Hero v3.1 Thermal Comfort Simulation Software. This calculates the expected level of energy required to heat and cool each dwelling per annum, expressed in megajoules per square metre of floor area (MJ/m<sup>2</sup>).

Each unit has individual heating and cooling caps applied. Accompanying these individual caps are average heating and cooling caps applied to the whole development. The average caps are lower, or harder to comply with than the individual unit caps.

---

#### Energy

The proposed development has achieved the Energy target of 67% to pass this section.

The energy usage of the development is calculated based on the efficiency of fixed appliances that will be used. This includes the air-conditioning system, hot water system, lighting, exhaust fans, cook top, oven, and clothes drying facilities.

---

### Thermal Comfort Inclusions Summary

The inclusions as outlined below have been incorporated in each unit to allow them to reach their environmental sustainability targets.

---

#### Glazing Doors/Windows

Glazed windows and doors:

##### Group A – awning

U-value: 6.70 (equal to or lower than) SHGC: 0.57 (±5%)

##### Group B – sliding doors and fixed glazing

U-value: 6.70 (equal to or lower than) SHGC: 0.70 (±5%)

#### Upgrade to Unit 25:

Glazed windows and doors:

##### Group A – awning

U-value: 4.50 (equal to or lower than) SHGC: 0.50 (±5%)

##### Group B – sliding doors and fixed glazing

U-value: 4.50 (equal to or lower than) SHGC: 0.61 (±5%)

Given values are AFRC total window system values (glass and frame)

Note: BASIX Thermal Comfort Protocol Table 1 SHGC value of the unit should be within the range specified on the Assessor Certificate.

**Window frame Colour** - Default colour modelled

#### Window restrictors

Window restrictors are modelled to all windows with a sill height under 1.7m and a fall height over 2m from the floor level of the room.

---

#### Roof and ceiling

Minimum 150mm Concrete roof, no insulation above

Plasterboard ceiling **with R4.0 insulation** (insulation only value) to soffit of concrete where roof is over.

Plasterboard ceiling, no insulation where neighbouring units are above.

#### External Colour

Medium ( $0.475 < SA < 0.7$ )

---

#### Ceiling Penetrations

No downlights accounted for in NatHERS modelling.

Sealed exhaust fan to Kitchen and bathroom.

---

### Ceiling Fans

900mm ceiling fans to living and bedrooms.

---

### External Wall

Brick veneer 110mm Brick – 109 air gap – 92mm metal stud framed wall **with R2.0 insulation (insulation only value)** – 38mm Furring channel – 26mm Plasterboard

Lightweight framed wall 25mm Metal cladding- 54mm furring channel – 26mm plasterboard – 92mm metal stud **with R2.0 insulation (insulation only value)** – 45mm air gap - 92mm metal stud **with R2.0 insulation (insulation only value)** – 28mm furring channel – 13mm plasterboard

**No insulation to concrete columns within the external wall envelope**

### External Colour

Brick wall - Medium ( $0.475 < SA < 0.7$ )

Metal cladding wall – Surfmist SA 0.33

---

### Inter-tenancy walls

Hebel wall – 13mm plasterboard - 75mm Hebel wall - 76mm metal stud - 13mm plasterboard to walls between neighbouring dwellings, no insulation required.

Framed wall – 13mm plasterboard - 76mm metal stud **with minimum R1.2 insulation (insulation only value)** - 13mm plasterboard to walls between dwelling and common corridor, no insulation required.

Minimum 150mm concrete with furring channel and plasterboard lining to all walls adjacent to lift shafts and fire stairs, no insulation required.

**No insulation to concrete columns between habitable areas and common areas**

---

### Walls within dwellings

Plasterboard on studs – no insulation

Concrete column no insulation

---

### Floors

Minimum 200mm Concrete slab on ground, no insulation required.

Minimum 200mm Suspended Concrete slab between levels, no insulation required.

### Dwelling 12 and 17:

Minimum 200mm Suspended Concrete slab with R1.0 insulation (insulation only value) between dwelling and waste/pump room.

---

### Floor coverings

Carpet to bedrooms, tiles elsewhere

---

### External Shading

Shading as per stamped documentation

Fixed exterior horizontal screens as per plans and elevations which provide 50% shading



450mm overhang window hood as per plans and elevations.

---

#### BASIX water inclusions

Score 40/40

---

##### Fixtures within units

Showerheads: 4 star Low flow ( $>4.5\text{L}$  but  $\leq 6\text{L}/\text{min}$ )

Toilets: 4 star

Kitchen taps: 4 star

Bathroom vanity taps: 4 star

---

##### Fixtures within common areas

None

---

##### Appliances within units

None specified.

---

##### Central rainwater storage

Tank size: 5,000L

Collecting from 1000m<sup>2</sup> roof area

Connected to outdoor tap for irrigation of common area landscaping.

---

##### Indigenous and low water use species

755m<sup>2</sup> (100% of common garden beds)

---

#### BASIX Energy Inclusions

Score 67/67

---

##### Hot water system

Individual electric instantaneous

---

##### Lift motors

All lifts to have gearless traction with VVVF motor

---

##### Appliances and other efficiency measures within units

Electric cooktop & electric oven

Dishwashers: none specified

Clothes dryers: none specified



---

Private outdoor clothes line: yes

---

#### Heating and cooling within units

All units to have individual, single phase non ducted air conditioning, to living areas, and at least 1 bedroom.

A minimum efficiency of EER 3.0 – 3.5 is required for cooling; and

A minimum efficiency of EER 3.0 – 3.5 is required for heating.

---

#### Artificial lighting within units

All light fittings within each room are to have sealed LED fixtures installed

---

#### Ventilation within units

Bathroom: individual fan, ducted to roof or façade – interlocked to light / timer off

Laundry: individual fan, ducted to roof or façade – interlocked to light

Kitchen range hood: Individual fan, ducted to roof or façade – manual on / off switch

---

#### Ventilation to common areas

Garbage rooms – Naturally ventilated

Plant / service rooms – Naturally ventilated

Lobbies and Hallways – Naturally ventilated

---

#### Artificial lighting to common areas

Lifts – Light emitting diodes (LEDs) connected to lift call button

Garbage rooms – Light emitting diodes (LEDs) with motion sensor

Plant / service rooms – Light emitting diodes (LEDs) with motion sensor

Lobbies and Hallways – Light emitting diodes (LEDs) with zoned switching and motion sensors

---

#### Alternative Energy

Photovoltaic system: rated electrical output (min.) 20 peak kW

---

Issued in accordance with BASIX Thermal Comfort Simulation Method

Certificate # HR-9TJLCY-01							Accreditation # HERA10035
Thermal performance specifications							
Unit number	Number of Bedrooms	Floor area (m <sup>2</sup> )		Predict. loads (MJ/m <sup>2</sup> /y)		Star Rating	Thermal Comfort Upgrades
		Con.	Uncon.	Heat	Cool (Sens & Lat)		
U01	2	81.8	9.8	15.9	4.8	8.0	
U02	1	61	0	15.8	3.1	8.2	
U03	1	61	0	14.4	2.7	8.4	
U04	1	61	0	16.5	2.5	8.2	
U05	2	81.5	0	20.4	3.8	7.6	
U06	2	78.4	0	15.4	3.4	8.2	
U07	2	76.3	0	10.4	5.4	8.5	
U08	1	61.5	0	11.2	5.7	8.4	
U09	2	71.7	10	18.2	5.0	7.7	
U10	2	81.8	9.8	18.0	12.2	6.9	
U11	1	61	0	6.1	13.0	8.2	
U12	1	62.6	0	22.7	7.7	6.9	
U13	1	61	0	8.5	11.5	8.1	
U14	1	61	0	13.5	9.7	7.7	
U15	2	81.5	0	23.5	10.9	6.4	
U16	2	78.3	0	9.2	9.2	8.3	
U17	1	61.6	0	26.5	6.5	6.6	
U18	1	61.6	0	10.3	14.0	7.6	
U19	1	61.6	0	8.1	16.5	7.6	
U20	2	71.7	10	17.1	11.9	7.1	
U21	1	61	0	11.8	14.1	7.4	
U22	1	62.7	0	13.0	15.0	7.2	
U23	1	61	0	13.5	15.4	7.1	
U24	1	61	0	20.4	15.2	6.3	
U25	2	81.5	0	25.9	11.7	6.1	Glazing upgrade
U26	2	78.4	0	14.3	13.6	7.2	
U27	1	61.6	0	19.4	11.0	6.9	
U28	1	61.6	0	17.8	16.7	6.4	
U29	2	81	0	22.9	14.2	6.1	

# Nationwide House Energy Rating Scheme® Class 2 Summary

**NatHERS® Certificate No. #HR-9TJLCY-01**

Generated on 07 Aug 2024 using Hero 4.1

## Property

**Address** 17-27 Hardwicke Street, Riverwood, NSW, 2210  
**Lot/DP** 11/-/36368  
**NatHERS climate zone** 56 - Mascot AMO



## Accredited assessor

**Name** Stefanie Simpson  
**Business name** Efficient Living  
**Email** stefanie@efficientliving.com.au  
**Phone** +61 299706181  
**Accreditation No.** 10035  
**Assessor Accrediting Organisation** HERA

## Verification

To verify this certificate, scan the QR code or visit <http://www.hero-software.com.au/pdf/HR-9TJLCY-01>.  
When using either link, ensure you are visiting <http://www.hero-software.com.au>



## National Construction Code (NCC) requirements

The NCC allows the use of NatHERS accredited software to comply with the energy efficiency requirements for houses (Class 1 buildings) and apartments (Class 2 sole-occupancy units and Class 4 parts of buildings). The applicable requirements for houses are detailed in Specification 42 of NCC Volume Two. For apartments the requirements are detailed in clauses J3D3 and J3D15 of NCC Volume One.

NCC 2022 includes enhanced thermal performance requirements for houses and apartments. It also includes a new whole-of-home annual energy use budget which applies to the major equipment in the home.

The NCC, and associated ABCB Standards and support material, can be accessed at [www.abcb.gov.au](http://www.abcb.gov.au).

Note, variations and additions to the NCC energy efficiency requirements may apply in some states and territories.

## Summary of all dwellings

Certificate number and link	Unit Number	Heating load (load limit) (MJ/m².yr)	Cooling load (load limit) (MJ/m².yr)	Total load (MJ/m².yr)	Star Rating	Whole of Home Rating
<a href="#">HR-C0JHXG-01</a>	U01	15.9 (33)	4.8 (20)	20.7	8.0	n/a
<a href="#">HR-RVEGRA-01</a>	U02	15.8 (33)	3.1 (20)	18.8	8.2	n/a
<a href="#">HR-04AEYL-01</a>	U03	14.4 (33)	2.7 (20)	17.2	8.4	n/a

## Thermal performance Star rating



**NATIONWIDE  
HOUSE**  
ENERGY RATING SCHEME®

The rating above is the average of all dwellings in this summary.

For more information on your dwelling's rating see:  
[www.nathers.gov.au](http://www.nathers.gov.au)

## NCC heating and cooling maximum loads MJ/m².yr

Limits taken from ABCB Standard 2022

	Heating	Cooling
Average load	15.9	9.9
Maximum load	26.5	16.7
Average limit	29.7	21.2
Maximum limit	32.9	20.4

## Whole of Home performance rating

No Whole of Home performance rating generated for this certificate or not completed for all dwellings.

## Summary of all dwellings

Certificate number and link	Unit Number	Heating load (load limit) (MJ/m <sup>2</sup> .yr)	Cooling load (load limit) (MJ/m <sup>2</sup> .yr)	Total load (MJ/m <sup>2</sup> .yr)	Star Rating	Whole of Home Rating
<a href="#">HR-V69OAP-01</a>	U04	16.5 (33)	2.5 (20)	19.0	8.2	n/a
<a href="#">HR-OZ3GZM-01</a>	U05	20.4 (33)	3.8 (20)	24.3	7.6	n/a
<a href="#">HR-0TBHEU-01</a>	U06	15.4 (33)	3.4 (20)	18.9	8.2	n/a
<a href="#">HR-Q8VUC2-01</a>	U07	10.4 (33)	5.4 (20)	15.7	8.5	n/a
<a href="#">HR-5C5V7L-01</a>	U08	11.2 (33)	5.7 (20)	16.9	8.4	n/a
<a href="#">HR-L5FCJJ-01</a>	U09	18.2 (33)	5.0 (20)	23.2	7.7	n/a
<a href="#">HR-G8G14I-01</a>	U10	18.0 (33)	12.2 (20)	30.2	6.9	n/a
<a href="#">HR-CIKZ8C-01</a>	U11	6.1 (33)	13.0 (20)	19.1	8.2	n/a
<a href="#">HR-AI365E-01</a>	U12	22.7 (33)	7.7 (20)	30.4	6.9	n/a
<a href="#">HR-XHGEV2-01</a>	U13	8.5 (33)	11.5 (20)	20.0	8.1	n/a
<a href="#">HR-CE3MKT-01</a>	U14	13.5 (33)	9.7 (20)	23.2	7.7	n/a
<a href="#">HR-KMWKSG-01</a>	U15	23.5 (33)	10.9 (20)	34.4	6.4	n/a
<a href="#">HR-B3GGQ1-01</a>	U16	9.2 (33)	9.2 (20)	18.3	8.3	n/a
<a href="#">HR-NZQJEE-01</a>	U17	26.5 (33)	6.5 (20)	32.9	6.6	n/a
<a href="#">HR-QJ3RA4-01</a>	U18	10.3 (33)	14.0 (20)	24.4	7.6	n/a
<a href="#">HR-2UNYRP-01</a>	U19	8.1 (33)	16.5 (20)	24.5	7.6	n/a
<a href="#">HR-SKR9E9-01</a>	U20	17.1 (33)	11.9 (20)	29.0	7.1	n/a
<a href="#">HR-20GQ44-01</a>	U21	11.8 (33)	14.1 (20)	25.9	7.4	n/a
<a href="#">HR-9GRI43-01</a>	U22	13.0 (33)	15.0 (20)	28.1	7.2	n/a
<a href="#">HR-KN1JTC-01</a>	U23	13.5 (33)	15.4 (20)	28.9	7.1	n/a
<a href="#">HR-4K9CI0-01</a>	U24	20.4 (33)	15.2 (20)	35.6	6.3	n/a
<a href="#">HR-52GT8D-01</a>	U25	25.9 (33)	11.7 (20)	37.5	6.1	n/a
<a href="#">HR-VR7FVI-01</a>	U26	14.3 (33)	13.6 (20)	28.0	7.2	n/a
<a href="#">HR-F6A293-01</a>	U27	19.4 (33)	11.0 (20)	30.4	6.9	n/a
<a href="#">HR-JE0G5F-01</a>	U28	17.8 (33)	16.7 (20)	34.5	6.4	n/a
<a href="#">HR-JQIH9-01</a>	U29	22.9 (33)	14.2 (20)	37.1	6.1	n/a
Averages	29x (Total)	15.9	9.9	25.8	7.4	n/a
Maximum Loads and Minimum Ratings		26.5	16.7	37.5	6.1	n/a

## Explanatory notes

### About the ratings

The thermal performance star rating in this Certificate is the average rating of all NCC Class 2 dwellings in an apartment block. The Whole of Home performance rating in this Certificate is the lowest rating for the apartment block. Individual unit ratings are listed in the 'Summary of all dwellings' section of this Certificate.

NatHERS ratings use computer modelling to evaluate a home's energy efficiency and performance. They use localised climate data and standard assumptions on how people use their home to predict the energy loads and societal cost. The thermal performance star rating uses the home's building specifications, layout, orientation and fabric (i.e. walls, windows, floors, roofs and ceilings) to predict the heating and cooling energy loads. The Whole of Home performance rating uses information about the home's appliances and onsite energy production and storage to estimate the home's societal cost.

For more details about an individual dwelling's assessment, refer to the individual dwelling's NatHERS Certificate (accessible via link).

### Accredited Assessors

For high quality NatHERS Certificates, always use an accredited or licenced assessor registered with an Assessor Accrediting Organisation (AAO). AAOs have strict quality assurance processes, and professional development requirements ensuring consistently high standards for assessments.

Non-accredited assessors (Raters) have no ongoing training requirements and are not quality assured.

Licensed assessors in the Australian Capital Territory (ACT) can produce assessments for regulatory purposes only, using endorsed software, as listed on the ACT licensing register.

Any queries about this report should be directed to the assessor. If the assessor is unable to address questions or concerns, contact the AAO specified on the front of this certificate.

### Disclaimer

The NatHERS Certificate format is developed by the NatHERS Administrator. However, the content in certificates is entered by the assessor. It is the assessor's responsibility to use NatHERS accredited software correctly and follow the NatHERS Technical Note to produce a NatHERS Certificate.

The predicted annual energy use, cost and greenhouse gas emissions in this NatHERS Certificate are an estimate based on an assessment of the dwelling's design by the assessor. It is not a prediction of actual energy use, cost or emissions. The information and ratings may be used to compare how other dwellings are likely to perform when used in a similar way.

Information presented in this report relies on a range of standard assumptions (both embedded in NatHERS accredited software and made by the assessor who prepared this report), including assumptions about occupancy, behaviour, appliance performance, indoor air temperature and local climate.

Not all assumptions made by the assessor while using the NatHERS accredited software tool are presented in this report and further details or data files may be available from the assessor.

# BASIX<sup>®</sup>Certificate

Building Sustainability Index [www.basix.nsw.gov.au](http://www.basix.nsw.gov.au)

## Multi Dwelling

Certificate number: 1758935M

This certificate confirms that the proposed development will meet the NSW government's requirements for sustainability, if it is built in accordance with the commitments set out below. Terms used in this certificate, or in the commitments, have the meaning given by the document entitled "BASIX Definitions" dated 10/09/2020 published by the Department. This document is available at [www.basix.nsw.gov.au](http://www.basix.nsw.gov.au)

Secretary

Date of issue: Wednesday, 07 August 2024

To be valid, this certificate must be submitted with a development application or lodged with a complying development certificate application within 3 months of the date of issue.



### Project summary

Project name	17-27 Hardwicke Street, Riverwood
Street address	17 HARDWICKE STREET RIVERWOOD 2210
Local Government Area	GEORGES RIVER
Plan type and plan number	Deposited Plan 36368
Lot No.	11
Section no.	-
No. of residential flat buildings	1
Residential flat buildings: no. of dwellings	29
Multi-dwelling housing: no. of dwellings	0
No. of single dwelling houses	0

### Project score

Water	✓ 40	Target 40
Thermal Performance	✓ Pass	Target Pass
Energy	✓ 67	Target 67
Materials	✓ -63	Target n/a

### Certificate Prepared by

Name / Company Name: Efficient Living Pty Ltd

ABN (if applicable): 82116346082

# Description of project

Project address	
Project name	17-27 Hardwicke Street, Riverwood
Street address	17 HARDWICKE STREET RIVERWOOD 2210
Local Government Area	GEORGES RIVER
Plan type and plan number	Deposited Plan 36368
Lot No.	11
Section no.	-
Project type	
No. of residential flat buildings	1
Residential flat buildings: no. of dwellings	29
Multi-dwelling housing: no. of dwellings	0
No. of single dwelling houses	0
Site details	
Site area (m²)	3658
Roof area (m²)	1198
Non-residential floor area (m²)	0
Residential car spaces	14
Non-residential car spaces	0

Common area landscape		
Common area lawn (m²)	345	
Common area garden (m²)	755	
Area of indigenous or low water use species (m²)	755	
Assessor details and thermal loads		
Assessor number	HERA10035	
Certificate number	HR-9TJLCY-01	
Climate zone	56	
Project score		
Water	✔ 40	Target 40
Thermal Performance	✔ Pass	Target Pass
Energy	✔ 67	Target 67
Materials	✔ -63	Target n/a

## Description of project

The tables below describe the dwellings and common areas within the project

### Residential flat buildings - Building 1, 29 dwellings, 3 storeys above ground

Dwelling no.	No. of bedrooms	Conditioned floor area (m <sup>2</sup> )	Unconditioned floor area (m <sup>2</sup> )	Area of garden & lawn (m <sup>2</sup> )	Indigenous species (min area m <sup>2</sup> )
U01	2	81.8	9.8	1.5	0
U05	2	81.5	0	14.5	0
U09	2	71.7	10	2.5	0
U13	1	61	0	0	0
U17	1	61.6	0	0	0
U21	1	61	0	0	0
U25	2	81.5	0	0	0
U29	2	81	0	0	0

Dwelling no.	No. of bedrooms	Conditioned floor area (m <sup>2</sup> )	Unconditioned floor area (m <sup>2</sup> )	Area of garden & lawn (m <sup>2</sup> )	Indigenous species (min area m <sup>2</sup> )
U02	1	61	0	14.5	0
U06	2	78.4	0	0	0
U10	2	81.8	9.8	0	0
U14	1	61	0	0	0
U18	1	61.6	0	0	0
U22	1	62.7	0	0	0
U26	2	78.4	0	0	0

Dwelling no.	No. of bedrooms	Conditioned floor area (m <sup>2</sup> )	Unconditioned floor area (m <sup>2</sup> )	Area of garden & lawn (m <sup>2</sup> )	Indigenous species (min area m <sup>2</sup> )
U03	1	61	0	14.5	0
U07	2	76.3	0	8	0
U11	1	61	0	0	0
U15	2	81.5	0	0	0
U19	1	61.6	0	0	0
U23	1	61	0	0	0
U27	1	61.6	0	0	0

Dwelling no.	No. of bedrooms	Conditioned floor area (m <sup>2</sup> )	Unconditioned floor area (m <sup>2</sup> )	Area of garden & lawn (m <sup>2</sup> )	Indigenous species (min area m <sup>2</sup> )
U04	1	61	0	14.5	0
U08	1	61.5	0	10	0
U12	1	62.6	0	0	0
U16	2	78.3	0	0	0
U20	2	71.7	10	0	0
U24	1	61	0	0	0
U28	1	61.6	0	0	0

**Description of project**

The tables below describe the dwellings and common areas within the project

# Schedule of BASIX commitments

## 1. Commitments for Residential flat buildings - Building 1

### (a) Buildings

#### (i) Materials

### (b) Dwellings

#### (i) Water

#### (ii) Energy

#### (iii) Thermal Performance

### (c) Common areas and central systems/facilities

#### (i) Water

#### (ii) Energy

## 2. Commitments for multi-dwelling housing

### (a) Dwellings

#### (i) Water

#### (ii) Energy

#### (iii) Thermal Performance and Materials

## 3. Commitments for common areas and central systems/facilities for the development (non-building specific)

### (b) Common areas and central systems/facilities

#### (i) Water

#### (ii) Energy

## Schedule of BASIX commitments

The commitments set out below regulate how the proposed development is to be carried out. It is a condition of any development consent granted, or complying development certificate issued, for the proposed development, that BASIX commitments be complied with.

### 1. Commitments for Residential flat buildings - Building 1

#### (a) Buildings

(i) Materials	Show on DA plans	Show on CC/CDC plans & specs	Certifier check
(a) The details of the proposed development on the Assessor Certificate must be consistent with the details shown in this BASIX Certificate, including the details shown in the "Floor types", "External wall types", "Internal wall types", "Ceiling and roof types", "Frames" and "Glazing" tables below.			✓
(b) The applicant must show on the plans accompanying the application for a construction certificate (or complying development certificate, if applicable), all specifications included in the tables below.		✓	
(c) The applicant must construct the floors, walls, roof, ceiling and roof, windows, glazed doors and skylights of the development in accordance with the specifications listed in the tables below. In the case of glazing, a 5% variance from the area values listed in the "Frames" and "Glazing" tables is permitted.	✓	✓	✓
(d) The applicant must show through receipts that the materials purchased for construction are consistent with the specifications listed in the below tables.			✓

#### Floor types

Floor type	Area (m2)	Insulation	Low emissions option
concrete slab on ground, frame:	891	-	none
suspended floor above open subfloor, frame: suspended concrete slab	284	-	-
floors above habitable rooms, frame: suspended concrete slab	1272	-	-
suspended floor above enclosed subfloor, frame: suspended concrete slab	276	-	-

#### External wall types

External wall type	Construction type	Area (m2)	Low emissions option	Insulation
External wall type 1	brick veneer, frame: light steel frame	1714	-	-

External wall types				
External wall type	Construction type	Area (m2)	Low emissions option	Insulation
External wall type 2	framed (metal clad),frame:light steel frame	671	-	-
External wall type 3	off form concrete,frame:no frame	406	none	-

Internal wall types			
Internal wall type	Construction type	Area (m2)	Insulation
Internal wall type 1	75 mm AAC panel, frame:light steel frame	835	-
Internal wall type 2	plasterboard, frame:light steel frame	1220	-

Reinforcement concrete frames/columns		
Building has reinforced concrete frame/columns?	Volume (m³)	Low emissions option
yes	0.5	-

Ceiling and roof types			
Ceiling and roof type	Area (m²)	Roof Insulation	Ceiling Insulation
concrete - plasterboard internal, frame: no frame	1077	-	-
framed - metal roof, frame: heavy steel post and beam frame	121	-	-

Glazing types			Frame types				
Single glazing (m²)	Double glazing (m²)	Triple glazing (m²)	Aluminium frames (m²)	Timber frames (m²)	uPVC frames (m²)	Steel frames (m²)	Composite frames (m²)
436	-	-	436	-	-	-	-

## (b) Dwellings

(i) Water	Show on DA plans	Show on CC/CDC plans & specs	Certifier check
(a) The applicant must comply with the commitments listed below in carrying out the development of a dwelling listed in a table below.			
(b) The applicant must plant indigenous or low water use species of vegetation throughout the area of land specified for the dwelling in the "Indigenous species" column of the table below, as private landscaping for that dwelling. (This area of indigenous vegetation is to be contained within the "Area of garden and lawn" for the dwelling specified in the "Description of Project" table).	✓	✓	
(c) If a rating is specified in the table below for a fixture or appliance to be installed in the dwelling, the applicant must ensure that each such fixture and appliance meets the rating specified for it.		✓	✓
(d) The applicant must install an on demand hot water recirculation system which regulates all hot water use throughout the dwelling, where indicated for a dwelling in the "HW recirculation or diversion" column of the table below.		✓	✓
(e) The applicant must install: (aa) a hot water diversion system to all showers, kitchen sinks and all basins in the dwelling, where indicated for a dwelling in the "HW recirculation or diversion" column of the table below; and (bb) a separate diversion tank (or tanks) connected to the hot water diversion systems of at least 100 litres. The applicant must connect the hot water diversion tank to all toilets in the dwelling.		✓ ✓	✓ ✓
(e) The applicant must not install a private swimming pool or spa for the dwelling, with a volume exceeding that specified for it in the table below.	✓	✓	
(f) If specified in the table, that pool or spa (or both) must have a pool cover or shading (or both).		✓	
(g) The pool or spa must be located as specified in the table.	✓	✓	
(h) The applicant must install, for the dwelling, each alternative water supply system, with the specified size, listed for that dwelling in the table below. Each system must be configured to collect run-off from the areas specified (excluding any area which supplies any other alternative water supply system), and to divert overflow as specified. Each system must be connected as specified.	✓	✓	✓

	Fixtures					Appliances		Individual pool				Individual spa		
Dwelling no.	All shower-heads	All toilet flushing systems	All kitchen taps	All bathroom taps	HW recirculation or diversion	All clothes washers	All dish-washers	Volume (max volume)	Pool cover	Pool location	Pool shaded	Volume (max volume)	Spa cover	Spa shaded
All dwellings	4 star (> 4.5 but <= 6 L/min)	4 star	4 star	4 star	-	not specified	not specified	-	-	-	-	-	-	-

	Alternative water source							
Dwelling no.	Alternative water supply systems	Size	Configuration	Landscape connection	Toilet connection (s)	Laundry connection	Pool top-up	Spa top-up
All dwellings	No alternative water supply	-	-	-	-	-	-	-

(ii) Energy	Show on DA plans	Show on CC/CDC plans & specs	Certifier check
(a) The applicant must comply with the commitments listed below in carrying out the development of a dwelling listed in a table below.			
(b) The applicant must install each hot water system specified for the dwelling in the table below, so that the dwelling's hot water is supplied by that system. If the table specifies a central hot water system for the dwelling, then the applicant must connect that central system to the dwelling, so that the dwelling's hot water is supplied by that central system.	✓	✓	✓
(c) The applicant must install, in each bathroom, kitchen and laundry of the dwelling, the ventilation system specified for that room in the table below. Each such ventilation system must have the operation control specified for it in the table.		✓	✓
(d) The applicant must install the cooling and heating system/s specified for the dwelling under the "Living areas" and "Bedroom areas" headings of the "Cooling" and "Heating" columns in the table below, in/for at least 1 living/bedroom area of the dwelling. If no cooling or heating system is specified in the table for "Living areas" or "Bedroom areas", then no systems may be installed in any such areas. If the term "zoned" is specified beside an air conditioning system, then the system must provide for day/night zoning between living areas and bedrooms.		✓	✓
(e) This commitment applies to each room or area of the dwelling which is referred to in a heading to the "Artificial lighting" column of the table below (but only to the extent specified for that room or area). The applicant must ensure that the "primary type of artificial lighting" for each such room in the dwelling is fluorescent lighting or light emitting diode (LED) lighting. If the term "dedicated" is specified for a particular room or area, then the light fittings in that room or area must only be capable of being used for fluorescent lighting or light emitting diode (LED) lighting.		✓	✓
(f) This commitment applies to each room or area of the dwelling which is referred to in a heading to the "Natural lighting" column of the table below (but only to the extent specified for that room or area). The applicant must ensure that each such room or area is fitted with a window and/or skylight.	✓	✓	✓
(g) This commitment applies if the applicant installs a water heating system for the dwelling's pool or spa. The applicant must: (aa) install the system specified for the pool in the "Individual Pool" column of the table below (or alternatively must not install any system for the pool). If specified, the applicant must install a timer, to control the pool's pump; and (bb) install the system specified for the spa in the "Individual Spa" column of the table below (or alternatively must not install any system for the spa). If specified, the applicant must install a timer to control the spa's pump.		✓ ✓	
(h) The applicant must install in the dwelling: (aa) the kitchen cook-top and oven specified for that dwelling in the "Appliances & other efficiency measures" column of the table below;		✓	

(ii) Energy	Show on DA plans	Show on CC/CDC plans & specs	Certifier check
(bb) each appliance for which a rating is specified for that dwelling in the "Appliances & other efficiency measures" column of the table, and ensure that the appliance has that minimum rating; and		✓	✓
(cc) any clothes drying line specified for the dwelling in the "Appliances & other efficiency measures" column of the table.		✓	
(i) If specified in the table, the applicant must carry out the development so that each refrigerator space in the dwelling is "well ventilated".		✓	

	Hot water	Bathroom ventilation system		Kitchen ventilation system		Laundry ventilation system	
Dwelling no.	Hot water system	Each bathroom	Operation control	Each kitchen	Operation control	Each laundry	Operation control
All dwellings	electric instantaneous	individual fan, ducted to façade or roof	interlocked to light with timer off	individual fan, ducted to façade or roof	manual switch on/off	individual fan, ducted to façade or roof	interlocked to light

	Cooling		Heating		Natural lighting	
Dwelling no.	living areas	bedroom areas	living areas	bedroom areas	No. of bathrooms or toilets	Main kitchen
U01, U09, U10, U13, U20, U29	1-phase airconditioning - non ducted / EER 3.0 - 3.5	1-phase airconditioning - non ducted / EER 3.0 - 3.5	1-phase airconditioning - non ducted / EER 3.0 - 3.5	1-phase airconditioning - non ducted / EER 3.0 - 3.5	1	yes
All other dwellings	1-phase airconditioning - non ducted / EER 3.0 - 3.5	1-phase airconditioning - non ducted / EER 3.0 - 3.5	1-phase airconditioning - non ducted / EER 3.0 - 3.5	1-phase airconditioning - non ducted / EER 3.0 - 3.5	0	yes

	Individual pool			Individual spa		Appliances other efficiency measures				
Dwelling no.	Pool heating system	Pool Pump	Timer	Spa heating system	Timer	Kitchen cooktop/oven	Dishwasher	Clothes dryer	Indoor or sheltered clothes drying line	Private outdoor or unsheltered clothes drying line
All dwellings	-	-	-	-	-	electric cooktop & electric oven	-	-	no	yes

(iii) Thermal Performance	Show on DA plans	Show on CC/CDC plans & specs	Certifier check
(a) The applicant must attach the certificate referred to under "Assessor details" on the front page of this BASIX certificate (the "Assessor Certificate") to the development application and construction certificate application for the proposed development (or, if the applicant is applying for a complying development certificate for the proposed development, to that application). The applicant must also attach the Assessor Certificate to the application for a final occupation certificate for the proposed development.			
(b) The Assessor Certificate must have been issued by an Accredited Assessor in accordance with the Thermal Comfort Protocol.			
(c) The details of the proposed development on the Assessor Certificate must be consistent with the details shown in this BASIX Certificate, including the details shown in the "Thermal Loads" table below.			
(d) The applicant must show on the plans accompanying the development application for the proposed development, all matters which the Thermal Comfort Protocol requires to be shown on those plans. Those plans must bear a stamp of endorsement from the Accredited Assessor, to certify that this is the case.	✓		
(e) The applicant must show on the plans accompanying the application for a construction certificate (or complying development certificate, if applicable), all thermal performance specifications set out in the Assessor Certificate, and all aspects of the proposed development which were used to calculate those specifications.		✓	
(f) The applicant must construct the development in accordance with all thermal performance specifications set out in the Assessor Certificate, and in accordance with those aspects of the development application or application for a complying development certificate which were used to calculate those specifications.		✓	✓
(g) Where there is an in-slab heating or cooling system, the applicant must:  (aa) Install insulation with an R-value of not less than 1.0 around the vertical edges of the perimeter of the slab; or (bb) On a suspended floor, install insulation with an R-value of not less than 1.0 underneath the slab and around the vertical edges of the perimeter of the slab.	✓	✓	✓
(h) The applicant must construct the floors and walls of the development in accordance with the specifications listed in the table below.	✓	✓	✓
(i) The applicant must show on The plans accompanying The development application for The proposed development, The locations of ceiling fans set out in The Assessor Certificate.	✓		
(j) The applicant must show on the plans accompanying the application for a construction certificate (or complying development certificate, if applicable), the locations of ceiling fans set out in the Assessor Certificate.		✓	

	Thermal loads		
Dwelling no.	Area adjusted heating load (in MJ/m <sup>2</sup> /yr)	Area adjusted cooling load (in MJ/m <sup>2</sup> /yr)	Area adjusted total load (in MJ/m <sup>2</sup> /yr)
U01	15.9	4.8	20.700
U02	15.8	3.1	18.900
U03	14.4	2.7	17.100
U04	16.5	2.5	19.000

	Thermal loads		
Dwelling no.	Area adjusted heating load (in MJ/m <sup>2</sup> /yr)	Area adjusted cooling load (in MJ/m <sup>2</sup> /yr)	Area adjusted total load (in MJ/m <sup>2</sup> /yr)
U05	20.4	3.8	24.200
U06	15.4	3.4	18.800
U07	10.4	5.4	15.800
U08	11.2	5.7	16.900
U09	18.2	5	23.200
U10	18	12.2	30.200
U11	6.1	13	19.100
U12	22.7	7.7	30.400
U13	8.5	11.5	20.000
U14	13.5	9.7	23.200
U15	23.50	10.9	34.400
U16	9.20	9.2	18.400
U17	26.5	6.5	33.000
U18	10.3	14	24.300
U19	8.1	16.5	24.600
U20	17.1	11.9	29.000
U21	11.8	14.1	25.900
U22	13	15	28.000
U23	13.5	15.4	28.900
U24	20.4	15.2	35.600
U25	25.9	11.7	37.600
U26	14.3	13.6	27.900
U27	19.4	11	30.400
U28	17.8	16.7	34.500
All other dwellings	22.9	14.2	37.100

**(c) Common areas and central systems/facilities**

<b>(i) Water</b>	<b>Show on DA plans</b>	<b>Show on CC/CDC plans &amp; specs</b>	<b>Certifier check</b>
(a) If, in carrying out the development, the applicant installs a showerhead, toilet, tap or clothes washer into a common area, then that item must meet the specifications listed for it in the table.		✓	✓
(b) The applicant must install (or ensure that the development is serviced by) the alternative water supply system(s) specified in the "Central systems" column of the table below. In each case, the system must be sized, be configured, and be connected, as specified in the table.	✓	✓	✓
(c) A swimming pool or spa listed in the table must not have a volume (in kLs) greater than that specified for the pool or spa in the table.	✓	✓	
(d) A pool or spa listed in the table must have a cover or shading if specified for the pool or spa in the table.		✓	
(e) The applicant must install each fire sprinkler system listed in the table so that the system is configured as specified in the table.		✓	✓
(f) The applicant must ensure that the central cooling system for a cooling tower is configured as specified in the table.		✓	✓

<b>Common area</b>	<b>Showerheads rating</b>	<b>Toilets rating</b>	<b>Taps rating</b>	<b>Clothes washers rating</b>
All common areas	no common facility	no common facility	no common facility	no common laundry facility

<b>Central systems</b>	<b>Size</b>	<b>Configuration</b>	<b>Connection (to allow for...)</b>
Central water tank - rainwater or stormwater (No. 1)	5000	To collect run-off from at least: - 1000 square metres of roof area of buildings in the development	- irrigation of 1100 square metres of common landscaped area on the site - car washing in 0 car washing bays on the site

<b>(ii) Energy</b>	<b>Show on DA plans</b>	<b>Show on CC/CDC plans &amp; specs</b>	<b>Certifier check</b>
(a) If, in carrying out the development, the applicant installs a ventilation system to service a common area specified in the table below, then that ventilation system must be of the type specified for that common area, and must meet the efficiency measure specified.		✓	✓
(b) In carrying out the development, the applicant must install, as the "primary type of artificial lighting" for each common area specified in the table below, the lighting specified for that common area. This lighting must meet the efficiency measure specified. The applicant must also install a centralised lighting control system or Building Management System (BMS) for the common area, where specified.		✓	✓

(ii) Energy	Show on DA plans	Show on CC/CDC plans & specs	Certifier check
(c) The applicant must install the systems and fixtures specified in the "Central energy systems" column of the table below. In each case, the system or fixture must be of the type, and meet the specifications, listed for it in the table.	✓	✓	✓

	Common area ventilation system		Common area lighting		
Common area	Ventilation system type	Ventilation efficiency measure	Primary type of artificial lighting	Lighting efficiency measure	Lighting control system/ BMS
Garbage room	no mechanical ventilation	-	light-emitting diode	motion sensors	no
Plant or service room	no mechanical ventilation	-	light-emitting diode	motion sensors	no
Hallway/lobby type	no mechanical ventilation	-	light-emitting diode	zoned switching with motion sensor	no
Lift bank (No. 1)	-	-	light-emitting diode	connected to lift call button	no
Lift bank (No. 2)	-	-	light-emitting diode	connected to lift call button	no

Central energy systems	Type	Specification
Lift bank (No. 1)	gearless traction with V V V F motor	Number of levels (including basement): 3 number of levels from the bottom of the lift shaft to the top of the lift shaft: 3 number of lifts: 1 lift load capacity: $\geq 1001$ kg but $\leq 1500$ kg
Lift bank (No. 2)	gearless traction with V V V F motor	Number of levels (including basement): 3 number of levels from the bottom of the lift shaft to the top of the lift shaft: 3 number of lifts: 1 lift load capacity: $\geq 1001$ kg but $\leq 1500$ kg

## 2. Commitments for multi-dwelling housing

### (a) Dwellings

(i) Water	Show on DA plans	Show on CC/CDC plans & specs	Certifier check
(a) The applicant must comply with the commitments listed below in carrying out the development of a dwelling listed in a table below.			
(b) The applicant must plant indigenous or low water use species of vegetation throughout the area of land specified for the dwelling in the "Indigenous species" column of the table below, as private landscaping for that dwelling. (This area of indigenous vegetation is to be contained within the "Area of garden and lawn" for the dwelling specified in the "Description of Project" table).	✓	✓	
(c) If a rating is specified in the table below for a fixture or appliance to be installed in the dwelling, the applicant must ensure that each such fixture and appliance meets the rating specified for it.		✓	✓
(d) The applicant must install an on demand hot water recirculation system which regulates all hot water use throughout the dwelling, where indicated for a dwelling in the "HW recirculation or diversion" column of the table below.		✓	✓
(e) The applicant must install: (aa) a hot water diversion system to all showers, kitchen sinks and all basins in the dwelling, where indicated for a dwelling in the "HW recirculation or diversion" column of the table below; and (bb) a separate diversion tank (or tanks) connected to the hot water diversion systems of at least 100 litres. The applicant must connect the hot water diversion tank to all toilets in the dwelling.		✓ ✓	✓ ✓
(e) The applicant must not install a private swimming pool or spa for the dwelling, with a volume exceeding that specified for it in the table below.	✓	✓	
(f) If specified in the table, that pool or spa (or both) must have a pool cover or shading (or both).		✓	
(g) The pool or spa must be located as specified in the table.	✓	✓	
(h) The applicant must install, for the dwelling, each alternative water supply system, with the specified size, listed for that dwelling in the table below. Each system must be configured to collect run-off from the areas specified (excluding any area which supplies any other alternative water supply system), and to divert overflow as specified. Each system must be connected as specified.	✓	✓	✓
(ii) Energy	Show on DA plans	Show on CC/CDC plans & specs	Certifier check
(a) The applicant must comply with the commitments listed below in carrying out the development of a dwelling listed in a table below.			
(b) The applicant must install each hot water system specified for the dwelling in the table below, so that the dwelling's hot water is supplied by that system. If the table specifies a central hot water system for the dwelling, then the applicant must connect that central system to the dwelling, so that the dwelling's hot water is supplied by that central system.	✓	✓	✓
(c) The applicant must install, in each bathroom, kitchen and laundry of the dwelling, the ventilation system specified for that room in the table below. Each such ventilation system must have the operation control specified for it in the table.		✓	✓

(ii) Energy	Show on DA plans	Show on CC/CDC plans & specs	Certifier check
(d) The applicant must install the cooling and heating system/s specified for the dwelling under the "Living areas" and "Bedroom areas" headings of the "Cooling" and "Heating" columns in the table below, in/for at least 1 living/bedroom area of the dwelling. If no cooling or heating system is specified in the table for "Living areas" or "Bedroom areas", then no systems may be installed in any such areas. If the term "zoned" is specified beside an air conditioning system, then the system must provide for day/night zoning between living areas and bedrooms.		✓	✓
(e) This commitment applies to each room or area of the dwelling which is referred to in a heading to the "Artificial lighting" column of the table below (but only to the extent specified for that room or area). The applicant must ensure that the "primary type of artificial lighting" for each such room in the dwelling is fluorescent lighting or light emitting diode (LED) lighting. If the term "dedicated" is specified for a particular room or area, then the light fittings in that room or area must only be capable of being used for fluorescent lighting or light emitting diode (LED) lighting.		✓	✓
(f) This commitment applies to each room or area of the dwelling which is referred to in a heading to the "Natural lighting" column of the table below (but only to the extent specified for that room or area). The applicant must ensure that each such room or area is fitted with a window and/or skylight.	✓	✓	✓
(g) This commitment applies if the applicant installs a water heating system for the dwelling's pool or spa. The applicant must: (aa) install the system specified for the pool in the "Individual Pool" column of the table below (or alternatively must not install any system for the pool). If specified, the applicant must install a timer, to control the pool's pump; and (bb) install the system specified for the spa in the "Individual Spa" column of the table below (or alternatively must not install any system for the spa). If specified, the applicant must install a timer to control the spa's pump.		✓ ✓	
(h) The applicant must install in the dwelling: (aa) the kitchen cook-top and oven specified for that dwelling in the "Appliances & other efficiency measures" column of the table below; (bb) each appliance for which a rating is specified for that dwelling in the "Appliances & other efficiency measures" column of the table, and ensure that the appliance has that minimum rating; and (cc) any clothes drying line specified for the dwelling in the "Appliances & other efficiency measures" column of the table.		✓ ✓ ✓	✓
(i) If specified in the table, the applicant must carry out the development so that each refrigerator space in the dwelling is "well ventilated".		✓	
(iii) Thermal Performance and Materials	Show on DA plans	Show on CC/CDC plans & specs	Certifier check
(a) The applicant must attach the certificate referred to under "Assessor details" on the front page of this BASIX certificate (the "Assessor Certificate") to the development application and construction certificate application for the proposed development (or, if the applicant is applying for a complying development certificate for the proposed development, to that application). The applicant must also attach the Assessor Certificate to the application for a final occupation certificate for the proposed development.			
(b) The Assessor Certificate must have been issued by an Accredited Assessor in accordance with the Thermal Comfort Protocol.			

(iii) Thermal Performance and Materials	Show on DA plans	Show on CC/CDC plans & specs	Certifier check
(c) The details of the proposed development on the Assessor Certificate must be consistent with the details shown in this BASIX Certificate, including the details shown in the "Thermal Loads" table below.			
(d) The applicant must show on the plans accompanying the development application for the proposed development, all matters which the Thermal Comfort Protocol requires to be shown on those plans. Those plans must bear a stamp of endorsement from the Accredited Assessor, to certify that this is the case.	✓		
(e) The applicant must show on the plans accompanying the application for a construction certificate (or complying development certificate, if applicable), all thermal performance specifications set out in the Assessor Certificate, and all aspects of the proposed development which were used to calculate those specifications.		✓	
(f) The applicant must construct the development in accordance with all thermal performance specifications set out in the Assessor Certificate, and in accordance with those aspects of the development application or application for a complying development certificate which were used to calculate those specifications.		✓	✓
(g) Where there is an in-slab heating or cooling system, the applicant must:  (aa) Install insulation with an R-value of not less than 1.0 around the vertical edges of the perimeter of the slab; or (bb) On a suspended floor, install insulation with an R-value of not less than 1.0 underneath the slab and around the vertical edges of the perimeter of the slab.	✓	✓	✓
(h) The applicant must construct the floors and walls of the development in accordance with the specifications listed in the table below.	✓	✓	✓
(i) The applicant must show on The plans accompanying The development application for The proposed development, The locations of ceiling fans set out in The Assessor Certificate.	✓		
(j) The applicant must show on the plans accompanying the application for a construction certificate (or complying development certificate, if applicable), the locations of ceiling fans set out in the Assessor Certificate.		✓	

### 3. Commitments for common areas and central systems/facilities for the development (non-building specific)

#### (b) Common areas and central systems/facilities

(i) Water	Show on DA plans	Show on CC/CDC plans & specs	Certifier check
(a) If, in carrying out the development, the applicant installs a showerhead, toilet, tap or clothes washer into a common area, then that item must meet the specifications listed for it in the table.		✓	✓
(b) The applicant must install (or ensure that the development is serviced by) the alternative water supply system(s) specified in the "Central systems" column of the table below. In each case, the system must be sized, be configured, and be connected, as specified in the table.	✓	✓	✓
(c) A swimming pool or spa listed in the table must not have a volume (in kLs) greater than that specified for the pool or spa in the table.	✓	✓	
(d) A pool or spa listed in the table must have a cover or shading if specified for the pool or spa in the table.		✓	
(e) The applicant must install each fire sprinkler system listed in the table so that the system is configured as specified in the table.		✓	✓
(f) The applicant must ensure that the central cooling system for a cooling tower is configured as specified in the table.		✓	✓

Common area	Showerheads rating	Toilets rating	Taps rating	Clothes washers rating
All common areas	no common facility	no common facility	no common facility	no common laundry facility

(ii) Energy	Show on DA plans	Show on CC/CDC plans & specs	Certifier check
(a) If, in carrying out the development, the applicant installs a ventilation system to service a common area specified in the table below, then that ventilation system must be of the type specified for that common area, and must meet the efficiency measure specified.		✓	✓
(b) In carrying out the development, the applicant must install, as the "primary type of artificial lighting" for each common area specified in the table below, the lighting specified for that common area. This lighting must meet the efficiency measure specified. The applicant must also install a centralised lighting control system or Building Management System (BMS) for the common area, where specified.		✓	✓
(c) The applicant must install the systems and fixtures specified in the "Central energy systems" column of the table below. In each case, the system or fixture must be of the type, and meet the specifications, listed for it in the table.	✓	✓	✓

Central energy systems	Type	Specification
Alternative energy supply	Photovoltaic system	Rated electrical output (min): 20 peak kW
Other	-	-

## Notes

1. In these commitments, "applicant" means the person carrying out the development.
2. The applicant must identify each dwelling, building and common area listed in this certificate, on the plans accompanying any development application, and on the plans and specifications accompanying the application for a construction certificate / complying development certificate, for the proposed development, using the same identifying letter or reference as is given to that dwelling, building or common area in this certificate.
3. This note applies if the proposed development involves the erection of a building for both residential and non-residential purposes (or the change of use of a building for both residential and non-residential purposes). Commitments in this certificate which are specified to apply to a "common area" of a building or the development, apply only to that part of the building or development to be used for residential purposes.
4. If this certificate lists a central system as a commitment for a dwelling or building, and that system will also service any other dwelling or building within the development, then that system need only be installed once (even if it is separately listed as a commitment for that other dwelling or building).
5. If a star or other rating is specified in a commitment, this is a minimum rating.
6. All alternative water systems to be installed under these commitments (if any), must be installed in accordance with the requirements of all applicable regulatory authorities. NOTE: NSW Health does not recommend that stormwater, recycled water or private dam water be used to irrigate edible plants which are consumed raw, or that rainwater be used for human consumption in areas with potable water supply.

## Legend

1. Commitments identified with a "✔" in the "Show on DA plans" column must be shown on the plans accompanying the development application for the proposed development (if a development application is to be lodged for the proposed development).
2. Commitments identified with a "✔" in the "Show on CC/CDC plans and specs" column must be shown in the plans and specifications accompanying the application for a construction certificate / complying development certificate for the proposed development.
3. Commitments identified with a "✔" in the "Certifier check" column must be certified by a certifying authority as having been fulfilled. (Note: a certifying authority must not issue an occupation certificate (either interim or final) for a building listed in this certificate, or for any part of such a building, unless it is satisfied that each of the commitments whose fulfilment it is required to monitor in relation to the building or part, has been fulfilled).