

GEOTECHNICAL INVESTIGATION

FOR

NSW LAND & HOUSING CORPORATION

96 – 98 Brenan Street, Smithfield, New South Wales

Report No: 20/0334

Project No: 30237/3396D-G

February 2020

Table of Contents

1. INTRODUCTION.....	2
2. NATURE OF THE INVESTIGATION	2
2.1. Fieldwork	2
2.2. Laboratory Testing.....	3
3. GEOLOGY AND SITE CONDITIONS.....	3
4. SUBSURFACE CONDITIONS	4
5. GEOTECHNICAL DISCUSSION	4
5.1. Site Classification to AS2870.....	4
5.2. Foundation Design.....	4
5.3. Soil Aggressiveness	5
6. FINAL COMMENTS	6

DRAWING NO. 20/0334 – BOREHOLE AND PENETROMETER LOCATIONS

NOTES RELATING TO GEOTECHNICAL REPORTS

APPENDIX A – BOREHOLE LOGS AND EXPLANATION SHEETS

APPENDIX B – LABORATORY TEST RESULTS

1. INTRODUCTION

This report presents the results of a Geotechnical Investigation carried out by STS Geotechnics Pty Limited (STS) for a proposed new residential development to be constructed at 96 – 98 Brenan Street, Smithfield. At the time of writing this report STS were not provided with architectural drawings for the project, however we understand the development will typically comprise the demolition of existing dwellings and construction of one to two level residential unit type buildings. The development will not include basement levels.

The purpose of the investigation was to:

- assess the subsurface conditions over the site,
- provide a Site Classification to AS2870,
- provide recommendations regarding the appropriate foundation system for the site including design parameters, and
- comment on soil aggressiveness to buried steel and concrete.

The investigation was undertaken at the request of Land and Housing Corporation NSW.

Our scope of work did not include a contamination assessment.

2. NATURE OF THE INVESTIGATION

2.1. Fieldwork

The fieldwork consisted of drilling four (4) boreholes numbered BH1 to BH4, at the locations shown on Drawing No. 20/0334. The boreholes were drilled using a utility mounted Christie drilling rig owned and operated by STS. Soils and weathered bedrock were drilled using rotary solid flight augers. Soil strengths were determined by undertaking Dynamic Cone Penetrometer (DCP) tests at each borehole location.

Drilling operations were undertaken by one of STS's technical officers who also logged the subsurface conditions encountered.

The subsurface conditions observed are recorded on the borehole logs given in Appendix A. An explanation of the terms used on the logs is also given in Appendix A. Notes relating to geotechnical reports are also attached.

2.2. Laboratory Testing

In order to assist with determining the site classification, shrink swell index tests were carried out on representative samples retrieved from the site. The detailed test reports are attached and are summarised in Table 2.1 below:

Table 2.1 – Shrink Swell Summary Table

Location	Depth (m)	Material Description	Shrink/Swell Index (% per ΔpF)
BH1	0.8 – 1.0	Orange brown with grey silty clay	0.9
BH4	0.7 – 0.9	Orange brown with brown silty clay	3.1

In order to assess the soils for their aggressiveness, selected representative soil samples were tested to determine the following:

- pH,
- Sulphate content (SO_4),
- Chloride content (CL), and
- Electrical Conductivity (EC)

Detailed test reports are given in Appendix B.

3. GEOLOGY AND SITE CONDITIONS

The Sydney geological series sheet at a scale of 1:100,000 indicates that the site is underlain by Triassic Age Bringelly Shale of the Wianamatta Group. Rocks within this formation comprise shale, claystone and laminite.

The site is roughly trapezoidal in shape with a combined area of approximately 1,385m². At the time of the fieldwork, the site was occupied by a series of single level fibro clad residential dwellings with strip concrete driveways. Site vegetation comprised grass, trees and shrubs.

The ground surface falls approximately 0.5 metre to the north.

To the south and east of the site are Brenan Street and Stimson Street respectively and to the remaining sides are single and double storey residential dwellings.

4. SUBSURFACE CONDITIONS

When assessing the subsurface conditions across a site from a limited number of boreholes, there is the possibility that variations may occur between test locations. The data derived from the site investigation programme are extrapolated across the site to form a geological model and an engineering opinion is rendered about overall subsurface conditions and their likely behaviour regarding the proposed development. The actual condition at the site may differ from those inferred, since no subsurface exploration programme, no matter how comprehensive, can reveal all subsurface details and anomalies.

The subsurface conditions generally consist of topsoil and fill overlying natural silty clays and weathered shale. Some organics and minor topsoil and fill were encountered at the ground surface to approximate depths of 0.1 – 0.4 metres. Natural silty clays of firm to stiff becoming very stiff consistency were encountered below the surface materials to approximate depths of 1.9 – 2.2 m in BH3 and BH4 and to the termination depth of 3.0 m in BH1 and BH2. Weathered shale bedrock underlies the site and was encountered to the depth of drilling, 3.0 metres in BH3 and auger refusal depth of 2.5 m in BH4.

Groundwater was not observed during drilling of the boreholes.

5. GEOTECHNICAL DISCUSSION

5.1. Site Classification to AS2870

The classification has been prepared in accordance with the guidelines set out in the “Residential Slabs and Footings” Code, AS2870 – 2011.

Because there are buildings and trees present, abnormal moisture conditions (AMC) prevail at the site (Refer to Section 1.3.3 of AS2870).

Because of the AMC, the site is classified *a problem site (P)*. However, provided the recommendations given below are adopted and the footings bear in the underlying natural soils, the site may be reclassified *Highly Reactive (H1)*.

5.2. Foundation Design

Footings that bear in the firm to stiff natural clayey soils below any topsoil, fill or soft clayey soils may be proportioned using an allowable bearing pressure of 100 kPa. This value may be increased to 300 kPa when founding in the very stiff natural materials. The minimum depth of founding must comply with the requirements of AS2870-2011. In order to overcome the presence of trees, the foundations should be designed in accordance with the procedures given in Appendices H and CH of AS2870-2011. Tree information is attached.

Should a higher bearing pressure be required then piles can be used. Piles founded in very stiff clays may be proportioned using an allowable bearing pressure of 450 kPa, provided the depth to diameter ratio of the pile exceeds a value of 4. An allowable adhesion of 20 kPa may be adopted for the portion of the shaft within the natural soils.

Piles founded in weathered shale may be proportioned using an allowable bearing pressure of 700 kPa. An allowable adhesion of 70 kPa may be adopted for the portion of the shaft within the weathered shale. When piles are founded in shale the adhesion within the overlying soils must be ignored.

In order to ensure the bearing values given can be achieved, care should be taken to ensure that the base of excavations are free of all loose material prior to concreting. It is recommended that all footing excavations be protected with a layer of blinding concrete as soon as possible, preferably immediately after excavating, cleaning, inspection and approval. The possible presence of groundwater needs to be considered when drilling piers and pouring concrete.

5.3. Soil Aggressiveness

The aggressiveness or erosion potential of an environment in building materials, particularly concrete and steel is dependent on the levels of soil pH and the types of salts present, generally sulphates and chlorides. In order to determine the degree of aggressiveness, the test values obtained are compared to Tables 6.4.2 (C) and 6.5.2 (C) in AS2159 – 2009 Piling – Design and Installation and Tables 5.1 and 5.2 of AS2870-2011. In regards to the electrical conductivity, the laboratory test results have been multiplied by the appropriate factor to convert the results to EC_e . The test results are summarised in Table 5.1 below.

Table 5.1 – Soil Aggressiveness Summary Table

Sample No.	Location	Depth (m)	pH	Sulfate (mg/kg)	Chloride (mg/kg)	Electrical Conductivity (dS/m)	
						$EC_{1:5}$	EC_e
S1	BH1	0.3	5.5	20	<10	0.030	0.2
S2	BH3	0.3	5.5	20	60	0.053	0.4

The report results range between:

- pH - 5.5
- soluble SO_4 - 20 mg/kg (ppm)
- soluble Cl - <10 to 60 mg/kg (ppm)
- EC_e - 0.2 to 0.4 dS/m

The soils on the site consist of low permeability silty clays. Therefore, the soil conditions B are considered appropriate.

A review of the durability aspects indicates that:

- pH : minimum value of 5.5
- SO₄ : maximum value of 20 mg/kg (ppm) < 5000 ppm
- Cl : maximum value of 60 mg/kg (ppm) < 5000 ppm
- EC_e : maximum value of 0.4 dS/m

The exposure classification for the onsite soils is non-aggressive for steel and mildly aggressive to concrete in accordance with AS2159-2009. The soils are classified as A2 in accordance with AS2870-2011.

Reference to DLWC (2002) "Site Investigations for Urban Salinity" indicates that EC_e values of 0.2 dS/m to 0.4 dS/m are consistent with the presence of non-saline soils.

6. FINAL COMMENTS

During construction, should the subsurface conditions vary from those inferred above, we would be contacted to determine if any changes should be made to our recommendations.

The exposed bearing surfaces for footings should be inspected by a geotechnical engineer to ensure the allowable pressure given has been achieved.



Rasoul Machiani
Senior Geotechnical Engineer
STS Geotechnics Pty Limited



Matthew Green
Principal Engineering Geologist
STS Geotechnics Pty Limited



STS Geotechnics Pty. Ltd.

Scale: Unknown

Date: February 2020

Client: NSW LAND & HOUSING CORPORATION

GEOTECHNICAL INVESTIGATION
96-98 BRENAN STREET, SMITHFIELD
BOREHOLE AND PENETROMETER LOCATIONS

Project No.
30237/3396D-G

Drawing No: 20/0334

NOTES RELATING TO GEOTECHNICAL REPORTS

Introduction

These notes have been provided to outline the methodology and limitations inherent in geotechnical reporting. The issues discussed are not relevant to all reports and further advice should be sought if there are any queries regarding any advice or report.

When copies of reports are made, they should be reproduced in full.

Geotechnical Reports

Geotechnical reports are prepared by qualified personnel on the information supplied or obtained and are based on current engineering standards of interpretation and analysis.

Information may be gained from limited subsurface testing, surface observations, previous work and is supplemented by knowledge of the local geology and experience of the range of properties that may be exhibited by the materials present. For this reason, geotechnical reports should be regarded as interpretative rather than factual documents, limited to some extent by the scope of information on which they rely.

Where the report has been prepared for a specific purpose (eg. design of a three-storey building), the information and interpretation may not be appropriate if the design is changed (eg. a twenty storey building). In such cases, the report and the sufficiency of the existing work should be reviewed by STS Geotechnics Pty Limited in the light of the new proposal.

Every care is taken with the report content, however, it is not always possible to anticipate or assume responsibility for the following conditions:

- Unexpected variations in ground conditions. The potential for this depends on the amount of investigative work undertaken.
- Changes in policy or interpretation by statutory authorities.
- The actions of contractors responding to commercial pressures.

If these occur, STS Geotechnics Pty Limited would be pleased to resolve the matter through further investigation, analysis or advice.

Unforeseen Conditions

Should conditions encountered on site differ markedly from those anticipated from the information contained in the report, STS

Geotechnics Pty Limited should be notified immediately. Early identification of site anomalies generally results in any problems being more readily resolved and allows re-interpretation and assessment of the implications for future work.

Subsurface Information

Logs of a borehole, recovered core, test pit, excavated face or cone penetration test are an engineering and/or geological interpretation of the subsurface conditions. The reliability of the logged information depends on the drilling/testing method, sampling and/or observation spacings and the ground conditions. It is not always possible or economic to obtain continuous high quality data. It should also be recognised that the volume or material observed or tested is only a fraction of the total subsurface profile.

Interpretation of subsurface information and application to design and construction must take into consideration the spacing of the test locations, the frequency of observations and testing, and the possibility that geological boundaries may vary between observation points.

Groundwater observations and measurements outside of specially designed and constructed piezometers should be treated with care for the following reasons:

- In low permeability soils groundwater may not seep into an excavation or bore in the short time it is left open.
- A localised perched water table may not represent the true water table.
- Groundwater levels vary according to rainfall events or season.
- Some drilling and testing procedures mask or prevent groundwater inflow.

The installation of piezometers and long term monitoring of groundwater levels may be required to adequately identify groundwater conditions.

Supply of Geotechnical Information or Tendering Purposes

It is recommended tenderers are provided with as much geological and geotechnical information that is available and that where there are uncertainties regarding the ground conditions, prospective tenders should be provided with comments discussing the range of likely conditions in addition to the investigation data.

APPENDIX A – BOREHOLE LOGS AND EXPLANATION SHEETS

Client: NSW Land & Housing Corporation		Project / STS No. 30237/3396D-G		BOREHOLE NO.: BH 1		
Project: 96-98 Brenan Street, Smithfield		Date: January 28. 2020		Sheet 1 of 1		
Location: Refer to Drawing No. 20/0334		Logged: MB Checked By: MG				
W A T T A E B R L E	S A M P L E S	DEPTH (m)	DESCRIPTION OF DRILLED PRODUCT (Soil type, colour, grain size, plasticity, minor components, observations)	S Y M B O L	CONSISTENCY (cohesive soils) or RELATIVE DENSITY (sands and gravels)	M O I S T U R E
	S1 @ 0.3 m	0.0	SILTY CLAY: brown, medium plasticity, trace of gravel	CL	FIRM	D
		0.5	SILTY CLAY: orange brown with grey, medium plasticity	CL	STIFF	D
		1.0			VERY STIFF	
	U50	1.5	SILTY CLAY: grey, medium plasticity	CL	VERY STIFF	D
		2.0				
		2.5				
		3.0	BOREHOLE DISCONTINUED AT 3.0 M			
D - disturbed sample U - undisturbed tube sample B - bulk sample WT - level of water table or free water N - Standard Penetration Test (SPT) S - jar sample				Contractor: STS Equipment: Christie Hole Diameter (mm): 100		
NOTES: See explanation sheets for meaning of all descriptive terms and symbols				Angle from Vertical (°): 0 Drill Bit: Spiral		

Client: NSW Land & Housing Corporation		Project / STS No. 30237/3396D-G		BOREHOLE NO.: BH 2		
Project: 96-98 Brenan Street, Smithfield		Date: January 28. 2020				
Location: Refer to Drawing No. 20/0334		Logged: MB Checked By: MG		Sheet 1 of 1		
W A T E R L E V E L	S A M P L E S	DEPTH (m)	DESCRIPTION OF DRILLED PRODUCT (Soil type, colour, grain size, plasticity, minor components, observations)	S Y M B O L	CONSISTENCY (cohesive soils) or RELATIVE DENSITY (sands and gravels)	M O I S T U R E
			SILTY SANDY CLAY: brown, low to medium plasticity	CL	STIFF	D
		0.5	SILTY CLAY: orange brown with grey, medium plasticity	CL	VERY STIFF	D
		1.0				
		1.5	SILTY CLAY: grey with orange brown, medium plasticity	CL	VERY STIFF	
		2.0				
		2.5				
			BOREHOLE DISCONTINUED AT 3.0 M			
D - disturbed sample U - undisturbed tube sample B - bulk sample WT - level of water table or free water N - Standard Penetration Test (SPT) S - jar sample				Contractor: STS Equipment: Christie Hole Diameter (mm): 100		
NOTES: See explanation sheets for meaning of all descriptive terms and symbols				Angle from Vertical (°): 0 Drill Bit: Spiral		

Client: NSW Land & Housing Corporation		Project / STS No. 30237/3396D-G		BOREHOLE NO.: BH 3		
Project: 96-98 Brenan Street, Smithfield		Date: January 28. 2020		Sheet 1 of 1		
Location: Refer to Drawing No. 20/0334		Logged: MB Checked By: MG				
W A T E R L E	S A M P L E S	DEPTH (m)	DESCRIPTION OF DRILLED PRODUCT (Soil type, colour, grain size, plasticity, minor components, observations)	S Y M B O L	CONSISTENCY (cohesive soils) or RELATIVE DENSITY (sands and gravels)	M O I S T U R E
	S2 @ 0.3 m		SILTY CLAY: brown, medium plasticity, trace of gravel	CL	SOFT	M
	U50	0.5	SILTY CLAY: orange brown with grey, medium plasticity	CL	FIRM	D-M
		1.0				
		1.5	SILTY CLAY: grey, medium plasticity	CL	VERY STIFF	D
		2.0				
		2.5	WEATHERED ROCK: brown		EXTREMELY LOW STRENGTH	D
BOREHOLE DISCONTINUED AT 3.0 M ON WEATHERED ROCK						
D - disturbed sample U - undisturbed tube sample B - bulk sample				Contractor: STS		
WT - level of water table or free water N - Standard Penetration Test (SPT)				Equipment: Christie		
S - jar sample				Hole Diameter (mm): 100		
NOTES: See explanation sheets for meaning of all descriptive terms and symbols				Angle from Vertical (°): 0		
				Drill Bit: Spiral		

[illegible]

Dynamic Cone Penetrometer Test Report

Project: 96-98 BRENAN STREET, SMITHFIELD

Project No.: 30237/3396D-G

Client: NSW LAND & HOUSING CORPORATION

Report No.: 20/0334

Address: Level 2, 31-39 Macquarie Street, Parramatta

Report Date: 3/02/2020

Test Method: AS 1289.6.3.2



Accredited for compliance with ISO/IEC

17025 - Testing

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards
NATA Accreditation Number 2750

Page: 1 of 1

Site No.	P1	P2	P3	P4		
Location	Refer to Drawing No. 20/0334	Refer to Drawing No. 20/0334	Refer to Drawing No. 20/0334	Refer to Drawing No. 20/0334		
Date Tested	28/1/2020	28/1/2020	28/1/2020	28/1/2020		
Starting Level	Surface Level	Surface Level	Surface Level	Surface Level		
Depth (m)	Penetration Resistance (blows / 150mm)					
0.00 - 0.15	3	4	1	2		
0.15 - 0.30	4	8	2	2		
0.30 - 0.45	6	8	3	4		
0.45 - 0.60	6	10	3	4		
0.60 - 0.75	8	10	6	6		
0.75 - 0.90	10	16	5	8		
0.90 - 1.05	10	16	4	7		
1.05 - 1.20	14	16	5	9		
1.20 - 1.35	16	18	5	9		
1.35 - 1.50	23+	18	6	10		
1.50 - 1.65	Refusal	23+	10	11		
1.65 - 1.80		Refusal	12	16		
1.80 - 1.95			18	23+		
1.95 - 2.10			23+	Refusal		
2.10 - 2.25			Refusal			
2.25 - 2.40						
2.40 - 2.55						
2.55 - 2.70						
2.70 - 2.85						
2.85 - 3.00						
3.00 - 3.15						
3.15 - 3.30						
3.30 - 3.45						
3.45 - 3.60						
3.60 - 3.75						

Remarks: * Pre drilled prior to testing



Approved Signatory.....

Technician: MB

Orlando Mendoza - Laboratory Manager

E1. CLASSIFICATION OF SOILS

E1.1 Soil Classification and the Unified System

An assessment of the site conditions usually includes an appraisal of the data available by combining values of engineering properties obtained by the site investigation with descriptions, from visual observation of the materials present on site.

The system used by STS Geotechnics Pty Ltd (STS) in the identification of soil is the Unified Soil Classification system (USC) which was developed by the US Army Corps of Engineers during World War II and has since gained international acceptance and has been adopted in its metricated form by the Standards Association of Australia.

The Australian Site Investigation Code (AS1726-1981, Appendix D) recommends that the description of a soil includes the USC group symbols which are an integral component of the system.

The soil description should contain the following information in order:

Soil composition

- SOIL NAME and USC classification symbol (IN BLOCK LETTERS)
- plasticity or particle characteristics
- colour
- secondary and minor constituents (name estimated proportion, plasticity or particle characteristics, colour)

Soil condition

- moisture condition
- consistency or density index

Soil structure

- structure (zoning, defects, cementing)

Soil origin

interpretation based on observation eg FILL, TOPSOIL, RESIDUAL, ALLUVIUM.

E1.2 Soil Composition

- (a) Soil Name and Classification Symbol

The USC system is summarised in Figure E1.2.1. The primary division separates soil types on the basis of particle size into:

- Coarse grained soils - more than 50% of the material less than 60 mm is larger than 0.06 mm (60 µm).
- Fine grained soils - more than 50% of the material less than 60 mm is smaller than 0.06 mm (60 µm).

Initial classification is by particle size as shown in Table E1.2.1. Further classification of fine grained soils is based on plasticity.

TABLE E1.2.1 - CLASSIFICATION BY PARTICLE SIZE

NAME	SUB-DIVISION	SIZE
Clay (1)		< 2 µm
Silt (2)		2 µm to 60 µm
Sand	Fine Medium Coarse	60 µm to 200 µm 200 µm to 600 µm 600 µm to 2 mm
Gravel (3)	Fine Medium Coarse	2 mm to 6 mm 6 mm to 20 mm 20 mm to 60 mm
Cobbles (3)		60 mm to 200 mm
Boulders (3)		> 200 mm

Where a soil contains an appropriate amount of secondary material, the name includes each of the secondary components (greater than 12%) in increasing order of significance, eg sandy silty clay.

Minor components of a soil are included in the description by means of the terms "some" and "trace" as defined in Table E1.2.2.

TABLE E1.2.2 - MINOR SOIL COMPONENTS

TERM	DESCRIPTION	APPROXIMATE PROPORTION (%)
Trace	presence just detectable, little or no influence on soil properties	0-5
Some	presence easily detectable, little influence on soil properties	5-12

The USC group symbols should be included with each soil description as shown in Table E1.2.3

TABLE E1.2.3 - SOIL GROUP SYMBOLS

SOIL TYPE	PREFIX
Gravel	G
Sand	S
Silt	M
Clay	C
Organic	O
Peat	Pt

The group symbols are combined with qualifiers which indicate grading, plasticity or secondary components as shown on Table E1.2.4

TABLE E1.2.4 - SOIL GROUP QUALIFIERS

SUBGROUP	SUFFIX
Well graded	W
Poorly Graded	P
Silty	M
Clayey	C
Liquid Limit <50% - low to medium plasticity	L
Liquid Limit >50% - medium to high plasticity	H

(b) Grading

“Well graded”	Good representation of all particle sizes from the largest to the smallest.
“Poorly graded”	One or more intermediate sizes poorly represented
“Gap graded”	One or more intermediate sizes absent
“Uniformly graded”	Essentially single size material.

(c) Particle shape and texture

The shape and surface texture of the coarse grained particles should be described.

Angularity may be expressed as “rounded”, “sub-rounded”, “sub-angular” or “angular”.

Particle **form** can be “equidimensional”, “flat” or “elongate”.

Surface texture can be “glassy”, “smooth”, “rough”, “pitted” or “striated”.

(d) Colour

The colour of the soil should be described in the moist condition using simple terms such as:

Black	White	Grey	Red
Brown	Orange	Yellow	Green
Blue			

These may be modified as necessary by “light” or “dark”. Borderline colours may be described as a combination of two colours, eg red-brown.

For soils that contain more than one colour terms such as:

- Speckled Very small (<10 mm dia) patches
- Mottled Irregular
- Blotched Large irregular (>75 mm dia)
- Streaked Randomly oriented streaks

(e) Minor Components

Secondary and minor components should be individually described in a similar manner to the dominant component.

E1.3 Soil Condition

(a) Moisture

Soil moisture condition is described as “dry”, “moist” or “wet”.

The moisture categories are defined as:

Dry (D) - Little or no moisture evident. Soils are running. Moist (M) - Darkened in colour with cool feel. Granular soil particles tend to adhere. No free water evident upon remoulding of cohesive soils.

In addition the moisture content of cohesive soils can be estimated in relation to their liquid or plastic limit.

(b) Consistency

Estimates of the consistency of a clay or silt soil may be made from manual examination, hand penetrometer test, SPT results or from laboratory tests to determine undrained shear or unconfined compressive strengths. The classification of consistency is defined in Table E1.3.1.

TABLE E1.3.1 - CONSISTENCY OF FINE-GRAINED SOILS

TERM	UNCONFINED STRENGTH (kPa)	FIELD IDENTIFICATION
Very Soft	<25	Easily penetrated by fist. Sample exudes between fingers when squeezed in the fist.
Soft	25 - 50	Easily moulded in fingers. Easily penetrated 50 mm by thumb.
Firm	50 - 100	Can be moulded by strong pressure in the fingers. Penetrated only with great effort.
Stiff	100 - 200	Cannot be moulded in fingers. Indented by thumb but penetrated only with great effort.
Very Stiff	200 - 400	Very tough. Difficult to cut with knife. Readily indented with thumb nail.
Hard	>400	Brittle, can just be scratched with thumb nail. Tends to break into fragments.

Unconfined compressive strength as derived by a hand penetrometer can be taken as approximately double the undrained shear strength ($q_u = 2 c_u$).

(c) Density Index

The insitu density index of granular soils can be assessed from the results of SPT or cone penetrometer tests. Density index should not be estimated visually.

TABLE E1.3.2 - DENSITY OF GRANULAR SOILS

TERM	SPT N VALUE	STATIC CONE VALUE q _c (MPa)	DENSITY INDEX (%)
Very Loose	0 - 3	0 - 2	0 - 15
Loose	3 - 8	2 - 5	15 - 35
Medium Dense	8 - 25	5 - 15	35 - 65
Dense	25 - 42	15 - 20	65 - 85
Very Dense	>42	>20	>85

E1.4 Soil Structure

(a) Zoning

A sample may consist of several zones differing in colour, grain size or other properties. Terms to classify these zones are:

Layer - continuous across exposure or sample

Lens - discontinuous with lenticular shape

Pocket - irregular inclusion

Each zone should be described, their distinguishing features, and the nature of the interzone boundaries.

(b) Defects

Defects which are present in the sample can include:

- fissures
- roots (containing organic matter)
- tubes (hollow)
- casts (infilled)

Defects should be described giving details of dimensions and frequency. Fissure orientation, planarity, surface condition and infilling should be noted. If there is a tendency to break into blocks, block dimensions should be recorded

E1.5 Soil Origin

Information which may be interpretative but which may contribute to the usefulness of the material description should be included. The most common interpreted feature is the origin of the soil. The assessment of the probable origin is based on the soil material description, soil structure and its relationship to other soil and rock materials.

Common terms used are:

“Residual Soil” - Material which appears to have been derived by weathering from the underlying rock. There is no evidence of transport.

“Colluvium” - Material which appears to have been transported from its original location. The method of movement is usually the combination of gravity and erosion.

“Landslide Debris” - An extreme form of colluvium where the soil has been transported by mass movement. The material is obviously distributed and contains distinct defects related to the slope failure.

“Alluvium” - Material which has been transported essentially by water. usually associated with former stream activity.

“Fill” - Material which has been transported and placed by man. This can range from natural soils which have been

placed in a controlled manner in engineering construction to dumped waste material. A description of the constituents should include an assessment of the method of placement.

E1.6 Fine Grained Soils

The physical properties of fine grained soils are dominated by silts and clays.

The definition of clay and silt soils is governed by their Atterberg Limits. Clay soils are characterised by the properties of cohesion and plasticity with cohesion defines as the ability to deform without rupture. Silts exhibit cohesion but have low plasticity or are non-plastic.

The field characteristics of clay soils include:

- dry lumps have appreciable dry strength and cannot be powdered
- volume changes occur with moisture content variation
- feels smooth when moist with a greasy appearance when cut.

The field characteristics of silt soils include:

- dry lumps have negligible dry strength and can be powdered easily
- dilatancy - an increase in volume due to shearing - is indicated by the presence of a shiny film of water after a hand sample is shaken. The water disappears upon remoulding. Very fine grained sands may also exhibit dilatancy.
- low plasticity index
- feels gritty to the teeth

E1.7 Organic Soils

Organic soils are distinguished from other soils by their appreciable content of vegetable matter, usually derived from plant remains.

The soil usually has a distinctive smell and low bulk density.

The USC system uses the symbol Pt for partly decomposed organic material. The O symbol is combined with suffixes “O” or “H” depending on plasticity.

Where roots or root fibres are present their frequency and the depth to which they are encountered should be recorded. The presence of roots or root fibres does not necessarily mean the material is an “organic material” by classification.

Coal and lignite should be described as such and not simply as organic matter.

APPENDIX B – LABORATORY TEST RESULTS

STS Geotechnics Pty Ltd

14/1 Cowpasture Place, Wetherill Park NSW 2164

Phone: (02)9756 2166 | Email: enquiries@stsgео.com.au

**Shrink Swell Index Report**

Project: 96 - 98 BRENNAN STREET, SMITHFIELD

Project No.: 30237

Client: NEW SOUTH WALES LAND AND HOUSING CORPORATION

Report No.: 20/0307

Address: 31 - 39 MAQUARIE STREET, PARAMMATT

Report Date: 30/01/2020

Test Method: AS 1289.7.1.1

Page: 1 OF 1

Sampling Procedure: AS 1289.1.3.1 Clause 3.1.3.2 - Thin Walled Sampler

STS / Sample No.		3396D-L/1	3396D-L/2				
Sample Location		Borehole 1 Refer to Drawing	Borehole 3 Refer to Drawing				
Material Description		Silty Clay, red brown, trace of gravel	Silty Clay, red brown, trace of gravel				
Depth (m)		0.8 - 1.0	0.8 - 1.0				
Sample Date		28/01/2020	28/01/2020				
Shrink	Moisture Content (%)	15.4	20.2				
	Soil Crumbling	Nil	Nil				
	Extent of Cracking	Nil	Nil				
	Strain (%)	1.0	5.3				
Swell	Moisture Content Initial (%)	14.6	22.3				
	Moisture Content Final (%)	25.1	40.3				
	Strain (%)	1.3	0.5				
Inert Inclusions (%)		<5	<5				
Shrink Swell Index (%)		0.9	3.1				

Remarks:



Accredited for compliance with ISO/IEC

17025 - Testing

The results of the tests, calibrations and/or
measurements included in this document are
traceable to Australian/national standards
NATA Accreditation Number 2750

A handwritten signature in black ink, appearing to read 'Orlando Mendoza'.

Approved Signatory.....

Technician: NP

Orlando Mendoza - Laboratory Manager

CERTIFICATE OF ANALYSIS

Work Order	: ES2002535	Page	: 1 of 4
Client	: STS Geotechnics	Laboratory	: Environmental Division Sydney
Contact	: Enquiries	Contact	: Customer Services ES
Address	: Unit 14/1 Cowpasture Place Wetherill Park 2164	Address	: 277-289 Woodpark Road Smithfield NSW Australia 2164
Telephone	: ----	Telephone	: +61-2-8784 8555
Project	: 30055/30060/30237	Date Samples Received	: 28-Jan-2020 12:30
Order number	: E-2020-0029	Date Analysis Commenced	: 28-Jan-2020
C-O-C number	: ----	Issue Date	: 31-Jan-2020 17:52
Sampler	: ----		
Site	: ----		
Quote number	: EN/222		
No. of samples received	: 10		
No. of samples analysed	: 10		



Accreditation No. 825
Accredited for compliance with
ISO/IEC 17025 - Testing

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QA/QC Compliance Assessment to assist with Quality Review and Sample Receipt Notification.

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is carried out in compliance with procedures specified in 21 CFR Part 11.

<i>Signatories</i>	<i>Position</i>	<i>Accreditation Category</i>
Ankit Joshi	Inorganic Chemist	Sydney Inorganics, Smithfield, NSW
Edwandy Fadjar	Organic Coordinator	Sydney Inorganics, Smithfield, NSW
Ivan Taylor	Analyst	Sydney Inorganics, Smithfield, NSW
Wisam Marassa	Inorganics Coordinator	Sydney Inorganics, Smithfield, NSW



General Comments

The analytical procedures used by the Environmental Division have been developed from established internationally recognized procedures such as those published by the USEPA, APHA, AS and NEPM. In house developed procedures are employed in the absence of documented standards or by client request.

Where moisture determination has been performed, results are reported on a dry weight basis.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

When sampling time information is not provided by the client, sampling dates are shown without a time component. In these instances, the time component has been assumed by the laboratory for processing purposes.

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Key : CAS Number = CAS registry number from database maintained by Chemical Abstracts Services. The Chemical Abstracts Service is a division of the American Chemical Society.
LOR = Limit of reporting
^ = This result is computed from individual analyte detections at or above the level of reporting
ø = ALS is not NATA accredited for these tests.
~ = Indicates an estimated value.



Analytical Results

Sub-Matrix: SOIL (Matrix: SOIL)				Client sample ID	30055/6229	30055/6231	30055/6234	30055/6235	30055/6236
Client sampling date / time					24-Jan-2020 00:00	24-Jan-2020 00:00	24-Jan-2020 00:00	24-Jan-2020 00:00	24-Jan-2020 00:00
Compound	CAS Number	LOR	Unit		ES2002535-001	ES2002535-002	ES2002535-003	ES2002535-004	ES2002535-005
				Result	Result	Result	Result	Result	Result
EA002: pH 1:5 (Soils)									
pH Value	----	0.1	pH Unit		6.4	5.2	5.4	5.6	4.8
EA010: Conductivity (1:5)									
Electrical Conductivity @ 25°C	----	1	µS/cm		75	53	142	371	451
EA055: Moisture Content (Dried @ 105-110°C)									
Moisture Content	----	0.1	%		19.6	8.8	15.6	8.3	19.8
ED040S : Soluble Sulfate by ICPAES									
Sulfate as SO4 2-	14808-79-8	10	mg/kg		10	20	140	80	170



Analytical Results

Sub-Matrix: SOIL (Matrix: SOIL)				Client sample ID	30055/6237	30055/6238	30060/1060	30237/S1	30237/S2
Client sampling date / time					24-Jan-2020 00:00	24-Jan-2020 00:00	24-Jan-2020 00:00	24-Jan-2020 00:00	24-Jan-2020 00:00
Compound	CAS Number	LOR	Unit		ES2002535-006	ES2002535-007	ES2002535-008	ES2002535-009	ES2002535-010
				Result	Result	Result	Result	Result	Result
EA002: pH 1:5 (Soils)									
pH Value	----	0.1	pH Unit		6.4	6.2	6.2	5.5	5.5
EA010: Conductivity (1:5)									
Electrical Conductivity @ 25°C	----	1	µS/cm		87	300	63	30	53
EA055: Moisture Content (Dried @ 105-110°C)									
Moisture Content	----	0.1	%		16.2	5.9	5.6	13.2	20.1
ED040S : Soluble Sulfate by ICPAES									
Sulfate as SO4 2-	14808-79-8	10	mg/kg		60	70	20	20	20
ED045G: Chloride by Discrete Analyser									
Chloride	16887-00-6	10	mg/kg		----	----	----	<10	60