

Project:	Milton Ulladulla Hospital – Cancer Care upgrades	Project No: 301351690
Project Address:	Milton Ulladulla Hospital - 106 Princes Hwy, Milton NSW 2538 Australia	Revision No: B
Date:	25/03/2025	

Stantec Australia has provided the following design documentation for certification purposes. All documents are to be reviewed by the BCA Certifier for compliance to the satisfaction of the BCA Certifier.

- Mechanical & Medical Gases Services Design Report dated 18/12/2024
  - o 301351690-STN-XX-XXX-BR-ME-000001
- Mechanical and Medical Gas Services Specifications dated 18/12/2024
  - o 301351690-STN-XX-XXX-SP-ME-000001
  - o 301351690-STN-XX-XXX-SP-MG-000001
- Mechanical and Medical Gas Services Drawings dated 18/12/2024
  - o 301351690-STN-01-000-DR-ME-000001 COVER SHEET
  - o 301351690-STN-01-000-DR-ME-000002 LEGEND AND NOTES
  - o 301351690-STN-ZZ-100-DG-ME-210012 CANCER CARE HVAC LAYOUT OPTION 1
  - o 301351690-STN-ZZ-100-DG-ME-210022 CANCER CARE HVAC LAYOUT OPTION 2
  - o 301351690-STN-ZZ-100-DG-ME-310012 CANCER CARE PIPEWORK LAYOUT OPTION 1
  - o 301351690-STN-ZZ-100-DG-ME-310022 CANCER CARE PIPEWORK LAYOUT OPTION 2
  - o 301351690-STN-00-000-DG-MG-040001 COVER SHEET
  - o 301351690STN-01-000-DR-MG-000002 LEGEND AND NOTES
  - o 301351690-STN-ZZ-100-DG-MG-410002 CANCER CARE EXPANSION MEDICAL GAS LAYOUT
- Medical Gas Services Drawings dated 17/01/2025 (Revision C02)
  - o 301351690-STN-01-000-DR-ME-000001 COVER SHEET
  - o 301351690-STN-01-000-DR-ME-000002 LEGEND AND NOTES
  - o 301351690-STN-ZZ-100-DG-ME-210012 CANCER CARE HVAC LAYOUT OPTION 1
  - o 301351690-STN-ZZ-100-DG-ME-210022 CANCER CARE HVAC LAYOUT OPTION 2
  - o 301351690-STN-ZZ-100-DG-ME-310012 CANCER CARE PIPEWORK LAYOUT OPTION 1

- o 301351690-STN-ZZ-100-DG-ME-310022 CANCER CARE PIPEWORK LAYOUT OPTION 2
- o 301351690-STN-00-000-DG-MG-040001 COVER SHEET

Stantec

- o 301351690STN-01-000-DR-MG-000002 LEGEND AND NOTES
- o 301351690-STN-ZZ-100-DG-MG-410002 CANCER CARE EXPANSION MEDICAL GAS LAYOUT



Stantec

• Relevant clauses of the National Construction Code (NCC) 2022, Volume One Building Code of Australia (BCA) Class 2 to 9 Buildings, as listed below:

NCC Clause	Description
C.3.15	Fire resistance
	Protection of Openings
	Openings for service installations
E.2.2b&c	Smoke Hazard Management
	General requirements
	Air Handling Systems
F4.5	Health and Amenity
	Light and Ventilation
	Ventilation of rooms
F4.11	Health and Amenity
	Light and Ventilation
	Carparks
F4.12	Health and Amenity
	Light and Ventilation
	Kitchen local exhaust ventilation
J3.5	Energy Efficiency
	Building Sealing
	Exhaust Fans
J3.7	Energy Efficiency
	Building Sealing
	Evaporative Coolers
J5	Energy Efficiency
	Air-conditioning and Ventilation Systems

## Stantec

• Relevant Australian Standards, including the following:

Standard	Description
AS1530.4:2005	Fire-resistance tests on elements of construction
AS1668.1:2015	The use of ventilation and air conditioning in buildings; Fire and smoke control in multi- compartment buildings
AS 1668.2:2012	The use of ventilation and air conditioning in buildings; Part 2 Mechanical ventilation for acceptable indoor-air quality
AS1668.4:2012	The use of ventilation and air conditioning in buildings; Part 4 Natural ventilation of buildings
AS1677.2	Refrigerating Systems Safety Requirements for fixed applications
AS 3000	SAA Wiring Rules
AS3500	Plumbing and Drainage
AS1682	Fire Dampers
AS3666.1:2011	Air-handling and water systems of buildings — Microbial control
AS 4254.1&2: 2012	Ductwork for air handling systems in buildings.

Stantec Australia has issued the following Services Design Statement for the Mechanical and Medical Gas services to assist Health Infrastructure NSW in preparing a REF for the Milton-Ulladulla Hospital Cancer Care upgrade, including the following:

• Services required

Stantec

- Capacities available or needed
- Connections needed
- Broader Headworks
- Any mitigation measures needed
- Acoustic treatment required

The Mechanical and Medical gas **Services Design Statement** has been prepared by Stantec at the request of **Gilda Barakat Project Director at Johnstaff** for the development of the *Milton Ulladulla Hospital upgrades within the Cancer Care.* 

Mechanical Services	Description
Services Required	<ul> <li>Variable Refrigerant Flow (VRF) to serve the cancer care.</li> <li>Fan Coil Units (FCU's) to serve the new room within the cancer care.</li> <li>Outside Air Fan (OAF) to serve the FCU's in fresh air.</li> <li>Exhaust Air Fan (EAF) to serve the Cleaner's room.</li> <li>Roof Cowl Mounted fan (RC) to serve the new ensuite room.</li> <li>Electrical switch boards for Mechanical services</li> </ul>
	Option 2 involves replacing the existing AC unit serving the refurbished area. The current plant is located at the back of the cancer care facility, see figure 1 below.
	Figure 1: Cancer Care facility



Capacities The mechanical services capacities will be driven by the heat load of the building. needed Connections Electrical supply connection for new Mechanical Switch Boards. needed Broader Conducting a detailed assessment of the new and existing HVAC system to determine Headworks its capacity, layout, and compatibility with the layout of the cancer care. Developing a comprehensive plan for the installation and integration of the new Ventilation connections and equipment. Ensuring adequate capacity and reliability of existing system to meet the operational demands of the HVAC system in general. The refrigerant pipework reticulation shall be configured to accommodate the new layout and Mechanical services as required. Any mitigation The positioning of the Fan coil units within the rooms could potentially increase the • measures needed difficulty of accessing and controlling maintenance procedures, thereby elevating the risk of operational disruptions or inefficiencies. Lack of as-built documentation. The following acoustic treatments are required for the new 1 bedroom and consult room Acoustic treatment required 3. New 1 BEDROOM: EGG CRATE TYPE EXHAUST GRILLE WITHIN ENSUITE TO PROVIDE EXHAUST WITHIN ROOM MAKEUP AIR TO BE SUPPLIED VIA ADJACENT ROOM NEW FAN COIL UNIT SERVING 1 BED ROOM TRANSFER GRILLE BETWEEN ENSUITE AND ROOM TO FACILITATE MAKEUP AIR SWIRL TYPE SUPPLY DIFFUSERS TO PROVIDE CONDITIONED SUPPLY AIR FROM DEDICATED FAN COIL UNIT 150x150 OA RISER FROM SINGLE BED ROOM TO ROOF COWL MOUNTED FAN OAF-02



New CONSULTROOM 3:



Refer to the Acoustic Design Report for additional details and acoustic data.



Medical Gas Services	Description	
Services Required	<ul> <li>The following medical gases are going to be installed: Oxygen (O2), Suction (SU/SC).</li> <li>Medical Services Panels with the following outlets: O2, SU,</li> <li>Medical Gas Alarm Panel</li> <li>Medical Gas Valve Box</li> <li>Note: Medical Air will not be provided in the cancer care area. This is a deviation from the AusHFG requirements. Design departure agreed with LHD during the design phase.</li> </ul>	
Capacities needed	<ul> <li>Existing medical gas enabling the connection of the following gases and their respective outlet quantities and requirements (Flow rate, pressure and O2%):</li> <li>x2 O2 (oxygen); x2 SU (Suction).</li> </ul>	
Connections needed	<list-item><list-item><list-item><list-item></list-item></list-item></list-item></list-item>	

Broader Headworks	<ul> <li>Conducting a detailed assessment of the existing medical gas system to determine its capacity, layout, and compatibility with the new room of the cancer care.</li> <li>Developing a comprehensive plan for the installation and integration of the new medical gas connections and equipment.</li> </ul>
	<ul> <li>Ensuring adequate capacity and reliability of the existing system to meet the operational demands of the new room of the cancer care upgrades and medical gas system.</li> </ul>
	<ul> <li>The new pipework shall be configured to accommodate the new layout and medical gas services panels as required.</li> </ul>
Any mitigation measures needed	<ul> <li>Disruption of the medical gas supply due to extension/altering of the existing system.</li> <li>The capacity of existing medical gas systems serving the new and existing rooms of the cancer care needs to be confirmed.</li> <li>Reuse of existing systems requiring recommissioning.</li> <li>Lack of as-built documentation.</li> </ul>

We trust that the above is sufficient for your present requirements. Should you require any further information, please do not hesitate to contact the undersigned.

### **Tommy Seidl**

### Mechanical Engineer Stantec Australia Pty Ltd

Stantec

Signature:

N. T.

Date:

25th of March 2025