


15 May 2024

Homes NSW
4 Parramatta Square
12 Darcy Street
Parramatta NSW 2150

Design Certificate for New Stormwater Detention Basin At York St, Forbes

This is to certify the design for the above-mentioned project per ADW Johnson Plans (Drawing Number 240380(2), Revision G, Dated 14.05.2024). The design has been carried out in accordance with ARR 2019, specifically in relation to the safety and access design consideration outlined in table 9.4.6. As detailed below, all sides have been graded at less than 1:4 to permit safe egress in an emergency.



ADW JOHNSON PTY LIMITED

ABN 62 129 445 398

Central Coast

5 Pioneer Avenue, Tuggerah NSW 2259
PO Box 3717, Tuggerah NSW 2259
Ph. 02 4305 4300
Fax. 02 4305 4399
Video. 02 43054374
Email. coast@adwjohnson.com.au

Hunter Region

7/335 Hillsborough Road, Warners Bay NSW 2282
Ph. 02 4978 5100
Fax. 02 4978 5199
Video. 02 4954 3948

Email. hunter@adwjohnson.com.au



Feel free to contact us in the office if you require further clarifications on any of the above.

Yours faithfully,

George Allan

**George Allan
Senior Engineer
ADW Johnson Pty Ltd
Hunter Office**

ADW JOHNSON PTY LIMITED

ABN 62 129 445 398

Central Coast

5 Pioneer Avenue, Tuggerah NSW 2259
PO Box 3717, Tuggerah NSW 2259
Ph. 02 4305 4300
Fax. 02 4305 4399
Video. 02 43054374
Email. coast@adwjohnson.com.au

Hunter Region

7/335 Hillsborough Road, Warners Bay NSW 2282
Ph. 02 4978 5100
Fax. 02 4978 5199
Video. 02 4954 3948
Email. hunter@adwjohnson.com.au

www.adwjohnson.com.au