

## Ausgrid Submission

## DA 10689 – 46 Fitzroy Street, Carrington

29th July 2021

Hi Tahlia,

Ausgrid has no major comment or objection for the development of this site as per the proposal in the links provided.

Ausgrid's acceptance is based primarily on the proposal to underground the electricity mains as per the Services Assessment document, page 41 & to follow through with this as per Ausgrid's contestable works process, more information on how to connect can be found on our website at <a href="https://www.ausgrid.com.au/Connections/Get-connected/Apply-for-a-connection">https://www.ausgrid.com.au/Connections/Get-connected/Apply-for-a-connection</a>

If the developer decides not to procced with undergrounding the overhead mains adjacent to the development site, these existing mains will need to be assessed by a competent "Approved Service Provider Level 3 – Overhead line Designer" to confirm if the development complies with Ausgrid standard NS220 & AS/NZ:7000.

## Regards,

## **Chris Jeffery**

Engineering Officer | Design Newcastle | Engineering - Asset Management



Wallsend Depot, Building 3, Abbott Street Wallsend NSW 2287

🖀 (02) 4951 9246 (59246) | 🔋 0409 714 311

📇 (02) 4951 9459 (59459) | 🖂 cjeffery@ausgrid.com.au