



NSW RURAL FIRE SERVICE

Department of Planning and Environment (Alpine Resorts)
PO Box 36
Jindabyne NSW 2627

Your reference: (CNR-63477) DA 21/18285
Our reference: DA20231209005588-Original-1

ATTENTION: Sandria Butler

Date: Wednesday 13 December 2023

Dear Sir/Madam,

Integrated Development Application
s100B – SFPP – Other Tourist Accommodation
2 GUTHRIE PL CHARLOTTE PASS NSW 2624, 112//DP1242013

I refer to your correspondence dated 08/12/2023 seeking general terms of approval for the above Integrated Development Application.

The New South Wales Rural Fire Service (NSW RFS) has considered the information submitted. General Terms of Approval, under Division 4.8 of the *Environmental Planning and Assessment Act 1979*, and a Bush Fire Safety Authority, under section 100B of the *Rural Fires Act 1997*, are now issued subject to the following conditions:

Asset Protection Zones

1. At the commencement of building works, and in perpetuity, all land within the subject leasehold site shall be managed as an inner protection area (IPA) in accordance with Appendix 4 of 'Planning for Bush Fire Protection 2019'.

Construction Standards

2. All proposed external alternations to the existing building identified as repair and replacement works shall:
- Not comprise the making of, or an alteration to the size of, any opening in a wall or roof, such as a doorway, window or skylight;
 - Be adequately sealed or protected to prevent the entry of embers; and,
 - Use equivalent or improved fire-resistant materials that do not affect any existing fire resisting components of the building.

Water and Utility Services

3. The provision of all new, and the modification of any existing water, electricity, and gas services must comply with Table 6.8c of Planning for Bush Fire Protection 2019.

Postal address

NSW Rural Fire Service
Locked Bag 17
GRANVILLE NSW 2142

Street address

NSW Rural Fire Service
4 Murray Rose Ave
SYDNEY OLYMPIC PARK NSW 2127

T (02) 8741 5555
F (02) 8741 5550
www.rfs.nsw.gov.au

Landscaping Assessment

4. Landscaping within the required asset protection zone must comply with Appendix 4 of Planning for Bush Fire Protection 2019.

Emergency and Evacuation Planning Assessment

5. A Bush Fire Emergency Management and Evacuation Plan must be prepared in accordance with Table 6.8d of Planning for Bush Fire Protection 2019 and be consistent with the following:

- The NSW RFS document: A Guide to Developing a Bush Fire Emergency Management and Evacuation Plan;
- include planning for the early relocation of occupants and;
- detailed plans of all emergency assembly areas, including on-site and off-site arrangements as stated in AS 3745 'Planning for emergencies in facilities', are clearly displayed.

General Advice – Consent Authority to Note

The existing buildings should to be upgraded where practical to improve ember protection (if not already constructed to the relevant Bushfire Attack Level under Australian Standard AS3959). Improved ember protection can be achieved by undertaking some, or all of the following; enclosing all openings (excluding roof tile spaces) or covering openings with a non-corrosive metal screen mesh with a maximum aperture of 2mm. Where applicable, this includes any subfloor areas, openable windows, vents, weep holes and eaves. External doors are to be fitted with draft excluders. Details of proposed upgrades to improve ember protection shall be submitted with the application for the Construction Certificate.

On advice from DPE Alpine this application has been assessed for repair/replacement works only as no new works are proposed.

For any queries regarding this correspondence, please contact David Webster on 1300 NSW RFS.

Yours sincerely,

Martha Dotter
Manager Planning & Environment Services
Built & Natural Environment



NSW RURAL FIRE SERVICE

BUSH FIRE SAFETY AUTHORITY

SFPP – Other Tourist Accommodation
2 GUTHRIE PL CHARLOTTE PASS NSW 2624, 112//DP1242013
RFS Reference: DA20231209005588-Original-1
Your Reference: (CNR-63477) DA 21/18285

This Bush Fire Safety Authority is issued on behalf of the Commissioner of the NSW Rural Fire Service under s100b of the Rural Fires Act (1997) subject to the attached General Terms of Approval.

This authority confirms that, subject to the General Terms of Approval being met, the proposed development will meet the NSW Rural Fire Service requirements for Bush Fire Safety under *s100b of the Rural Fires Act 1997*.



Department of Planning
and Environment

Issued under the Environmental Planning and Assessment Act 1979

Approved Application No 21/18285

Granted on the 19 December 2023

Signed S Butler

Sheet No 13 of 13

Martha Dotter

Manager Planning & Environment Services
Built & Natural Environment

Wednesday 13 December 2023