



From: Brian Calcutt Brian.Calcutt@meinhardtgroup.com
Subject: 122895 Sanctuary Point Lib-DA Queries
Date: 6 June 2022 at 4:53 pm
To: Rus Manaf rus.manaf@brewsterhorth.com.au
Cc: Sailesh Sharan Sailesh.Sharan@meinhardtgroup.com

BC

Rus,

Thanks for this.

1. We have made application for supply to Endeavour Energy, investigate the existing substation capacities with them and have prepared a design based on this information.
As we have advised previously, there is no requirement for a substation on this site, as we can get the required supply from the substation located across the road. This was covered in our Concept Report from November 2020.
2. We are not involved in the lighting of the carpark and cannot comment on whatever the Council and Endeavour Energy have agreed to.
3. The X2 fittings are pole lights. The lighting to the pathway complies with the requirements of AS 1158.3.1
4. The X3 is an inground wall washer fitting, intended to illuminate the green wall.

X2 	Pole Light	Simes/ Eagle Lighting	Boulevard pedestrian/ Cycle optics	17.8 W LED	3000 K	102 dia x 545	Pole mounted. Fitting integrated into pole	4m pole Grey fitting an dmatching pole' IP65 IK09 McAdam step 3
X3 	In ground wall washer	Targetti	Jedi recessed	12W LED	4000 K	600 x 81 x 82	In ground	IP66 IK10 60

Regards,

Brian Calcutt
Associate Director - Electrical


www.meinhardtgroup.com
www.meinhardt.com.au

Meinhardt Australia Pty Ltd.
Level 4, 66 Clarence Street
Sydney, NSW, 2000
Australia

P: +61 2 9699 3088
D: +61 2 8252 0409
M: +61 416 084 260
E: brian.calcutt@meinhardtgroup.com

Infrastructure & Environment | Structures | MEP | Project Management | Urban Development |
Façade Engineering | Environmentally Sustainable Design | Fire Performance Engineering |
Integrated Design Management | Mission Critical Facility Design