

Tom Wetzlar

From: Adela Ngui
Sent: Thursday, 9 December 2021 2:08 PM
To: Eva Ma
Subject: FW: Black Bear - Groundwork Variation

Kind regards,

Adela Ngui
M +61 432 935 121



BELLEVARDE CONSTRUCTIONS PTY LTD

BELLEVARDE.COM



From: Euan Diver <euan_diver@evt.com>
Sent: Thursday, 9 December 2021 12:07 PM
To: Stephen O'Ryan <steve.oryan@bellevarde.com.au>
Cc: Rhyllie Maurirere <rhyllie@bellevarde.com.au>; Adela Ngui <adela@bellevarde.com.au>; Andrew Harrigan <Andrew_Harrigan@evt.com>
Subject: RE: Black Bear - Groundwork Variation

Afternoon Stephen,

Please accept this e-mail as confirmation that Kosciuszko Thredbo Pty Ltd has no objection to the installation of the temporary construction anchors as proposed and detailed.

As discussed, there are existing underground services located in the Diggings Terrace roadway, however given the proposed depth of the anchors is greater than 2.0m at the south eastern road edge where the services are located, the anchors will be well below the services.

Regards,

Euan

Euan Diver | Environmental Services Manager
Kosciuszko Thredbo Pty Ltd
PO Box 92 Thredbo NSW 2625
P: 02 6459 4103 | M: 0417 042 739



Follow us on:



From: Stephen O'Ryan <steve.oryan@bellevarde.com.au>

Sent: Thursday, 9 December 2021 8:43 AM

To: Euan Diver <euan_diver@evt.com>

Cc: Rhylie Maurirere <rhylie@bellevarde.com.au>; Adela Ngui <adela@bellevarde.com.au>

Subject: FW: Black Bear - Groundwork Variation

Euan,

As discussed earlier please see the revised documentation for the site retention works at the Blackbear.

The engineer would like to put some temporary anchors under the road. These anchors will be destressed when the structure is complete.

It would be appreciated if you would provide your acceptance of the proposed temporary anchors.

If you have any questions please call.

Regards,

Stephen O'Ryan



BELLEVARDE CONSTRUCTIONS

T +61 2 6295 2928 | M 0409 625 314 | steve.oryan@bellevarde.com.au | www.bellevarde.com

ABN 88 001 998 036