



PLATFORM 5 PTY.LTD Copyright \bigcirc

> This drawing remains the property of Platform 5 pty ltd. It may be used for the purpose for which it was commissioned & in accordance with the terms of engagement for that commission. Unauthorised use of this drawing is prohibited. Do not scale drawings Verify all dimensions on site

LEGEND

270MM DOUBLE BRICK CONSTRUCTION

110MM SINGLE BRICK CONSTRUCTION

110MM STUD WALL

200MM DINCEL WALL

200MM BLOCK WALL CONSTRUCTION

EXISTING NATURAL GROUND LEVELS

250MM BRICK VENEER CONSTRUCTION

EX XXXX

30

SET DOWN IN BATHROOMS

SSL - STRUCTURAL SLAB LEVEL

EXISTING STRUCTURES TO BE DEMOLISHED.

GENERAL NOTES:

_ _ _ _

1. Written dimensions to take precedence over scale 2. Builder to verify all boundary clearances and site set out dimensions prior to

commencement of construction 3. Levels and contours are based on supplied datum. prior to construction the relevant authority should be contacted for possible minimum floor level requirements and flood information.

4. All works to be carried out in accordance with the Building Code of Australia, all Local and State Government Ordinances, relevant Australian Standards, Local

Electricity and Water Authorities concerned. 5. All structural work and site drainage to be subject to the Engineers details or

certification where required by Council. 6. Articulation joints in masonary to be provided as per Engineers Details and/or in

accordance with BCA clause 3.3.1.8 Retaining walls are required to be engineer designed and certified where required.
All plumbing works to be strictly in accordance with A.S. 3500 and approved by

relevant authorities. 9. All drawings are to be read in conjunction with the Engineer's Structural Drawings.

10. All windows and glazing to comply with A.S. 1288 & A.S. 2047. 11. Batters to comply with appropriate soil classification described in Table 3.1.1.1 BCA Vol 2 12. Engineer to provide design to address footings if built in close proximity to sewer,

stormwater easements.

13. Vehicular crossover to be constructed as per Council requirements. 14. Articulated joints in accordance with BCA 3.3.1.8 (Vol2)

15. Ventilation to wc to be an exhaust fan in accordance with BCA-f4.5 & As-1668.2

16. Provide cold water connection & gpo to dishwasher space 17. Hotwater system to comply with A.S.3500

Downpipes to be a maximum 12m spacing and adjacent to valley intersections
Drainage to be in accordance with part 3 of the BCA. point

of discharge to meet local authority requirement

