### PROPOSED RESIDENTIAL DEVELOPMENT LOT 4 NO. 57 TOMPSON ROAD, PANANIA STORMWATER MANAGEMENT PLANS

#### **GENERAL NOTES:**

- THESE THE PLANS SHALL BE READ IN CONJUCTION WITH OTHER RELEVANT CONSULTANTS'S PLANS, SPECIFICATIONS, CONDITIONS OF DEVELOPMENT CONCEST AND CONSTRUCTION CERTIFICATE REQUIREMENTS. WHERE DISCREPANCIES ARE FOUND NASTASI & ASSOCIATES MUST BE CONTACTED
- WHERE THESE PLANS ARE NOTED FOR DEVELOPMENT APPLICATION PURPOSES ONLY, THEY SHALL NOT BE USED FOR OBTAINING A CONSTRUCTION CERTIFICATE NOR USED FOR CONSTRUCTION PURPOSES.
- SUBSOIL DRAINAGE SHALL BE DESIGNED AND DETAILED BY THE STRUCTURAL ENGINEER. SUBSOIL DRAINAGE SHALL NOT BE CONNECTED INTO THE STORMWATER SYSTEM IDENTIFIED ON THESE PLAN UNLESS APPROVED BY NASTASI & ASSOCIATES ENGINEERS.

#### STORMWATER CONSTRUCTION NOTES:

- ALL WORK SHALL BE CARRIED OUT IN ACCORDANCE WITH AS/NZS 3500 (CURRENT EDITION) AND THE REQUIREMENTS OF THE LOCAL COUNCIL'S POLICIES AND CODES
- THE MINIMUM SIZE OF THE STORMWATER DRAINS SHALL NOT BE LESS THAN DN 90 FOR CLASS 1 BUILDINGS AND DN100 FOR OTHER CLASSES OF BUILDING OR AS REQUIRED BY REGULATORY AUTHORITY
- THE MINIMUM GRADIENT OF STORMWATER DRAINS SHALL BE 1%, UNLESS NOTED OTHERWISE
- COUNCIL'S TREE PRESERVATION ORDER IS TO BE STRICTLY ADHERED TO . NO TREES SHALL BE REMOVED UNTIL PERMIT IS OBTAINED
- 5. PUBLIC UTILITY SERVICES ARE TO BE ADJUSTED AS NECESSARY AT THE CLIENT'S EXPENSE
- ALL PITS TO BE BENCHED AND STREAMLINED. PROVIDE STEP IRONS FOR ALL PITS OVER 1.2m DEEP
- ALL PITS IN AN EASEMENT OR TRAFFICABLE AREA ARE TO BE PRE-CAST OR CASTIN-SITU OR
- MAKE SMOOTH JUNCTION WITH ALL EXISTING WORK
- VEHICULAR ACCESS AND ALL SERVICES TO BE MAINTAINED AT ALL TIMES TO ADJOINING PROPERTIES
- SERVICES SHOWN ON THESE PLANS HAVE BEEN LOCATED FROM INFORMATION SUPPLIED BY THE RELEVANT AUTHORITIES AND FIELD INVESTIGATIONS AND ARE NOT GUARANTEED COMPLETE NOR CORRECT. IT IS THE CLIENT & CONTRACTOR'S RESPONSIBILITY TO LOCATE ALL PRIOR TO CONSTRUCTION
- ANY VARIATION TO THE WORKS AS SHOWN ON THE APPROVED DRAWINGS ARE TO BE CONFIRMED BY NASTASI & ASSOCIATES PRIOR TO THEIR COMMENCEMENT

- RAINWATER SUPPLY PLUMBING TO BE CONNECTED TO OUTLETS WHERE REQUIRED BY BASIX CERTIFICATE
- TOWN WATER CONNECTION TO RAINWATER TANK TO THE SATISFACTION OF THE REGULATORY AUTHORITY. THIS WAY REQUIRE PROVISION OF:
- 2.2. BACKFLOW PREVENTION DEVICE
- NO DIRECT CONNECTION BETWEEN TOWN WATER SUPPLY AND THE RAINWATER SUPPLY
- AN APPROVED STOP VALVE AND/OR PRESSURE LIMITING VALVE AT THE RAINWATER TANK
- PROVIDE AT LEAST ONE EXTERNAL HOSE COCK ON THE TOWN WATER SUPPLY FOR FIRE FIGHTING
- PROVIDE APPROPRIATE FLOAT VALVES AND/OR SOLENOID VALVES TO CONTROL TOWN WATER SUPPLY INLET TO TANK IN ORDER TO ACHIEVE THE TOP-UP INDICATED ON THE TYPICAL DETAIL
- ALL PLUMBING WORKS ARE TO BE CARRIED OUT BY LICENSED PLUMBERS IN ACCORDANCE WITH AS/N7S3500.1 NATIONAL PLUMBING AND DRAINAGE CODE
- PRESSURE PUMP ELECTRICAL CONNECTION TO BE CARRIED OUT BY A LICENSED ELECTRICIAN
- ONLY ROOF RUN-OFF IS TO BE DIRECTED TO THE RAINWATER TANK. SURFACE WATER INLETS ARE NOT BE
- PIPE MATERIALS FOR RAINWATER SUPPLY PLUMBING ARE TO BE APPROVED MATERIALS TO AS/NZE3500 PART 1 SECTION 2 AND TO BE CLEARLY AND PERMANENTLY IDENTIFIED AS 'RAINWATER'. THIS MAY BE ACHIEVED FOR BELOW GROUND PIPES USING IDENTIFICATION TAPE (MADE IN ACCORDANCE WITH AS2648) OR FOR ABOVE FROUND PIPES BY USING ADHESIVE PIPE MARKERS (MAKE IN ACCORDANCE WITH AS1345)
- EVERY RAINWATER SUPPLY OUTLET POINT AND THE RAINWATER TANK ARE TO BE LABELED 'RAINWATER'
- 12. ALL INLETS AND OUTLETS TO THE RAINWATER TANK ARE TO HAVE SUITABLE MEASURES PROVIDED TO

#### **EROSION AND SEDIMENT NOTES:**

- THESE THE PLANS SHALL BE READ IN CONJUCTION WITH EROSION AND SEDIMENT CONTROL
- THE CONTRACTOR SHALL IMPLEMENT ALL SOIL EROSION AND SEDIMENT CONTROL MEASURE AS NECESSARY AND TO THE SATISFACTION OF THE RELEVANT LOCAL AUTHORITY PRIOR TO THE COMMENCEMENT ANY DURING CONSTRUCTION. NO DISTURBANCE TO THE SITE SHALL BE PERMITTED OTHER THAN IN THE IMMEDIATE AREA OF THE WORKS AND NO MATERIAL SHALL BE REMOVED FROM THE SITE WITHOUT THE RELEVANT LOCAL AUTHORITY APPROVAL. ALL EROSION AND SEDIMENT CONTROL DEVICES TO BE INSTALLED AND MAINTAINED IN ACCORDANCE WITH STANDARDS OUTLINED IN NSW DEPARTMENT OF HOUSING'S "MANAGING URBAN STORMWATER - SOILS AND CONSTRUCTIONS"
- TOPSOIL SHALL BE STRIPPED AND STOCKPILED OUTSIDE HAZARD AREA SUCH AS DRAINAGE LINES. THIS TOPSOIL SHALL BE RESPREAD LATER ON AREAS TO BE REVEGETATED AND STABILIZED ONLY, TOPSOIL SHALL NOT BE RESPREAD ON ANY OTHER AREA UNLESS. SPECIFICALLY INSTRUCTED BY THE SUPERINTENDENT. IF THEY ARE TO REMAIN LONGER THAN MULCH AND HYDROSEEDING AND, IF NECESSARY, BY LOCATING BANKS OR DRAINS DOWNSTREAM OF A STOCKPILE TO RETARD SILT LADEN RUNOFF
- THE CONTRACTOR SHALL REGULARLY MAINTAIN ALL EROSION AND SEDIMENT CONTROL DEVICES AND REMOVE ACCUMULATED SILT FROM SUCH DEVICES SUCH THAT MORE THAN 60% OF THEIR CAPACITY IS NOT LOST. ALL THE SILT IS TO BE PLACED OUTSIDE THE LIMIT OF WORKS. THE PERIOD FOR MAINTAINING THESE DEVICES SHALL BE AT LEAST UNTIL ALL DRISTURBED AREAS ARE REVEGETATED AND FURTHER AS MAY BE DIRECTED BY SUPERINTENDENT. OR COUNCIL
- VEHICULAR TRAFFIC SHALL BE CONTROLLED DURING CONSTRUCTION CONFINING ACCESS WHERE POSSIBLE TO NOMINATED STABILISED ACCESS POINTS
- THE CONTRACTOR SHALL IMPLEMENT DUST CONTROL BY REGULAR WETTING DOWN DISTURBED
- 7. ALL DRAINAGE PIPE INLETS TO BE CAPPED UNTIL
- PITS CONSTRUCTED AND PROTECTED WITH SILT BARRIER

#### MINIMUM PIPE COVER NOTES:

LOCATION	MINIMUM COVER							
NO SUBJECT TO VEHICLE LOADING	100mm SINGLE RESIDENTIAL							
SUBJECT TO VEHICLE LOADING	450mm WHERE NOT IN A ROAD							
UNDER A SEALED ROAD	600mm							
UNSEALED ROAD	750mm							
PAVED DRIVEWAY	100mm PLUS DEPTH OF CONCRETE							

SEE AS2032 INSTALLATION OF UPVC PIPES FOR FURTHER INFORMATION.

CONCRETE PIPE COVER SHALL BE IN ACCORDANCE WITH AS3725-1989 LOADS ON BURIED CONCRETE PIPES, HOWEVER A MINIMUM COVER OF 450mm WILL APPLY

WHERE INSUFFICIENT COVER IS PROVIDED, THE PIPE SHALL BE COVERED AT LEAST 50mm THICK OVERLAY AND SHALL

- 150 mm REINFORCED CONCRETE WHERE SUBJECT TO HEAVY VEHICLE TRAFFIC
- 75 mm thickness of Brick or 100 mm of concrete paving where subject to light vehicle traffic; or
- 50mm THICK BRICK OR CONCRETE PAVING WHERE NOT SUBJECT TO VEHICLE TRAFFIC

#### **SURFACE STORMWATER PIT NOTES:**

<u>PIT DEPTH (mm)</u>	MINIMUM PIT SIZE (mm)							
UP TO 600 mm	450 x 450							
FROM 600mm TO LESS THAN 900mm	600 x 600							
FROM 900mm	900 x 900							

ALL BASEMENT PIT TO BE FITTED WITH HEAVY DUTY CLASS C GRATE & FRAME

	<u>LEGEND</u>
	DENOTES BELOW GROUND ON-SITE DETENTION TANK
+ + + + + + + + + + + + + + + + + + +	DENOTES ON-SITE DETENTION BASIN
<sub>o</sub> DP	DENOTES \$100 DOWNPIPE (U.N.O)
。 IP	DENOTES INSPECTION OPENING WITH SCREW DOWN LID AT FINISHED SURFACE LEVEL
● <sup>PB</sup>	DENOTED PLANTER BOX DRAINS
<sup>fD</sup> <b>■</b> ● <sup>fD</sup>	DENOTED SURFACE DRAINAGE GRATES
<b>©</b>	DENOTED CLEANING EYE
×	STORMWATER PIT - SOLID COVER
	STORMWATER PIT - GRATED INLET
	DENOTES GRATED DRAIN
2505355555	DENOTES ABSORPTION TRENCH
И	DENOTES NON RETURN VALVE
<b>&gt;&gt;&gt;&gt;</b>	DENOTES OVERLAND FLOW PATH
IL .	INVERT LEVEL
TK	TOP OF KERB
RL	REDUCED LEVEL/SURFACE LEVEL
RL 17.09 +	PROPOSED FINISH SURFACE LEVEL
<del></del>	DENOTED Ø100mm PVC (SEWER GRADE) @1% Min. Fall u.n.o for rainwater re-use
<del></del>	DENOTED #100mm PVC (SEWER GRADE) @1% Min. Fall U.N.O
<del></del>	DENOTED #150mm PVC (SEWER GRADE) @1% Min. Fall U.N.O
225	DENOTED #225mm PVC (SEWER GRADE) @0.5% Min. Fall U.N.O
<b>—</b> G <b>—</b>	DENOTE AGG PIPE
	DENOTE RAINWATER TANK

SCHEDULE OF DR.	AWING
DESCRIPTION	SHEET NUMBER
OVER SHEET & NOTES	C1
RAINAGE PLANS	C2
TORMWATER DETAILS	З
TORMWATER DETAILS	C4


#### LOCATION MAP





# www.dialbeforeyoudig.com.au

### ISSUE FOR APPROVAL

<sub>A</sub> L	PREVENT MOSQUITO AND VERMIN ENTRY.														_				100 510
Ϋ́Ε							eneral notes:	NASTASI & ASSOCIATES	QUALITY CONT	QUALITY CONTROL APPROVED:		CLIENT:		ADDRESS:		CONCEPT PLAN FOR APPROVAL			
⊢		<del>                                     </del>			GR.	* THIS DRIVING IS THE COPPRIGHT OF INISTING ASSOCIATES CONSULTING CRILL & STRUCTURAL EXCHANGES, Unit 5,1-3 Whyele Place, Produces, 2170. PO Bax 6004, Harmanshiffs, ISSE, 2170.	DESIGNED DATE		/ /		LOT 4 NO. 57	TOMPSON ROAD, PANANIA							
			DISCIPLINE DIVINING T	PLINE DIVINING TITLE AND NUMBER DATE REX. DRAWING TITLE AND NUMBER DATE REX.	ER DATE REV. DI	IT IS NOT ALLOWED TO COPY OR REPRODUCE IT'S CONTENTS IN ANY FORM EXCEPT FOR THE PURPOSE WHICH IT IS INTENDED WITHOUT THE ABOVE	CONSULTING CIVIL & STRUCTURAL ENGINEERS B.E., M.I.E. AUSTON	SH.D. 07.04.202	.2022	A			TITLE:		SCALE ( AT ORIGINAL SIZE) AS NOT		AS NOTED		
⊢			STRUCT.		LANE	E DS	00	ORBILITAT'S AUTHORITY. DO NOT SCALE THIS DAMING, ONLY STATED DIMENSIONS ARE TO BE ORBIDETED.	UNIT 5, 1-3 WHYALLA PLACE, PRESTONS NSW 2170 PH: (02) 9607 2864 OR (02) 8798 5617 FAX: (02) 9731 2081	CHECKED DATE	$\equiv$	THUN	_			0U557 A NOT50	PROJECT NO.	DRAWING NO.	REVISION NO.
	A ISSUED FOR REVIEW	07.04.202	2 BLEC.		CME	L MEY	DR	CONTRACTOR TO VERIFY THE DETAIL / INFORMATION GIVEN IN THIS WIND THE SERVICES SHALL BE BROUGHT TO BEGINEERS ATTENTION MOR TO COMMERCEMENT OF WORK, FAILURE TO COMPLY WITH THE ABOVE	MOB: 0419 041 401		.2022	S. NASTASI B.E, M.I.E, CpEng, Npor—3	WIS	DOM	LOVER	SHEET & NOTES	27248	C1	Α
ISS	SUE REVISION	DATE	HND.					ILL BE CONTRACTORS LIMBLITY.										= -	• •









### POLLUTION CONTROL PIT NOTES:

- 1. MESH SCREEN IS TO BE GALVANISED LYSAGHT RH3030 MAXI MESH COVERED WITH GEOTEXTILE IN GALVANISED STEEL FRAME WITH LIFTING HANDLES ACROSS BASE.
- 2. GEOTEXTILE IS TO BE BIDIM A14, PROPEX 4550 OR SIMILAR WITH COEFFICIENT OF PERMEABILITY GREATER THAN 50E-4m/s.



## SILT ARRESTOR PIT 1 DETAILS SCALE 1:20



## TYPICAL SURFACE DRAINS

www.dialbeforeyoudig.com.au

