



Issued under the Environmental Planning and Assessment Act 1979

Approved Application No 22/6646 Granted on the 12 December 2022

Signed M Brown
Sheet No 9 of 9

Department of Planning and Environment (Alpine Resorts) PO Box 36

Jindabyne NSW 2627

Your reference: (CNR-39643) DA 22/6646 Our reference: DA20220518007897-Original-1

ATTENTION: Mark Brown Date: Tuesday 16 August 2022

Dear Sir/Madam,

Integrated Development Application s100B - SFPP - Other Tourist Accommodation SNOWY RIVER SKI CLUB-DOORACK 8 FARM CREEK PL GUTHEGA NSW 2624, 3//DP1152944

I refer to your correspondence dated 30/05/2022 seeking general terms of approval for the above Integrated Development Application.

The New South Wales Rural Fire Service (NSW RFS) has considered the information submitted. General Terms of Approval, under Division 4.8 of the *Environmental Planning and Assessment Act 1979*, and a Bush Fire Safety Authority, under section 100B of the *Rural Fires Act 1997*, are now issued subject to the following conditions:

Asset Protection Zones

1. At the commencement of building works, and in perpetuity, all land within the subject leasehold site shall be managed as an inner protection area (IPA) in accordance with Appendix 4 of 'Planning for Bush Fire Protection 2019'.

Construction Standards

- 2. All proposed external alternations to the existing building identified as repair and replacement works shall:
- Not comprise the making of, or an alteration to the size of, any opening in a wall or roof, such as a doorway, window or skylight;
- Be adequately sealed or protected to prevent the entry of embers; and
- Use equivalent or improved fire-resistant materials that do not affect any existing fire resisting components of the building.
- 3. The existing buildings are required to be upgraded where practical to improve ember protection (if not already constructed to the relevant Bushfire Attack Level under Australian Standard AS3959). Improved ember protection

can be achieved by undertaking some, or all of the following; enclosing all openings (excluding roof tile spaces) or covering openings with a non-corrosive metal screen mesh with a maximum aperture of 2mm. Where

1

applicable, this includes any subfloor areas, openable windows, vents, weep holes and eaves. External doors are to be fitted with draft excluders. Details of proposed upgrades to improve ember protection shall be submitted with the application for the Construction Certificate.

4. Any new Class 10a or 10b structures as defined per the 'Building Code of Australia' situated within 6 metres of a habitable building must comply with the relevant Bushfire Attack Level under Australian Standard AS3959.

Water and Utility Services

5. The provision of all new and the modification of any existing water, electricity, and gas services must comply with Table 6.8c of 'Planning for Bush Fire Protection 2019'.

Landscaping Assessment

- 6. Landscaping within the required asset protection zone must comply with Appendix 4 of *Planning for Bush Fire Protection 2019*. In this regard, the following principles are to be incorporated:
 - A minimum 1 metre wide area (or to the property boundary where the setbacks are less than 1 metre), suitable for pedestrian traffic, must be provided around the immediate curtilage of the building;
 - Planting is limited in the immediate vicinity of the building;
 - Planting does not provide a continuous canopy to the building (i.e. trees or shrubs are isolated or located in small clusters);
 - Landscape species are chosen to ensure tree canopy cover is less than 15% (IPA), and less than 30% (OPA) at maturity and trees do no touch or overhang buildings;
 - Avoid species with rough fibrous bark, or which retain/shed bark in long strips or retain dead material in their canopies;
 - Use smooth bark species of trees species which generally do not carry a fire up the bark into the crown;
 - Avoid planting of deciduous species that may increase fuel at surface/ ground level (i.e. leaf litter);
 - Avoid climbing species to walls and pergolas:
 - Locate combustible materials such as woodchips/mulch, flammable fuel stores away from the building;
 - Locate combustible structures such as garden sheds, pergolas and materials such as timber garden furniture away from the building; and
 - Low flammability vegetation species are used.

Emergency and Evacuation Planning Assessment

- 7. A Bush Fire Emergency Management and Evacuation Plan must be prepared in accordance with Table 6.8d of Planning for Bush Fire Protection 2019 and be consistent with the following:
- The NSW RFS document: A Guide to Developing a Bush Fire Emergency Management and Evacuation Plan;
- include planning for the early relocation of occupants and;
- detailed plans of all emergency assembly areas, including on-site and off-site arrangements as stated in AS 3745 'Planning for emergencies in facilities', are clearly displayed.

For any queries regarding this correspondence, please contact David Webster on 1300 NSW RFS.

Yours sincerely,

Michael Gray

Manager Planning & Environment Services

Built & Natural Environment



BUSH FIRE SAFETY AUTHORITY

SFPP – Other Tourist Accommodation SNOWY RIVER SKI CLUB-DOORACK 8 FARM CREEK PL GUTHEGA NSW 2624, 3//DP1152944 RFS Reference: DA20220518007897-Original-1

Your Reference: (CNR-39643) DA 22/6646

This Bush Fire Safety Authority is issued on behalf of the Commissioner of the NSW Rural Fire Service under s100b of the Rural Fires Act (1997) subject to the attached General Terms of Approval.

This authority confirms that, subject to the General Terms of Approval being met, the proposed development will meet the NSW Rural Fire Service requirements for Bush Fire Safety under *s100b* of the Rural Fires Act 1997.

Michael Gray

Manager Planning & Environment Services
Built & Natural Environment

Tuesday 16 August 2022