



NSW RURAL FIRE SERVICE



Department of Planning
and Environment

Issued under the Environmental Planning and Assessment Act 1979

Approved Application No DA 22/11263

Granted on the 17 February 2023

Signed M Brown

Sheet No 15 of 15

Your reference: (CNR-44903) DA 22/11263

Our reference: DA20220904010407-Original-1

Department of Planning and Environment (Alpine Resorts)
PO Box 36
Jindabyne NSW 2627

ATTENTION: Sandria Butler

Date: Thursday 10 November 2022

Dear Sir/Madam,

Integrated Development Application

s100B – SFPP – Other Tourist Accommodation

FRIDAY DR THREDBO VILLAGE NSW 2625, 876//DP1243112, 862//DP1128686

I refer to your correspondence dated 06/09/2022 seeking general terms of approval for the above Integrated Development Application.

The New South Wales Rural Fire Service (NSW RFS) has considered the information submitted. General Terms of Approval, under Division 4.8 of the *Environmental Planning and Assessment Act 1979*, and a Bush Fire Safety Authority, under section 100B of the *Rural Fires Act 1997*, are now issued subject to the following conditions:

General Conditions

1. The development shall be generally consistent with the submitted plans with project name "Proposed Development - New Bike Storage Facility, Thredbo NSW 2625" drawing no.325-01 and "MTB Repair Shop" drawing no. MTB1

Construction Standards

2. All proposed external alternations to the existing building identified as repair and replacement works shall:
- Not comprise the making of, or an alteration to the size of, any opening in a wall or roof, such as a doorway, window or skylight;
 - Be adequately sealed or protected to prevent the entry of embers; and
 - Use equivalent or improved fire-resistant materials that do not affect any existing fire resisting components of the building.
3. The existing buildings are required to be upgraded where practical to improve ember protection (if not already constructed to the relevant Bushfire Attack Level under Australian Standard AS3959). Improved ember protection can be achieved by undertaking some, or all of the following;
- enclosing all openings (excluding roof tile spaces) or covering openings with a non-corrosive metal screen mesh with a maximum aperture of 2mm.

Postal address

NSW Rural Fire Service
Locked Bag 17
GRANVILLE NSW 2142

Street address

NSW Rural Fire Service
4 Murray Rose Ave
SYDNEY OLYMPIC PARK NSW 2127

T (02) 8741 5555
F (02) 8741 5550
www.rfs.nsw.gov.au

- Where applicable, this includes any subfloor areas, openable windows, vents, weep holes and eaves.
- External doors are to be fitted with draft excluders.

Details of proposed upgrades to improve ember protection shall be submitted with the application for the Construction Certificate.

4. Any new construction that does not generally meet the criteria of Condition 3 must comply with Section 3 and Section 5 (BAL 12.5) Australian Standard AS3959-2018 *Construction of buildings in bushfire-prone areas* or the relevant requirements of the *NASH Standard - Steel Framed Construction in Bushfire Areas* (incorporating amendment A - 2015). New construction must also comply with the construction requirements in Section 7.5 of *Planning for Bush Fire Protection 2019*.

Water and Utility Services

5. The provision of all new, and the modification of any existing water, electricity, and gas services must comply with Table 6.8c of *Planning for Bush Fire Protection 2019*.

Emergency and Evacuation Planning Assessment

6. A Bush Fire Emergency Management and Evacuation Plan must be prepared in accordance with Table 6.8d of *Planning for Bush Fire Protection 2019* and be consistent with the following:

- The NSW RFS document: A Guide to Developing a Bush Fire Emergency Management and Evacuation Plan; and
- detailed plans of all emergency assembly areas, including on-site and off-site arrangements as stated in AS 3745 'Planning for emergencies in facilities', are clearly displayed.

For any queries regarding this correspondence, please contact David Webster on 1300 NSW RFS.

Yours sincerely,

Michael Gray
Manager Planning & Environment Services
Built & Natural Environment



NSW RURAL FIRE SERVICE

BUSH FIRE SAFETY AUTHORITY

SFPP – Other Tourist Accommodation

FRIDAY DR THREDBO VILLAGE NSW 2625, 876//DP1243112, 862//DP1128686

RFS Reference: DA20220904010407-Original-1

Your Reference: (CNR-44903) DA 22/11263

This Bush Fire Safety Authority is issued on behalf of the Commissioner of the NSW Rural Fire Service under s100b of the Rural Fires Act (1997) subject to the attached General Terms of Approval.

This authority confirms that, subject to the General Terms of Approval being met, the proposed development will meet the NSW Rural Fire Service requirements for Bush Fire Safety under *s100b of the Rural Fires Act 1997*.

Michael Gray

Manager Planning & Environment Services
Built & Natural Environment

Thursday 10 November 2022