

Jezzangel P/L t/as PDI Group (nsw) P.O Box 325, Winston Hills NSW 2153

**TEL:** (02) 9686 2982 **MOB:** 0405 735 011

**EMAIL:** anthony@pdigroupnsw.com.au

ABN 38 159 704 855

GOLD LIC. NO. 252392C

## Report

17-08-2022

Reference no. 1001

TO: To who may concern

DDRESS: Lot12 @ 22 Collins Crescent YAGOONA. NSW 2199

**DESCRIPTION OF WORKS: Dye inspection to the existing Storm water line &Sewer at the above address**

- At LOT 12. the existing 150 mm external storm water drainage pipeline, connecting the neighboring property through including lot 12. refer to the photos attached. During the dye testing.







- At the pit located at the Garden Reserve, the color dye appeared as a result confirming the test successfully. Refer to the photos below



The size of the outlet changes from **150mm to 225 mm** stormwater pipeline refer to the attached photo.




The existing 225mm stormwater pipeline continuing downstream through to Marion Street.  
Refer to the attached photos.



The colored dye appeared at the stormwater pipeline 900mm / pit at Marion Street successfully. Refer to the photo below.





Refer to the attached above marked drawing in relation to the pipeline layout from LOT12 to Marion Street.

YOURS TRULY

A handwritten signature in black ink, appearing to read 'A Saliba', with a stylized flourish at the end.

ANTHONY SALIBA

CUSTOMERS SIGNATURE.....

DATE...17-08-2022