

Mr Jake Freeman  
Asset Manager  
oOh! Media  
Level 2, 73 Miller Street  
North Sydney NSW 2060

Arcadis Australia Pacific Pty Ltd  
Level 16, 580 George Street  
SYDNEY NSW 2000  
Tel No: +61 2 8907 9000  
arcadis.com

15/11/2023


**Advertising Signage Structure – Pedestrian Bridge over  
Cowpasture Road, Bossley Park – Structural Statement**

**30110779-43**

Dear Jake,

Arcadis Australia Pacific Pty Ltd (Arcadis) was engaged by oOh! Media on behalf of Transport for New South Wales to inspect and provide an appraisal of the structural condition and adequacy of the advertising signage structure located on the roof of the pedestrian bridge over Cowpasture Road, Bossley Park.

The signage structure is commonly referred to as a double sided front lit 'Supersite', having a nominal display size of 12.660m long x 3.350m high – as depicted in the photograph below.



*Figure 1 – General view of advertising signage structure*

Arcadis visited the site on Wednesday 21<sup>st</sup> June 2023 to undertake a detailed visual inspection of the advertising structure from all readily accessible areas. During this visit, information was recorded regarding the condition of the structure, supporting elements, protective surfacing, and other relevant material with respect to its performance and safety.

Whilst this appraisal is based on a detailed visual inspection of the structure, we do not purport to have discovered or seen every hidden defect or structural condition in existence. The inspection has been made without the removal of any parts of the structure, fixtures and fittings and has been limited to areas where reasonable and safe access was available.

Furthermore, Arcadis has assumed that the existing signage structure has been designed and constructed in accordance with relevant Australian codes/standards and certified as being structurally adequate.

Our inspection review concluded that the advertising signage structure is in a satisfactory condition and should continue to perform as per the original design intent.

Arcadis would recommend that the signage structure be re-inspected every three (3) years from the date of this correspondence. This ongoing inspection regime, and regular maintenance requirements will ensure structural viability for the 15 year period of operation.

Trusting the above satisfies your current requirements.

Yours sincerely

A handwritten signature in black ink, appearing to read 'Chris Slater', with a stylized flourish at the end.

Chris Slater  
Senior Engineer  
02 8907 3942 / 0410 630 972