



Ref: 23041-006-I

14th December 2023

Attention: Daya Perez

MN Builders
Level 2, 66 Wentworth Ave
SURREY HILLS NSW 2010

Dear Daya

**Subject: 149-163 Milton St Ashbury
Proposed Swimming Pool**

ABC Consultants have reviewed the location of the proposed swimming pool for the above development. It is proposed that the swimming pool will sit above the proposed ground floor slab. The ground floor slab has been detailed with a 450 thick slab, sufficient to take the pool in its proposed location.

If you have any queries in regard to any of the above please contact the undersigned at your convenience.

Yours faithfully,

Andrew Castle
Director
BE(Hons), MIEAust, CPEng, NPER-3