



NOTES

1. Depth will vary to maintain the consistent 4.8% slope of pipe from inlet to outlet
2. Backfill and pipe bedding will meet AS/NZS 3500.3 Plumbing and Drainage - Stormwater drainage
3. If trench section is deeper than 1500mm, then benching must be carried out to achieve a temporary batter slope no deeper than 1H:1V and with max individual bench heights of 1500mm

DRAWING

Stormwater Trench Cross Section

PROJECT

24018ES Village Green Stormwater Repairs



REV	DATE	DESCRIPTION
0	10/07/24	Original for DA
DESIGNED BY K. O'Sullivan		CHECKED BY E. Diver
SCALE NTS		FILE NAME 24018ES Village Green
SHEET 1/1		SWRepairs.dwg