











PIERED CONCRETE CONCOURSE (up to 600 WIDE) FOR FILL SITE OR WHERE FILL IS USED

## **CONCRETE CONCOURSE DETAILS**

SCALE 1:20

## NOTES:

## RE: SL 82 MESH PLUS N12 EXTRA BARS IN 600 WIDE HARVEST POOLS CONCOURSE SLAB

In lieu of N12 bars throughout, the following mesh specification can be used:

- 1. SL82 mesh may be used in the 600 wide Concourse Slab around the pool shell
- 2. Please also add an N12 bar alongside the shell (inner edge of Concourse) and lapped 500 where required
- 3. Please add an N12 bar to the outer edge and lapped 500 where required
- 4. Provide an N12 L-Bar at the corners 500 legs
- 5. Reinforce around the Skimmer as per the Harvest Concourse Standard drawing

This will be satisfactory for the 600 wide Concourse typically and is applicable for use in Class S, M and Class 3 (Acid Sulphate ) soils.

## GENERAL:

- 1. APPLIES TO ALL IN-GROUND STANDARD, SPA AND LAP POOLS MANUFACTURED BY HARVEST POOLS
- 2. REFER TO MANUFACTURING AND INSTALLATION DETAILS ON STANDARD HARVEST SPECIFICATION
- 3. BACK FILL 1:8 CEMENT/SAND
- 4. CONCRETE N25
- 5. CONCOURSE TO BE CAST ON FIRM NATURAL OR COMPACTED FOUNDATION
- 6. LAP ALL BARS 600mm MIN. FULL PERIMETER PAST SKIMMER AND AT CORNERS



MIEAust MEngSc CPEng NER CHARTERED PROFESSIONAL ENGINEER MEMBER No. 174326

	Barga	) alli	Р
В	REVISED	ВВ	01/11/2
^	CONSTRUCTION ISSUE		0 1/03/2

CONSULTING CIVIL & STRUCTURAL ENGINEERS ACN 108 249 485 37A NEWMAN AVE. BLUEYS BEACH 2428 Ph. 6552 9030

Email: brett@bargallie.com Mobile: 0412 088 416

	Drawn	Designed	Approved		Revision Date	
	WR	ВВ	BB		SEPT 2016	
	Project No. 16059		Scale			
			AS SHOWN			
	Project					

HARVEST POOLS PTY LTD

CONCRETE CONCOURSE AND SKIMMER DETAILS

S101 B N-B9187.00