

30 April 2024

Reg. No.: FC24-08

ICG CONSTRUCTION GROUP - WAGGA WAGGA, NSW

Attention: MICHAEL MARTIN

Dear Sir,

**FILL CERTIFICATION COVER LETTER - PROPOSED PUMP HOUSE & TANKS- MERRITTS MOUNTAIN HOUSE -  
THREDBO, NSW**

This cover letter is to confirm that placement of fill at the above site across the proposed has been tested by Aitken Rowe Testing Laboratories Pty Ltd in accordance with AS 3798-2007 "Guidelines on earthworks for commercial and residential developments" under level 1 supervision between 19 March and 29 April 2024.

**NB: Final Proof Roll partially failed through the centre of the pad. As it is standard practice to return and perform Proof Roll prior to construction commencement (if delayed for a substantial period), we would suggest that the final assessment of the pad be done at that time.**

<input checked="" type="checkbox"/>	TOPSOIL/UNSUITABLE MATERIAL REMOVED	<input type="checkbox"/>	N/A
<input checked="" type="checkbox"/>	INITIAL PROOF ROLL PASSED/FOUNDATION INSPECTION		
<input checked="" type="checkbox"/>	INTERMEDIATE PROOF ROLLS PASSED	<input type="checkbox"/>	N/A
<input checked="" type="checkbox"/>	FILL MATERIAL SUITABLE		
<input checked="" type="checkbox"/>	FILL LAYERS ACHIEVED MINIMUM RELATIVE COMPACTION		
<input type="checkbox"/>	FINAL PROOF ROLL PASSED		<b>*NOTE COMMENTS ABOVE</b>

A detailed report including field and laboratory testing results and compliance with AS 3798-2007 and site-specific requirements will be provided outlining fill compliance.

Should you have any queries, please do contact us.

Yours Faithfully,



**Peter Forbes-Taber**  
Geotechnical Engineer