



Appendix 1 – Draft Fire Safety Schedule

The following table is a list of the required fire safety measures within the proposed building. These measures may be subject to further change pending the outcomes of the final Fire Safety Engineering Report. Fire Safety Schedule shall be finalised at CC stage.

It is recommended that the Draft Fire Safety Schedule is issued to the relevant contractors / consultants for review to confirm the 'Proposed' Fire Safety Measures are consistent with the measures proposed as part of their scope of works. Fire Safety Measures which are incorrectly listed or omitted will create an inconsistency with the Construction Certificate (CC) and Occupation Certificate (OC) schedules and may require an amended CC to be issued by the Principal Certifier.

Statutory Fire Safety Measure	Standard of Performance	Proposed
Exit Signs	BCA Clauses E4D5, NSW E4D6 & E4D8 AS 2293.1 – 2018	✓
Paths of Travel	EP&A Regulation Clause 109	✓
Portable Fire Extinguishers	BCA Clause E1D14 AS 2444 – 2001	✓
Fire Engineered Performance Solutions: TBC	TBC	TBC