



REPORT R240378R1

Revision 1

Road & Rail Traffic Noise Assessment
Proposed Residential Development
80 - 82 Showground Road, Gosford

PREPARED FOR:
DTA Architects

7 March 2025



Road & Rail Noise Assessment

Proposed Residential Development

80 - 82 Showground Road, Gosford

PREPARED BY:

Rodney Stevens Acoustics Pty Ltd

Telephone: 61 2 9943 5057 Facsimile 61 2 9475 1019
Email: info@rodneystevensacoustics.com.au
Web: www.rodneystevensacoustics.com.au

DISCLAIMER

Reports produced by Rodney Stevens Acoustics Pty Ltd are prepared for a particular Client's objective and are based on a specific scope, conditions and limitations, as agreed between Rodney Stevens Acoustics and the Client. Information and/or report(s) prepared by Rodney Stevens Acoustics may not be suitable for uses other than the original intended objective. No parties other than the Client should use any information and/or report(s) without first conferring with Rodney Stevens Acoustics.

The information and/or report(s) prepared by Rodney Stevens Acoustics should not be reproduced, presented or reviewed except in full. Before passing on to a third party any information and/or report(s) prepared by Rodney Stevens Acoustics, the Client is to fully inform the third party of the objective and scope and any limitations and conditions, including any other relevant information which applies to the material prepared by Rodney Stevens Acoustics. It is the responsibility of any third party to confirm whether information and/or report(s) prepared for others by Rodney Stevens Acoustics are suitable for their specific objectives.

DOCUMENT CONTROL

Reference	Status	Date	Prepared	Checked	Authorised
R240378R1	Revision 0	9 December 2024	Dani Awad	Desmond Raymond	Desmond Raymond
R240378R1	Revision 1	7 March 2025	Dani Awad	Desmond Raymond	Desmond Raymond

TABLE OF CONTENTS

1	INTRODUCTION	4
2	PROPOSED DEVELOPMENT	4
2.1	Development Site	4
2.2	Proposed Development	5
3	BASELINE NOISE SURVEY	5
3.1	Unattended Noise Monitoring	5
3.2	Data Processing	5
3.1	Noise Intrusion (State Environmental Planning Policy (Transport and Infrastructure) 2021)	6
4	NOISE GUIDELINES AND CRITERIA	6
4.1	Road & Rail Noise Criteria	6
4.2	Rail Vibration Criteria	6
4.3	State Environmental Planning Policy (Transport and Infrastructure) 2021	7
4.4	Operational Noise Project Trigger Noise Levels	8
4.4.1	Intrusiveness Noise Levels	8
4.4.2	Amenity Noise Levels	8
4.4.3	Area Classification	8
4.4.4	Project Specific Trigger Noise Levels	9
5	NOISE IMPACT ASSESSMENT	9
5.1	Traffic Noise Assessment	9
5.2	Recommended Noise Control Treatment	10
5.3	Glazing	10
5.4	External Walls	12
5.4.1	Masonry Walls	12
5.4.2	Detailing	12
5.5	Mechanical Plant Noise Assessment	12
5.6	Rail Vibration Assessment	13
6	CONCLUSION	13
	APPENDIX A – ACOUSTIC TERMINOLOGY	14
	APPENDIX B – LOGGER GRAPHS	17
	APPENDIX C – CALIBRATION CERTIFICATE	25
	APPENDIX D – ARCHITECTURAL DRAWINGS	27

Table 3-1	Measured Baseline Noise Levels Corresponding to Defined NPfI Periods	5
Table 3-2	Traffic Noise Levels Corresponding to Defined SEPP 2021 Periods	6
Table 4-1	Acceptable vibration dose values for intermittent vibration in residences ($\text{m/s}^{1.75}$)	7
Table 4-2	DP&I Interim Guideline Noise Criteria	7
Table 4-3	Operational Project Trigger Noise Levels	9
Table 5-1	Minimum Acoustic Rating (R_w) Required for glazing elements	11
Table 5-2	Glass Thickness Guideline	11
Figure 2-1	Site Location	4

1 INTRODUCTION

Rodney Stevens Acoustics Pty Ltd (RSA) has been engaged by DTA Architects to conduct a road and rail noise impact assessment for development application (DA) lodgment of the Proposed Residential Development at 80 - 82 Showground Road, Gosford.

This report addresses the road traffic noise impacts from Showground Road and the Central Coast North/Newcastle rail corridor on the amenity of the proposed residential development.

This assessment is to form part of the supporting documentation for the DA submission to Central Coast Council. Specific acoustic terminology is used in this report. An explanation of common acoustic terms is provided in Appendix A.

2 PROPOSED DEVELOPMENT

2.1 Development Site

The proposed development is located at 80 - 82 Showground Road, Gosford. The site is bounded by adjoining residential receivers to the north and west with Gosford Hospital Parking to the south. Figure 2-1 shows an aerial image of the site area and the surrounding environment.

Figure 2-1 Site Location



Aerial image courtesy of Google Maps © 2025

2.2 Proposed Development

The proposal is to construct a 6 level residential development with 1 level of basement parking. The floor plans of the proposed residential development are presented in Appendix D.

3 BASELINE NOISE SURVEY

3.1 Unattended Noise Monitoring

In order to characterise the existing acoustical environment of the area, unattended noise monitoring was conducted between Thursday 21st November and Thursday 28th November 2024 at the logging locations shown in Figure 2-1. Two noise loggers were set up on site. The first logger was located at the front boundary of the site overlooking Showground Road and the rail corridor. This location is representative of the traffic noise levels that the site will be exposed to.

The second logger was located at the rear yard of the site, noise monitoring at this location is representative of the acoustic environment of the site.

Logger locations were selected with consideration to other noise sources which may influence readings, security issues for noise monitoring equipment and gaining permission for access from other landowners.

Instrumentation for the survey comprised of 2 RION NL-42EX environmental noise loggers (serial numbers 133010 and 422907) fitted with microphone windshields. Calibration of the loggers was checked prior to and following measurements. Drift in calibration did not exceed ± 0.5 dB(A). All equipment carried appropriate and current NATA (or manufacturer) calibration certificates.

The logger determines L_{A1} , L_{A10} , L_{A90} and L_{Aeq} levels of the ambient noise. L_{A1} , L_{A10} , L_{A90} are the levels exceeded for 1%, 10% and 90% of the sample time respectively (see Glossary for definitions in Appendix A). Detailed results at the monitoring location are presented in graphical format in Appendix B. The graphs show measured values of L_{A1} , L_{A10} , L_{A90} and L_{Aeq} for each 15-minute monitoring period.

3.2 Data Processing

In order to assess noise emission from the Proposed Residential Development, the data obtained from the noise logger has been processed in accordance with the procedures contained in the NSW Environmental Protection Authority's (EPA) *Noise Policy for Industry* (NPfI, 2017) to establish representative noise levels that can be expected in the residential vicinity of the site. The monitored baseline noise levels are detailed in Table 3-1.

Table 3-1 Measured Baseline Noise Levels Corresponding to Defined NPfI Periods

Location	Measurement Descriptor	Measured Noise Level – dB(A) re 20 μ Pa		
		Daytime 7 am - 6 pm	Evening 6 pm – 10 pm	Night-time 10 pm – 7 am
Logger 2	L_{Aeq}	54	57	48
	RBL (Background)	46	42	37

Notes: All values expressed as dB(A) and rounded to nearest 1 dB(A);

L_{Aeq} Equivalent continuous (energy average) A-weighted sound pressure level. It is defined as the steady sound level that contains the same amount of acoustic energy as the corresponding time-varying sound.

L_{A90} Noise level present for 90% of time (background level). The average minimum background sound level (in the absence of the source under consideration).

3.1 Noise Intrusion (State Environmental Planning Policy (Transport and Infrastructure) 2021)

To assess noise intrusion into the Proposed Residential Development, the data obtained from the first logger location has been processed to establish representative ambient noise levels at the facades most exposed to Showground Road and the rail corridor.

The time periods used for this assessment are as defined in the State Environmental Planning Policy (Transport and Infrastructure) 2021 and the Development near Rail Corridors and Busy Roads Interim Guideline. Results are presented below in Table 3-2.

Table 3-2 Traffic Noise Levels Corresponding to Defined SEPP 2021 Periods

Location	Period	External Noise Levels dB(A)
Approximately 10m from Showground Road	Day Time 7:00 am - 10:00 pm	L _{Aeq} (15hour) 61
	Night Time 10:00 pm - 7:00 am	L _{Aeq} (9hour) 57

4 NOISE GUIDELINES AND CRITERIA

4.1 Road & Rail Noise Criteria

The determination of an acceptable level of traffic noise impacting the internal residential spaces requires consideration of the activities carried out within the space and the degree to which noise will interfere with those activities.

As sleep is the activity most affected by traffic noise, bedrooms are considered to be the most sensitive internal living areas. Higher levels of noise are acceptable in living areas without interfering with activities such as reading, listening to the television etc. Noise levels in utility spaces such as kitchens, bathrooms, laundries etc. can be higher.

4.2 Rail Vibration Criteria

Section 3.6.3 of the NSW Department of Planning and Infrastructure's "*Development near Rail Corridors and Busy Roads - Interim Guideline*" requires that intermittent vibration emitted by trains should comply with the criteria in the EPA's document Assessing Vibration: a technical guideline.

Table 2.4 of the "*Assessing Vibration guidelines*" sets out the following acceptable vibration dose values for residences affected by intermittent vibration:

Table 4-1 Acceptable vibration dose values for intermittent vibration in residences (m/s^{1.75})

Location	Period	Preferred VDV	Maximum VDV
Residences	Day (7am-10pm)	0.20	0.40
	Night (10pm-7am)	0.13	0.26

4.3 State Environmental Planning Policy (Transport and Infrastructure) 2021

The NSW Government's State Environmental Planning Policy (Transport and Infrastructure) 2021 (SEPP (Transport and Infrastructure) 2021) was introduced to facilitate the delivery of infrastructure across the State by improving regulatory certainty and efficiency. The NSW Department of Planning and Infrastructure's "Development near Rail Corridors and Busy Roads - Interim Guideline" (the DP&I Guideline) of December 2008 provides noise criteria for residential and non-residential buildings. These criteria are summarised in Table 4-2.

Table 4-2 DP&I Interim Guideline Noise Criteria

Type of occupancy	Noise Level dB(A)	Applicable time period
Sleeping areas (bedroom)	35	Night 10 pm to 7 am
Other habitable rooms (excl. garages, kitchens, bathrooms & hallways)	40	At any time

Note 1: Airborne noise is calculated as $L_{Aeq(15\text{hour})}$ daytime and $L_{Aeq(9\text{hour})}$ night-time

The following guidance is also provided in the DP&I Guideline:

"These criteria apply to all forms of residential buildings as well as aged care and nursing home facilities. For some residential buildings, the applicants may wish to apply more stringent design goals in response to market demand for a higher quality living environment."

The night-time "sleeping areas" criterion is 5 dB(A) more stringent than the "living areas" criteria to promote passive acoustic design principles. For example, designing the building such that sleeping areas are less exposed to road or rail noise than living areas may result in less onerous requirements for glazing, wall construction and acoustic seals. If internal noise levels with windows or doors open exceed the criteria by more than 10 dB(A), the design of the ventilation for these rooms should be such that occupants can leave windows closed, if they so desire, and also to meet the ventilation requirements of the Building Code of Australia."

The noise criteria presented in Section 4.3 and in Table 4-2 apply to a 'windows closed condition'. Standard window glazing of a building will typically attenuate noise ingress by 20 dB(A) with windows closed and 10 dB(A) with windows open (allowing for natural ventilation). Accordingly, the external noise threshold above which a

dwelling will require mechanical ventilation is an $L_{Aeq(9\text{hour})}$ 55 dB(A) for bedrooms and $L_{Aeq(15\text{hour})}$ 60 dB(A) for other areas.

Where windows must be kept closed, the adopted ventilation systems must meet the requirements of the Building Code of Australia and Australian Standard 1668 – The use of ventilation and air conditioning in buildings.

4.4 Operational Noise Project Trigger Noise Levels

Responsibility for the control of noise emissions in New South Wales is vested in Local Government and the EPA. The EPA oversees the Noise Policy for Industry (NPfI) October 2017 which provides a framework and process for deriving project trigger noise level. The NPfI project noise levels for industrial noise sources have two (2) components:

- Controlling the intrusive noise impacts for residents and other sensitive receivers in the short term; and
- Maintaining noise level amenity for particular land uses for residents and sensitive receivers in other land uses.

4.4.1 Intrusiveness Noise Levels

For assessing intrusiveness, the background noise generally needs to be measured. The intrusiveness noise level essentially means that the equivalent continuous noise level (L_{Aeq}) of the source should not be more than 5 dB(A) above the measured Rated Background Level (RBL), over any 15 minute period.

4.4.2 Amenity Noise Levels

The amenity noise level is based on land use and associated activities (and their sensitivity to noise emission). The cumulative effect of noise from industrial sources needs to be considered in assessing the impact. The noise levels relate only to other industrial-type noise sources and do not include road, rail or community noise. The existing noise level from industry is measured.

If it approaches the project trigger noise level value, then noise levels from new industrial-type noise sources, (including air-conditioning mechanical plant) need to be designed so that the cumulative effect does not produce total noise levels that would significantly exceed the project trigger noise level.

4.4.3 Area Classification

The NPfI characterises the “Urban” noise environment as an area with an acoustical environment that:

- is dominated by ‘urban hum’ or industrial source noise,
- where urban hum means the aggregate sound of many unidentifiable, mostly traffic and/or industrial related sound sources
- has through-traffic with characteristically heavy and continuous traffic flows during peak periods
- is near commercial districts or industrial districts
- has any combination of the above.

The area surrounding the proposed development falls under the “Urban” area classification.

4.4.4 Project Specific Trigger Noise Levels

Having defined the area type, the processed results of the unattended noise monitoring have been used to determine project specific project trigger noise levels. The intrusive and amenity project trigger noise levels for nearby residential premises are presented in Table 4-3. These project trigger noise levels are nominated for the purpose of assessing potential noise impacts from the proposed development.

In this case, the ambient noise environment is not controlled by industrial noise sources and therefore the project amenity noise levels are assigned as per Table 2.2 of the NPfI (Recommended Amenity Noise Levels) and standardised as per Section 2.2 of the NPfI. For each assessment period, the lower (i.e. the more stringent) of the amenity or intrusive project trigger noise levels are adopted. These are shown in bold text in Table 4-3.

Table 4-3 Operational Project Trigger Noise Levels

Receiver	Time of Day	ANL ¹ L _{Aeq}	Measured		Project Trigger Noise Levels	
			RBL ² L _{A90} (15min)	Existing L _{Aeq} (Period)	Intrusive L _{Aeq} (15min)	Amenity L _{Aeq} (15min)
Residential	Day	60	46	54	51	63
	Evening	50	42	57	47	53
	Night	45	37	48	42	48

Note 1: ANL = "Amenity Noise Level" for residences in Urban Areas.

Note 2: RBL = "Rating Background Level".

5 NOISE IMPACT ASSESSMENT

5.1 Traffic Noise Assessment

In order to ascertain the existing traffic noise levels from Showground Road and the rail corridor, the measured noise logger data was processed in accordance to the NSW Department of Planning and Infrastructure's "Development near Rail Corridors and Busy Roads - Interim Guideline" assessment time periods as shown in Table 3-2.

The final façade noise levels were predicted for each time period taking into account the distance attenuation from each respective source, virtual source, façade's orientation and any barrier effects.

The required noise reduction via the building façade for each respective room for each time period will be compared to determine the appropriate design criteria levels.

It is typically accepted that an open window (fractionally open to meet ventilation requirements) results in an attenuation of external noise by 10 dB. This reduction has been used to predict the room noise level in the window open condition.

5.2 Recommended Noise Control Treatment

The calculation procedure establishes the required noise insulation performance of each surface component such that the internal noise level is achieved whilst an equal contribution of traffic noise energy is distributed across each component. Building envelope components with a greater surface area must therefore offer increased noise insulation performance.

The recommended acoustic treatment is based on the following floor finishes:

- Bedrooms: Carpet and underlay
- Living Room Hard Flooring
- Kitchen/Wet Areas: Tiles

The acoustic requirements shown in this report may increase further where the bedroom floor finishes are tiled or timber.

All recommendations must be checked by others to ensure compliance with other non-acoustic requirements that Council or other authority may impose (e.g. Thermal requirements for BASIX compliance).

5.3 Glazing

The R_w rating required for each window will vary from room to room. Recommendations for windows also apply to any other item of glazing located on the external facade of the building in a habitable room unless otherwise stated.

Note that the R_w rating is required for the complete glazing and frame assembly. The minimum glazing thicknesses will not necessarily meet the required R_w rating without an appropriate frame system. It will be therefore necessary to provide a window glass and frame system having a laboratory tested acoustic performance meeting the requirements below

The window systems must be tested in accordance with both of the following:

- Australian Window Association Industry Code of Practice Window and Door – Method of Acoustic Testing; and
- AS 1191 Acoustics – Method for laboratory measurement of airborne sound insulation of building elements.

It is necessary to submit such Laboratory certification for the proposed glazing systems (i.e. windows and framing systems) (e.g. NAL or CSIRO) for approval by RSA prior to ordering or commitment.

The entire frame associated with the glazing must be sealed into the structural opening using acoustic mastics and backer rods. Normal weather proofing details do not necessarily provide the full acoustic insulation potential of the window system. The manufacturers' installation instructions for the correct acoustic sealing of the frame must be followed.

It is possible that structural demands for wind loading or fire rating or the like may require more substantial glass and framing assemblies than nominated above. Where this is the case the acoustic requirements must clearly be superseded by the structural or fire rating demands.

It must be noted that the presented glazing recommendations, in addition to traffic noise, consider the following site specific potential noise sources.

- Potential noise intrusion from the adjoining carpark premises.

Table 5-1 presents the minimum recommended R_w (weighted noise reduction) for glazing elements. Please refer to the color references in Table 5-1 below and Appendix D for glazing layout.

Table 5-1 Minimum Acoustic Rating (R_w) Required for glazing elements

Location	Glazing Type	Minimum Glazing R_w Rating
Living Rooms (BLUE - Appendix E)	Windows	R_w 32
	Sliding Doors	R_w 32
Bedrooms (BLUE - Appendix E)	Windows	R_w 34
	Sliding Doors	R_w 34
Living Rooms (ORANGE- Appendix E)	Windows	R_w 28
	Sliding Doors	R_w 28
Bedrooms (ORANGE- Appendix E)	Windows	R_w 32
	Sliding Doors	R_w 32

The above recommended glazing systems consist of glass pane, frame and seals. Care should be taken when selecting the system to ensure the acoustic rating (R_w) is verified through laboratory tested data. As a guide, the following table presents the R_w ratings of different glass thicknesses, please note that these are shown as a guide only, all final glazing system selections must comply with the requirements in Section 5.3.

Table 5-2 Glass Thickness Guideline

Glass Thickness	R_w Rating (Glass Pane Only)
5mm	26
6mm	28
6.38mm Laminated	32

8.38 Laminated	34
10.38 Laminated	36
12.38 Laminated	37
4mm – 50mm Airgap – 6mm Double Glazed	41

5.4 External Walls

The following wall construction recommendations are given as guidance only. The client is responsible for selecting adequate systems in order to achieve the recommended acoustic ratings.

5.4.1 Masonry Walls

It is understood that the existing external walls are rendered masonry. The masonry external walls will be required to achieve a rating of R_w 50. This R_w rating is generally achieved with a standard construction with insulation. No further acoustic requirements are needed

5.4.2 Detailing

Note that well-detailed construction and careful installation is needed to achieve the required R_w acoustic ratings. All gaps are to be minimised and fully sealed with an acoustic rated sealant, such as FireBan One by Bostik or Sikaflex Pro 2HP by Sika.

5.5 Mechanical Plant Noise Assessment

A specific mechanical plant selection has not been supplied at this stage. It is anticipated that the building will be serviced by typical mechanical ventilation/air conditioning equipment.

It is likely that the criteria set out in Table 4-3 will be met through the use of conventional noise control methods (e.g. selection of equipment on the basis of quiet operation and, where necessary, providing enclosures, localised barriers, silencers and lined ductwork).

An appropriately qualified acoustic consultant should review the mechanical plant associated with the development at the detailed design stage when final plant selections have been made.

5.6 Rail Vibration Assessment

The passage of trains along a railway corridor induces ground vibrations. These vibrations from rail movements can be perceived from floor vibration. The body's perception of vibration is frequency dependent thus a weighting filter is used to correct the measured vibration levels. The intermittent train vibrations are accumulated using the Vibration Dose Value (VDV). Note that the vibration dose value may also be evaluated by using the estimated vibration dose value (eVDV) provided the crest factor of the measured vibration is less than 6.

In accordance with NSW Department of Planning and Infrastructure's "*Development near Rail Corridors and Busy Roads - Interim Guideline*", a rail vibration impact assessment is not required for the site due to the distance of the rail line being more than 25-metres from the site boundary.

6 CONCLUSION

Rodney Stevens Acoustics has conducted a noise impact assessment of the Proposed Residential Development at 80 - 82 Showground Road, Gosford. The noise impact assessment has assessed the noise generation and intrusion of the site and compared it with the noise criteria required by in Central Coast Council and other relevant standards.

A noise survey has been conducted and the processed data has been used to determine traffic noise from Showground Road and the rail corridor at the project site.

Based on the noise impact study conducted, the proposed development is assessed to comply with the SEPP (Transport and Infrastructure) 2021 noise criteria with recommendations from this report. It is therefore recommended that planning approval be granted for the proposed development on the basis of acoustics.

Prepared by:



Dani Awad

Acoustic Consultant

Approved by:



Desmond Raymond


Director

Appendix A – Acoustic Terminology

A-weighted sound pressure	The human ear is not equally sensitive to sound at different frequencies. People are more sensitive to sound in the range of 1 to 4 kHz (1000 – 4000 vibrations per second) and less sensitive to lower and higher frequency sound. During noise measurement an electronic ' <i>A-weighting</i> ' frequency filter is applied to the measured sound level <i>dB(A)</i> to account for these sensitivities. Other frequency weightings (B, C and D) are less commonly used. Sound measured without a filter is denoted as linear weighted <i>dB(linear)</i> .
Ambient noise	The total noise in a given situation, inclusive of all noise source contributions in the near and far field.
Community annoyance	Includes noise annoyance due to: character of the noise (e.g. sound pressure level, tonality, impulsiveness, low-frequency content) character of the environment (e.g. very quiet suburban, suburban, urban, near industry) miscellaneous circumstances (e.g. noise avoidance possibilities, cognitive noise, unpleasant associations) human activity being interrupted (e.g. sleep, communicating, reading, working, listening to radio/TV, recreation).
Compliance	The process of checking that source noise levels meet with the noise limits in a statutory context.
Cumulative noise level	The total level of noise from all sources.
Extraneous noise	Noise resulting from activities that are not typical to the area. Atypical activities may include construction, and traffic generated by holiday periods and by special events such as concerts or sporting events. Normal daily traffic is not considered to be extraneous.
Feasible and reasonable measures	Feasibility relates to engineering considerations and what is practical to build; reasonableness relates to the application of judgement in arriving at a decision, taking into account the following factors: Noise mitigation benefits (amount of noise reduction provided, number of people protected). Cost of mitigation (cost of mitigation versus benefit provided). Community views (aesthetic impacts and community wishes). Noise levels for affected land uses (existing and future levels, and changes in noise levels).
Impulsiveness	Impulsive noise is noise with a high peak of short duration or a sequence of these peaks. Impulsive noise is also considered annoying.

Low frequency	Noise containing major components in the low-frequency range (20 to 250 Hz) of the frequency spectrum.
Noise criteria	The general set of non-mandatory noise levels for protecting against intrusive noise (for example, background noise plus 5 dB) and loss of amenity (e.g. noise levels for various land use).
Noise level (goal)	A noise level that should be adopted for planning purposes as the highest acceptable noise level for the specific area, land use and time of day.
Noise limits	Enforceable noise levels that appear in conditions on consents and licences. The noise limits are based on achievable noise levels, which the proponent has predicted can be met during the environmental assessment. Exceedance of the noise limits can result in the requirement for either the development of noise management plans or legal action.
Performance-based goals	Goals specified in terms of the outcomes/performance to be achieved, but not in terms of the means of achieving them.
Rating Background Level (RBL)	Rating background noise level (RBL) – the overall single-figure background level representing each assessment period (day/evening/night) over the whole monitoring period (as opposed to over each 24-hour period used for the assessment background level). The rating background level is the median L_{A90} noise level measured over all day, evening and night time monitoring periods.
Receptor	The noise-sensitive land use at which noise from a development can be heard.
Sleep disturbance	Awakenings and disturbance of sleep stages.
Sound and decibels (dB)	Sound (or noise) is caused by minute changes in atmospheric pressure that are detected by the human ear. The ratio between the quietest noise audible and that which should cause permanent hearing damage is a million times the change in sound pressure. To simplify this range the sound pressures are logarithmically converted to decibels from a reference level of 2×10^{-5} Pa.

The picture below indicates typical noise levels from common noise sources.



dB is the abbreviation for decibel – a unit of sound measurement. It is equivalent to 10 times the logarithm (to base 10) of the ratio of a given sound pressure to a reference pressure.

**Sound power
Level (SWL)**

The sound power level of a noise source is the sound energy emitted by the source. Notated as SWL, sound power levels are typically presented in $dB(A)$.


**Sound Pressure
Level (SPL)**

The level of noise, usually expressed as SPL in $dB(A)$, as measured by a standard sound level meter with a pressure microphone. The sound pressure level in $dB(A)$ gives a close indication of the subjective loudness of the noise.

**Statistic noise
levels**

Noise levels varying over time (e.g. community noise, traffic noise, construction noise) are described in terms of the statistical exceedance level.

A hypothetical example of A weighted noise levels over a 15 minute measurement period is indicated in the following figure:



Key descriptors:

L_{Amax} Maximum recorded noise level.

L_{A1} The noise level exceeded for 1% of the 15 minute interval.

L_{A10} Noise level present for 10% of the 15 minute interval. Commonly referred to the average maximum noise level.

L_{Aeq} Equivalent continuous (energy average) A-weighted sound pressure level. It is defined as the steady sound level that contains the same amount of acoustic energy as the corresponding time-varying sound.

L_{A90} Noise level exceeded for 90% of time (background level). The average minimum background sound level (in the absence of the source under consideration).



Threshold

The lowest sound pressure level that produces a detectable response (in an instrument/person).


Tonality

Tonal noise contains one or more prominent tones (and characterised by a distinct frequency components) and is considered more annoying. A 2 to 5 $dB(A)$ penalty is typically applied to noise sources with tonal characteristics


Appendix B – Logger Graphs





Traffic
80-82 Showground Road, Gosford
Saturday 23/11/2024




Traffic
80-82 Showground Road, Gosford
Sunday 24/11/2024








Traffic
80-82 Showground Road, Gosford
Wednesday 27/11/2024




Traffic
80-82 Showground Road, Gosford
Thursday 28/11/2024










Ambient
80-82 Showground Road, Gosford
Saturday 23/11/2024



Ambient
80-82 Showground Road, Gosford
Sunday 24/11/2024







Appendix C – Calibration Certificate



**Acoustic
Research
Labs Pty Ltd**

Unit 36/14 Loyalty Rd
North Rocks NSW AUSTRALIA 2151
Ph: +61 2 9484 0800 A.B.N. 65 160 399 119
www.acousticresearch.com.au

Sound Level Meter

IEC 61672-3:2013

Calibration Certificate

Calibration Number C23562

Client Details	Rodney Stevens Acoustics Pty Ltd PO Box 522 Wahroonga NSW 2076
Equipment Tested/ Model Number :	NL-42EX
Instrument Serial Number :	00133010
Microphone Serial Number :	196551
Pre-amplifier Serial Number :	74638
Firmware Version :	1.3
Pre-Test Atmospheric Conditions	Post-Test Atmospheric Conditions
Ambient Temperature : 20°C	Ambient Temperature : 21.6°C
Relative Humidity : 49.4%	Relative Humidity : 48%
Barometric Pressure : 101.9kPa	Barometric Pressure : 101.8kPa
Calibration Technician : Ken Williams	Secondary Check: Megan Williams
Calibration Date : 5 Aug 2023	Report Issue Date : 9 Aug 2023
Approved Signatory :	Ken Williams

Clause and Characteristic Tested	Result	Clause and Characteristic Tested	Result
12: Acoustical Sig. tests of a frequency weighting	Pass	17: Level linearity incl. the level range control	N/A
13: Electrical Sig. tests of frequency weightings	Pass	18: Toneburst response	Pass
14: Frequency and time weightings at 1 kHz	Pass	19: C Weighted Peak Sound Level	Pass
15: Long Term Stability	Pass	20: Overload Indication	Pass
16: Level linearity on the reference level range	Pass	21: High Level Stability	Pass

The sound level meter submitted for testing has successfully completed the class 2 periodic tests of IEC 61672-3:2013, for the environmental conditions under which the tests were performed.

However, no general statement or conclusion can be made about conformance of the sound level meter to the full requirements of IEC 61672-1:2013 because evidence was not publicly available, from an independent testing organisation responsible for pattern approvals, to demonstrate that the model of sound level meter fully conformed to the requirements in IEC 61672-1:2013 and because the periodic tests of IEC 61672-3:2013 cover only a limited subset of the specifications in IEC 61672-1:2013.

Uncertainties of Measurement -			
Acoustic Tests		Environmental Conditions	
125Hz	±0.13dB	Temperature	±0.1°C
1kHz	±0.13dB	Relative Humidity	±1.9%
8kHz	±0.14dB	Barometric Pressure	±0.014kPa
Electrical Tests	±0.13dB		

All uncertainties are derived at the 95% confidence level with a coverage factor of 2.



This calibration certificate is to be read in conjunction with the calibration test report.

Acoustic Research Labs Pty Ltd is NATA Accredited Laboratory Number 14172.
Accredited for compliance with ISO/IEC 17025 - Calibration.

The results of the tests, calibrations and/or measurements included in this document are traceable to SI units.

NATA is a signatory to the ILAC Mutual Recognition Arrangement for the mutual recognition of the equivalence of testing, medical testing, calibration and inspection reports.

PAGE 1 OF 1




**Acoustic
Research
Labs Pty Ltd**

Unit 36/14 Loyalty Rd
North Rocks NSW AUSTRALIA 2151
Ph: +61 2 9484 0800 A.B.N. 65 160 399 119
www.acousticresearch.com.au

Sound Level Meter IEC 61672-3:2013 Calibration Certificate

Calibration Number C24490

Client Details Rodney Stevens Acoustics Pty Ltd PO Box 522 Wahroonga NSW, 2076	
Equipment Tested/ Model Number : Rion NL-42AEX Instrument Serial Number : 00422907 Microphone Serial Number : 144601 Pre-amplifier Serial Number : 23060 Firmware Version : 1.1	
Pre-Test Atmospheric Conditions Ambient Temperature : 21.2 °C Relative Humidity : 43.2 % Barometric Pressure : 101.55 kPa	Post-Test Atmospheric Conditions Ambient Temperature : 22.9 °C Relative Humidity : 48.7 % Barometric Pressure : 101.41 kPa
Calibration Technician : Shaheen Boaz Calibration Date : 28 Jun 2024	Secondary Check: Cooper Sallway Report Issue Date : 1 Jul 2024
Approved Signatory :  Ken Williams	

Clause and Characteristic Tested	Result	Clause and Characteristic Tested	Result
12: Acoustical Sig. tests of a frequency weighting	Pass	17: Level linearity incl. the level range control	N/A
13: Electrical Sig. tests of frequency weightings	Pass	18: Toneburst response	Pass
14: Frequency and time weightings at 1 kHz	Pass	19: C Weighted Peak Sound Level	Pass
15: Long Term Stability	Pass	20: Overload Indication	Pass
16: Level linearity on the reference level range	Pass	21: High Level Stability	Pass

The sound level meter submitted for testing has successfully completed the class 2 periodic tests of IEC 61672-3:2013, for the environmental conditions under which the tests were performed.

However, no general statement or conclusion can be made about conformance of the sound level meter to the full requirements of IEC 61672-1:2013 because evidence was not publicly available, from an independent testing organisation responsible for pattern approvals, to demonstrate that the model of sound level meter fully conformed to the requirements in IEC 61672-1:2013 and because the periodic tests of IEC 61672-3:2013 cover only a limited subset of the specifications in IEC 61672-1:2013.

Uncertainties of Measurement -			
Acoustic Tests		Environmental Conditions	
125Hz	±0.13 dB	Temperature	±0.1 °C
1kHz	±0.13 dB	Relative Humidity	±1.9 %
8kHz	±0.14 dB	Barometric Pressure	±0.11 kPa
Electrical Tests	±0.13 dB		

All uncertainties are derived at the 95% confidence level with a coverage factor of 2.



This calibration certificate is to be read in conjunction with the calibration test report.

Acoustic Research Labs Pty Ltd is NATA Accredited Laboratory Number 14172.
Accredited for compliance with ISO/IEC 17025 - Calibration.

The results of the tests, calibrations and/or measurements included in this document are traceable to SI units.

NATA is a signatory to the ILAC Mutual Recognition Arrangement for the mutual recognition of the equivalence of testing, medical testing, calibration and inspection reports.

PAGE 1 OF 1

