



REDELEMENT
FIRE SERVICES

PO Box 127 Roselands NSW 2196

Email: sam@redelement.com.au

Phone: 0424 442 567

Address
Date

11 Curtis Rd, Chest Hill
29-Aug-24

Hydrant		System Requirements	
Flow rate	Discharge (kPa)	Flow (l/min)	Pressure (kPa)
0	440	600	150
600	250		
965	150		

