



15:30 Proposed

22 Redan Street Mosman
Solar compliance for 21st June

	APT 1		APT 2		APT 3		APT 4		APT 5		APT 6	
	LIVING	POS	LIVING	POS	LIVING	POS	LIVING	POS	LIVING	POS	LIVING	POS
9.00 - 9.30	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
9.30 - 10.00	0.5	0.5	0	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
10.00 - 10.30	0	0.5	0	0.5	0.5	0.5	0.5	0.5	0	0.5	0.5	0.5
10.30 - 11.00	0	0.5	0	0.5	0.5	0	0.5	0	0.5	0	0.5	0.5
11.00 - 11.30	0	0.5	0	0.5	0	0.5	0	0.5	0	0.5	0	0.5
11.30 - 12.00	0	0.5	0	0.5	0	0.5	0	0.5	0	0.5	0	0.5
12.00 - 12.30	0	0.5	0	0.5	0	0.5	0	0.5	0	0.5	0	0.5
12.30 - 13.00	0.5	0.5	0	0.5	0	0.5	0.5	0.5	0.5	0.5	0.5	0.5
13.00 - 13.30	0.5	0.5	0	0.5	0	0.5	0.5	0.5	0.5	0.5	0.5	0.5
13.30 - 14.00	0.5	0.5	0	0.5	0	0.5	0.5	0.5	0.5	0.5	0.5	0.5
14.00 - 14.30	0.5	0.5	0.5	0.5	0	0.5	0.5	0.5	0.5	0.5	0	0
14.30 - 15.00	0.5	0.5	0.5	0.5	0	0	0.5	0.5	0.5	0.5	0	0
TOTAL HRS	3.5	6	1.5	6	1.5	5.5	4	6	3.5	6	3	5
ADG 2 HOUR	✓	✓		✓	✓	✓	✓	✓	✓	✓	✓	✓
DCP 2 HOUR	✓	✓		✓	✓	✓	✓	✓	✓	✓	✓	✓

KEY

✓

YES CRITERIA ACHIEVED

SOLAR VIA KITCHEN/DINING/LIVING COMBINED OPEN LIVING SPACE

LIVING MIN 2HR SOLAR - 5 OUT OF 6 UNITS = 83%

POS MIN 2HR SOLAR - 6 OUT OF 6 UNITS = 100%

SUN COUNTED AS SOLAR REQUIREMENT