


ELECTRICAL INFRASTRUCTURE DUE DILIGENCE REPORT

TOGA PENWAY PLACE PENRITH

MULTIDISCIPLINARY CONSULTANCY SERVICES



JHA

JHASERVICES.COM

This report is prepared for the nominated recipient only and relates to the specific scope of work and agreement between JHA and TOGA (the recipient). It is not to be used or relied upon by any third party for any purpose.

DOCUMENT CONTROL SHEET

Project Number	180377
Project Name	TOGA Penrith
Description	Infrastructure Due Diligence Report for Level 3 Services
Key Contact	Mr Daniel Borkovic (TOGA)

Prepared By

Company	JHA
Address	Level 23, 101 Miller Street, North Sydney NSW 2060
Phone	61-2-9437 1000
Email	Boris.Skapik@jhaengineers.com.au
Website	www.jhaservices.com
Author	Boris Skapik
Checked	Kosma Tzannes
Authorised	Hadi Jalgha

Revision History

Issued To	Revision and Date								
Mr Daniel Borkovic	REV	DRAFT	FINAL	B					
	DATE	2/08/2019	23/01/2020	1/10/2021					
	REV								
	DATE								
	REV								
	DATE								

CONTENTS

CONTENTS.....	II
1 INTRODUCTION	1
2 ELECTRICAL SERVICES	2
2.1 EXISTING INFRASTRUCTURE.....	2
2.1.1 General	2
2.1.2 High Voltage Infrastructure	2
2.1.3 Low Voltage Infrastructure	2
2.1.4 Street Lighting	2
2.1.5 Summary	2
2.2 EAST DEVELOPMENT PROPOSED ELECTRICAL INFRASTRUCTURE.....	3
2.2.1 Electrical Maximum Demand	3
2.2.2 Proposed Supply Arrangements	3
2.2.3 Relocation of Existing Aerial LV Infrastructure	3
2.2.4 Proposed Authority Street Lighting	3
2.3 ENDEAVOUR ENERGY SUBSTATION PROGRAM	4
APPENDIX A – PREVIOUSLY APPROVED ELECTRICAL INFRASTRUCTURE	A
APPENDIX B – PROPOSED ELECTRICAL INFRASTRUCTURE	B
APPENDIX C – MAXIMUM DEMAND EAST DEVELOPMENT	C
APPENDIX D – SUBSTATION SPATIALS	D

1 INTRODUCTION

JHA have previously been engaged to complete detailed designs for a mixed use development (residential and commercial), which includes two towers totalling over 187 independent residential units. JHA scope included Level 3 and electrical services on the following property:

- DP 1243401 634-638 High Street, Penrith. NSW 2750 (East Development)

Project has been placed on hold for a considerable time and has now recommenced. It must be noted that previous investigation and Level 3 Design may no longer be viable and the purpose of this document is to re-investigate the potential impact the development shall have on the utility electrical infrastructure and update the findings in this document.

It is understood the above lot is proposed to be developed into a mixed commercial and residential premises consisting of the following expected arrangements:

- 1075m² of Commercial/Retail space
- 357 independent Residential Units
- 13,036m² of Carpark space

The following assumptions have been considered:

- Lifts at 32A/ph each
- Residential A/C rated at 12A/ph per unit
- Retail allowance 600A

This report covers the following infrastructure services:

- Electrical Services

During the creation of this report, the following sources of information were accessed and have been used to provide a summary of the utility services infrastructure available to, and surrounding the site and provide consideration for the potential points of connection for the development:

- Dial Before You Dig (DBYD)
- Endeavour Energy GIS Network
- Google Maps / Nearmaps / Sixmaps

Important note that this report is preliminary in nature and represents the findings at the time of writing. Until the Electrical Utility Endeavour Energy is formally engaged and a supply offer paid/signed the availability of the existing electrical infrastructure that is highlighted in this report could change at any time.

2 ELECTRICAL SERVICES

2.1 EXISTING INFRASTRUCTURE

2.1.1 GENERAL

The following section addresses the existing electrical infrastructure in the direct vicinity of the new development site, considering the Level 3 design provided for the East Development. A design has been previously submitted and approved by Endeavour Energy under the project UML8570 for a single 1000kVA kiosk substation, however the certification has lapsed and is no longer valid. The below summarises the existing infrastructure

2.1.2 HIGH VOLTAGE INFRASTRUCTURE

There are two 11kV High Voltage underground feeders located on the northern side of the development along High St. One of these feeders continues down along John Tipping Road.

To the west of the East development on Mulgoa Rd, there are two 11kV High Voltage underground feeders one of which passes alongside the southern part of site along Union Rd.

Spare capacity on HV network is currently unknown and subject to input from Endeavour Energy. If capacity is unavailable from local HV network, HV cable connections may be required from areas further away or from the nearest Zone Substation.

These existing assets are owned and operated by Endeavour Energy as the electrical authority for the area.

Please refer to Appendix A for service location details.

2.1.3 LOW VOLTAGE INFRASTRUCTURE

Existing 400V Low Voltage & Street Lighting aerial mains are located traversing along John Tripping Grove.

These assets are also owned by Endeavour Energy and provide the local properties with electrical supply.

The existing lots are supplied by aerial low voltage service mains connected to existing Endeavour Energy Poles from John Tripping Grove.

Please refer to Appendix A for service location details.

2.1.4 STREET LIGHTING

Existing 400V Street Lighting Underground cables are located traversing along Mulgoa Rd and down along Union Rd. Overhead 400V street lighting lines are located traversing along John Tipping Road and High St. Street lighting currently exists along all roads surrounding the property.

Please refer to Appendix A for service location details

2.1.5 SUMMARY

From our investigations, it appears the site is mostly unencumbered by any existing services except for the lighting and LV power poles located along John Tripping Grove that would make way for the public domain area. Street lighting may require changes based on council DA documents.

2.2 EAST DEVELOPMENT PROPOSED ELECTRICAL INFRASTRUCTURE

This section was completed on a high level desktop assessment without Endeavour Energy Input and is subject to change. The below summarises the electrical infrastructure requirements to suit the current proposed development.

2.2.1 ELECTRICAL MAXIMUM DEMAND

The maximum demand estimate for the site is shown below:

- 1,744.7 kVA; or
- 2,427 A/phase (3 phase)

The proposed electrical demand has been assessed based on the estimated number of independent living units and VA/m² for common property areas in accordance with AS/NZS 3000:2018 Electrical Installations (Wiring Rules).

Refer to Appendix C for a breakdown of the Maximum Demand.

2.2.2 PROPOSED SUPPLY ARRANGEMENTS

This section was completed on a high level desktop assessment without Endeavour Energy Input and is subject to change.

The following was proposed to Endeavour Energy, a visual representation is available in in Appendix B:

- Establishment of a two new High Voltage 1,000kVA transformer kiosks
- Trenching and installation of HV and LV cables to various feeders in the area.

The new kiosk substations and cables will become the property of Endeavour Energy at commissioning and, as such, all installation arrangements and design works will be in accordance with their Network Standards and site-specific requirements and is subject to their final approvals.

Refer to Appendix E for substation spatials, for the architectural and building considerations required around the substations as per Endeavour Energy Requirements. Additional notes to consider:

- Fire hydrants must be 10m away from the substations,
- Building ventilation must be 6m away from substations
- Substations must be located in an area that is free and available for Endeavour Energy maintenance trucks to gain 24/7 unimpeded access,
- Any structure within 3m of the substations must be fire rated.

2.2.3 RELOCATION OF EXISTING AERIAL LV INFRASTRUCTURE

N/A

2.2.4 PROPOSED AUTHORITY STREET LIGHTING

N/A

2.3 ENDEAVOUR ENERGY SUBSTATION PROGRAM

The following is an overview of the timing and required arrangements to be considered throughout the design and construction process for the new kiosk substations to be installed on site to provide suitable electrical supply.

ITEM	DESCRIPTION	Duration	Action By
DESIGN APPROVALS STAGE SCHEDULE			
1	Application for Connection to Endeavour	-	Client/ Consultant
2	Endeavour Connection Assessment: Endeavour Energy provides a 'Letter of Offer' to the applicant and monopoly fees for payment.	2 weeks	Endeavour Energy
3a	Design Contract Acceptance: Client accepts Endeavour Energy Design Contract terms and pays initial design and easement fees.	1 week	Client
3b	Proposed Design Scope: Consultant provides a proposed design scope to enable commencement of design information package.	Concurrent with 3a	Consultant
4a	Design Information: Endeavour Energy provides a Design Brief Package based on above PDS to enable commencement of ASP3 design for submission.	Up to 6 weeks	Endeavour Energy
4b	Notification Stage: ASP3 submits Section 45 notification (40 day notice) to council and SEPP notification (21 day notice) to council and neighbours	-	Consultant
5a	Design Stage: L3 ASP prepares design from Design Brief. Submission to Endeavour Energy for checking and further negotiations for final arrangements.	4 weeks*	Consultant
5b	Agreements & Contracts Stage: Client to execute contract documents including: <ul style="list-style-type: none"> - Deed of Agreement for Easement - Acceptance Contracts 	Concurrent with 5a	Client
6	Design Certification: Endeavour Energy design checking and certification of ASP3 design package. Includes for Endeavour Energy comments and revised design work submissions as required.	8 weeks**	Endeavour Energy / Consultant
7	Connection Offer: Endeavour Energy issues Connection Offer and construction phase fees.	1 week	Endeavour Energy
8	Connect Offer Acceptance: Client executes and returns Connection Offer Acceptance form. Client pays construction phase fees.	1 week	Client
9	Engage ASP1: Client engages ASP1 Contractor. ASP1 Contractor finalise the agreement with Endeavour Energy. ASP1 to order substation equipment (12 week lead time).	2 weeks	ASP1

* Design for the proposed kiosk substation is currently substantially complete. 4 weeks allows for:

- An unexpected result from Endeavour Energy Distribution Planning with regards to High Voltage Connection.
- Customer execution of easement and deed contracts for works.

** Subject to Endeavour Energy design review, Summary Environmental Report approval and minimal number of resubmissions. Section 45 Council 40 day notification expiration.

ITEM	DESCRIPTION	Duration	Action By
CONSTRUCTION STAGE SCHEDULE			
10	Pre-Construction Meeting: ASP1 schedules and requests construction kick-off meeting with Endeavour Energy and ASP3 on site.	2 weeks	ASP1
11a	Project Planning: ASP1 submits permits and construction planning critical dates to Endeavour Energy. ASP1 nominates its employees for authorisations by Endeavour Energy to enable works to commence. Client and the ASP1 to provide notification for Endeavour Energy inspection.	2 weeks	ASP1
11b	Compliance Officer Appointment: Endeavour Energy appoints a Compliance Officer for the project and attends initial site meeting to review the construction planning.	Concurrent with 11a	Endeavour Energy
12	Commencement Approval: Endeavour Energy Compliance Officer assesses construction planning pre-conditions and provides approval for the construction phase works to commence.	1-2 weeks	Endeavour Energy
13	Construction Stage: ASP1 commences construction of new kiosk substation. Endeavour Energy inspects work in progress at pre-determined milestones. Equipment delivery to site.	12 weeks^	ASP1
15	Request for Electrification: ASP1 schedules and requests the commissioning outage date for connection of new substation. Any defects notified to the ASP1 must be rectified prior to electrification.	Minimum 6 weeks	ASP1
16	Pre-Electrification / Practical Completion: Endeavour Energy conducts Practical Completion inspection of the works.	2 weeks	Endeavour Energy
17	Electrification / Commissioning: Endeavour Energy accepts the ASP1 works as part of its Network.		Endeavour Energy

^ Subject to delivery of substation equipment to site with minimum 4 weeks installation time and piercing / earthing / civil works completed.

APPENDIX A – PREVIOUSLY APPROVED ELECTRICAL INFRASTRUCTURE


Penway Place, East Development



Disclaimer: This report has been generated by various sources and is provided for information purposes only. Spatial Services does not warrant or represent that the information is free from errors or omission, or that it is exhaustive. Spatial Services gives no warranty in relation to the information, especially material supplied by third parties. Spatial Services accepts no liability for loss, damage, or costs that you may incur relating to any use or reliance upon the information in this report.

APPENDIX B – PROPOSED ELECTRICAL INFRASTRUCTURE

Penway Place, East Development



Disclaimer: This report has been generated by various sources and is provided for information purposes only. Spatial Services does not warrant or represent that the information is free from errors or omission, or that it is exhaustive. Spatial Services gives no warranty in relation to the information, especially material supplied by third parties. Spatial Services accepts no liability for loss, damage, or costs that you may incur relating to any use or reliance upon the information in this report.


APPENDIX C – MAXIMUM DEMAND EAST DEVELOPMENT

Toga - High St, Penrith

Date: 01/10/2021

AS 3000 Table C1	Blocks of living units		Total Numbers Of Units	
	21 or more living units per phase	357.0		
	Loading associated with individual units	119.0	Units Per Phase	
A. Lighting				
(i) Except as in (ii) and load group H below	0.5 A per living unit	59.5		
(ii) Outdoor lighting exceeding a total of 1000W	No assessment for purpose of maximum demand			
B. Socket outlets				
(i) Socket-outlets not exceeding 10 A. Permanently connected electrical equipment not exceeding 10 A and not included in other load groups	50 A + 1.9 A per living unit	276.1		
(ii) Where the electrical installation includes one or more 15 A socket-outlets other than socket-outlets provided to supply electrical equipment set out in groups C, D, E, F, G, and L	10 A	0.0	0	Qty
(iii) Where the electrical installation includes one or more 20 A socket-outlets other than socket-outlets provided to supply electrical equipment set out in groups C, D, E, F, G, and L	15 A	0.0	0	Qty
C. Ranges, cooking appliances, laundry equipment or socket outlets rated at more than 10 A for the connection thereof	2.8 A per living unit	333.2		
D. Fixed space heating of air-conditioning equipment, saunas or socket-outlets rated at more than 10 A for the connection thereof	75% connected load	1071.0	1428	685
E. Instantaneous water heaters	100 A + 0.8 A per living unit	0.0	If there is a value in M13 delete M14 If there is a value in M14 delete M13	
F. Storage water heaters	100 A + 0.8 A per living unit			
G. Spa and swimming pool heaters	75% of the largest spa, plus 75% of the largest swimming pool, plus 25% of the	0.0		Largest Spa
		0.0		Largest Pool
		0.0		Remainder
H. Communal lighting	100% connected load	100.0	100	Total Load
I. Socket-outlets not included in groups J and M below Permanently connected electrical equipment not exceeding 10 A	1 A per point, up to a maximum of 15 A	0.0		Qty
J. Appliances rated at more than 10 A and (i) Clothes dryers, water heaters, self-heating washing machines, wash boilers	50% connected load	0.0		Total Load
(ii) Fixed space heating, air-conditioning equipment, saunas	75% connected load	37.5	50	Total Load
(iii) Spa and swimming pool heaters	75% of the largest spa, plus 75% of the largest swimming pool, plus 25% of the	0.0		Largest Spa
		0.0		Largest Pool
		0.0		Remainder
K. Lifts	No assessment for purpose of maximum demand			
L. Motors	(i) Largest motor-100% (ii) Remaining motors-50%	0.0		Largest
		0.0		Remaining
M. Other items not covered by above	< 11 A - No assessment > 10 A - By assessment			
		1877.3	Amps	
		1501.8	Amps	Diversity 0.8

APPENDIX D – SUBSTATION SPATIALS



APPENDIX E – DBYD
