

9. Flooding Risk

Applies to

This section applies to land identified as Flood Prone Land within *Liverpool LEP 2008*.

Background

1. In 1984, the State Government introduced its current flood prone land policy applicable to New South Wales. The first Floodplain Development Manual was published in 1986, providing guidelines for the implementation of the government's flood prone land policy and the merit approach, which underpins its application. Revised guidelines were released in 2005 and are now embodied in the *Floodplain Development Manual*, April 2005. The revised *Floodplain Development Manual* continues to support the NSW Government's Flood Prone Land Policy. The primary objective of the policy is:

"To reduce the impact of flooding and flood liability on individual owners and occupiers of flood prone property, and to reduce private and public losses resulting from floods, utilising ecologically positive methods wherever possible."

2. To achieve this objective the *Floodplain Development Manual* acknowledges a broad risk management hierarchy of:
 - Avoidance of flood risk;
 - Minimisation of flood risk using appropriate planning controls; and
 - Flood risk mitigation.
3. Flood risk mitigation is not always the preferred option, being costly and most likely to adversely affect the natural environment. Avoidance and minimisation of flood risk are the options most likely to be acceptable and are primarily reliant on land use planning and development control for implementation. These planning and development controls are reflected in this Section.
4. Local Government is the primary authority responsible for both flood risk management and land use planning in New South Wales. The NSW Government's flood policy provides for a flexible merit based approach to be followed by local government when dealing with planning, development and building matters on flood prone land. For Council to fully carry out its responsibilities for management of flood prone land, it is necessary to prepare local Floodplain Risk Management Plans.
5. The *Floodplain Development Manual* requires that Councils prepare Floodplain Risk Management Studies as a prelude to the formulation of a Floodplain Risk Management Plan that, among other things, would control development and other activity within the floodplain. This Section of the DCP is consistent with Council's and State Government's "Flood Prone Land Policy" and the *Floodplain Development Manual*.
6. This Section of the DCP is an application of the State Policy, which reflects local circumstances, as identified for some floodplains, through the preparation of Floodplain Risk Management Plans.

Objectives

- a) To minimise the potential impact of development and other activity upon the aesthetic, recreational and ecological value of the waterway corridors.
- b) To ensure essential services and land uses are planned in recognition of all potential floods.
- c) To reduce the risk to human life and damage to property caused by flooding through controlling development on land affected by potential floods.
- d) To ensure that the economic and social costs which may arise from damage to property due to flooding is minimised and is not greater than that which can be reasonably managed by the property owner and general community.
- e) To limit developments with high sensitivity to flood risk (e.g. critical public utilities) to land with minimal risk from flooding.
- f) To prevent intensification of inappropriate use of land within high flood risk areas or floodways.
- g) To permit development with a lower sensitivity to the flood hazard to be located within the floodplain, subject to appropriate design and siting controls.
- h) To ensure that development should not detrimentally increase the potential flood affectation on other development or properties either individually or in combination with the cumulative impact of development that is likely to occur in the same floodplain.
- i) To ensure that development does not prejudice the economic viability of any Voluntary Acquisition Scheme.

9.1 Determining Relevant Controls**Controls**

The controls vary depending on:

1. Sensitivity of a land use to flooding
2. Severity of flood impact on site
3. Specific Floodplain in which a site is located

Follow these steps determine the relevant controls.

Step 1. Identify Flood Risk Category (degree of flooding risk). See Section 9.2.

Step 2. Identify Land Use Risk Category. See Section 9.3.

Step 3. Identify relevant Floodplain. See Section 9.4.

Step 4. Identify relevant Floodplain Controls. See Section 9.5 and 9.6.

The following figure summarises this consideration process.




Figure 6 Flow chart for the determination of flood risk

9.2 Step 1 Identify the Flood Risk Category

Controls

1. Flood liable land is categorised according to the levels of potential flood risk as outlined below.

High Flood Risk Category means land below the 1% AEP flood that is either subject to a high hydraulic hazard or where there are significant evacuation difficulties.

Note: The high flood risk Category is where high flood damages potential risk to life evacuation problems would be anticipated or development would significantly and adversely effect flood behaviour. Most development should be restricted in this Category. In this Category there would be a significant risk of flood damages without compliance with flood related building and planning controls.

Medium Flood Risk Category means land below the 1% AEP flood that is not subject to a high hydraulic hazard and where there are no significant evacuation difficulties.

Note: In this Category there would still be a significant risk of flood damage, but these damages can be minimised by the application of appropriate development controls.

Low Flood Risk Category means all other land within the floodplain (i.e. within the extent of the probable maximum flood) but not identified within either the High Flood Risk or the Medium Flood Risk Category.

Note: The Low Flood Risk Category is where the risk of damages is low for most land uses. The Low Flood Risk Category is that area above the 1% AEP flood and most land uses would be permitted within this Category.

No Flood Risk Mapping means that there has not yet been any risk Categories determined for this area.

Note: Flood Risk Category Maps are not available for all Flood Prone Land. Applicants may be required to undertake a flood study to determine the flood extent and Flood Risk Categories in order to apply appropriate controls required by this Development Control Plan.

2. Council has prepared flood risk mapping for the majority of the floodplains within the Liverpool LGA through a number of Floodplain Risk Management Studies and Plans adopted by Council and this information is available from Council.
3. It should be noted that the flood risk mapping prepared by Council has been developed at a broad scale for the purpose of undertaking Floodplain Risk Management Studies. This mapping is considered preliminary and can be subject to refinement as part of the assessment of individual proposals. Furthermore, works consistent with the flooding provisions of this DCP and acceptable to Council could be undertaken to alter the flood risk category of land.
4. If the peak flow rate of an overland flow path, during the 1% AEP flood, exceeds 5 cubic metres per second then the overland flow path shall be treated as mainstream flooding and the development controls for mainstream flooding shall be applied.

9.3 Step 2 Identify Land Use Risk Category

Land use is categorised into 8 Land Use Risk Categories according to the sensitivity of each land use to flooding. The definitions of each land use are based on the *Liverpool LEP 2008*, are categorised as follows.

Critical uses and Facilities

Community facility which may provide an important contribution to the notification or evacuation of the community during flood events

Hospitals

Residential care facility

Sensitive Uses and Facilities

Educational establishments

Schools

Hazardous or offensive industry or storage establishment

Liquid fuel depot

Seniors housing

Utility installations or Public utility undertakings (including generating works) undertakings which are essential to evacuation during periods of flood or if affected would unreasonably affect the ability of the community to return to normal activities after flood events

Telecommunications facility

Waste disposal land fill operation

Group home

Subdivision

Subdivision of land, which involves the creation of new allotments, with potential for further development

Residential

Attached dwelling	Exhibition village	Residential accommodation
Backpackers' accommodation	Family day care centre	Residential flat building
Bed and breakfast premises	Health consulting rooms	Rural workers' dwelling
Boarding houses	Home-based child care service	Secondary dwelling
Canal estate development	Home business	Semi-detached dwelling
Caravan Park	Home occupation	Serviced apartments
Child care centre	Hostel	Shop top housing
Dual occupancy	Information and education facility	Utility installations or Public utility undertakings (other than critical utilities)
Dwelling	Moveable dwelling	Tourist and visitor accommodation
Dwelling house	Multi dwelling housing	
Exhibition home		

Commercial or Industrial

Agricultural produce industry	Funeral home	Registered club
Amusement Centre	Heavy Industry	Restaurant
Animal boarding or training establishment	Heliport	Retail premises
Boat repair facility	Hotel accommodation	Roadside stall
Boat shed	Industry	Rural industry
Bulky goods premises	Kiosk	Sawmill or log processing works
Business premises	Light Industry	Service station
Cemetery	Materials recycling or recovery centre	Sex service premises
Charter and tourism boating facility	Medical centre	Transport depot
Commercial port facility	Mortuary	Take away food or drink premises
Crematorium	Neighbourhood shop	Tank based aquaculture
Depot	Office premises	Truck depot
Electricity generating works	Passenger transport terminal	Vehicle body repair workshop
Entertainment facility	Place of public worship	Vehicle repair station
Freight transport facility	Public administration building	Vehicle showroom
Function Centre	Recreation facility (indoor)	Veterinary hospital
Funeral chapel	Recreation facility (major)	Warehouse or distribution centre

Recreation or Non-urban Uses

Agriculture
 Aquaculture
 Dam
 Environmental facility
 Extractive industry
 Feedlot
 Helipads
 Horticulture
 Intensive livestock agriculture
 Landscape and garden supplies
 Marina
 Recreation facility (outdoor)
 Stock and sale yard
 Turf farming

Concessional Development

1. In the case of residential development:
 - An addition or alteration to an existing dwelling of not more than 30sqm or 10% (whichever is the lesser) of the habitable floor area which existed at 1 December 1987. (The date of adoption of the first *Liverpool City Council Floodplain Management Plan*); or
 - The construction of an outbuilding with a maximum floor area of 20sqm (or 50sqm for land zoned for non urban purposes); or
 - Rebuilding dwellings in a manner which substantially reduces the flood risk having regard to property damage and personal safety when compared to the existing building.
2. In the case of other development:
 - An addition to existing premises of not more than 10% of the floor area which existed at 1 December 1987. (The date of adoption of the first *Liverpool City Council Floodplain Management Plan*); or
 - Rebuilding of a development in a manner which substantially reduces the flood risk having regard to property damage and personal safety when compared to the existing development; or
 - A change of use, which does not increase flood risk having regard to property damage and personal safety; or
 - Subdivision that does not involve the creation of new allotments with potential for further development.

9.4 Step 3 Identify relevant Floodplain

Identify the relevant Floodplain on Figures 7 & 8.

9.5 Step 4 Identify relevant Floodplain Controls

1. Each floodplain area has two sets of controls. These are:
 - Mainstream Flooding Controls, identified in Tables 2 – 4 and Section 9.6.
 - Local Overland Flooding Controls, identified in Table 5.
2. Development on flood prone land will be required to comply with either or both of these.
3. An explanation of these controls is in Table 6.




Figure 7 Map for identification of relevant floodplains




Figure 8 Moorebank Floodway

Table 2 Nepean River Floodplains (Includes South Ck, Kemps Ck, Bonds Ck and other tributaries of the Nepean River)

Flood Risk Category	Land Use Risk Category	Planning Controls							
		Flood Level	Building Components	Structural Soundness	Flood Effects	Car Parking & Driveway Access	Evacuation	Management & Design	Fencing
Low Flood Risk	Critical Uses & Facilities								
	Sensitive Uses & Facilities	12	4	4	2, 4, 5	2, 3, 6, 7, 8	2, 6, 8	4, 5	
	Subdivision				2, 4, 5			1, 6	
	Residential (++)	2, 6	3	3		2, 3, 6, 7, 8	2, 6		
	Commercial & Industrial	2, 6	3	3	2, 4, 5	8	1, 6	2, 3, 5	
	Tourist Related Development	1, 6, 15	3	3	2, 4, 5	2, 3, 6, 7, 8	2, 6	2, 3, 5	
	Recreation & Non-Urban	1, 9, 15	3	3		1, 5, 7, 8	6, 8	2, 3, 5	
	Concessional Development	14	3	3		1, 3, 5, 7, 8, 9	2, 6	2, 3, 5	
Medium Flood Risk	Critical Uses & Facilities								
	Sensitive Uses & Facilities								
	Subdivision				1, 4, 5			1	1, 2, 3
	Residential	2, 6, 15	3	1	2, 4, 5	2, 3, 6, 7, 8	2, 6		1, 2, 3
	Commercial & Industrial	2, 6, 15	3	1	2, 4, 5	2, 3, 6, 7, 8	1, 6	2, 3, 5	1, 2, 3
	Tourist Related Development	1, 6, 15	3	1	2, 4, 5	2, 3, 6, 7, 8	2, 6	2, 3, 5	1, 2, 3
	Recreation & Non-Urban	1, 9, 15	3	1	2, 4, 5	1, 5, 7, 8	6, 8	2, 3, 5	1, 2, 3
	Concessional Development	1, 14, 15	3	1	2, 4, 5	1, 3, 5, 7, 8, 9	2, 8	2, 3, 5	1, 2, 3
High Flood Risk	Critical Uses & Facilities								
	Sensitive Uses & Facilities								
	Subdivision								
	Residential								
	Commercial & Industrial								
	Tourist Related Development								
	Recreation & Non-Urban	1, 9, 15	3	1	1, 4, 5	1, 5, 7, 8	6, 8	2, 3, 5	1, 2, 3
	Concessional Development	1, 14, 15	3	1	1, 4, 5	1, 3, 5, 7, 8, 9	2, 6	2, 3, 5	1, 2, 3

Key

Not Relevant

Unsuitable Land Use

1, 2, 3 Control reference number relevant to the particular planning consideration (see Table 6)

(++) Attached dwellings, Dwelling houses, dual occupancies, multi unit dwelling housing, residential flat buildings (not including development for the purpose of group homes or seniors housing), Secondary dwellings and Semi-detached dwellings are exempt from these controls.

Table 3 Cabramatta Creek and all other Floodplains (Includes Hinchinbrook Creek, Maxwells Creek, Brickmakers Creek, upper parts of Anzac Ck, and other tributaries)

Flood Risk Category	Land Use Risk Category	Planning Controls							
		Floor Level	Building Components	Structural Soundness	Flood Effects	Car Parking & Driveway Access	Evacuation	Management & Design	Fencing
Low Flood Risk	Critical Uses & Facilities								
	Sensitive Uses & Facilities	13	4	4	2, 4, 5	2, 3, 6, 7, 8	3, 6, 8	4, 5	
	Subdivision				2, 4, 5			1, 6	
	Residential (++)	2, 6	3	3		2, 3, 7	3, 6		
	Commercial & Industrial	2, 11, 15	3	3	2, 4, 5	2, 3, 6, 7, 8	(3 or 4), 6	2, 3, 5	
	Tourist Related Development	2, 6, 15	3	3	2, 4, 5	2, 3, 6, 7, 8	3, 6	2, 3, 5	
	Recreation & Non-Urban	2, 7	3	3	2, 4, 5	1, 5, 7, 8	6, 8	2, 3, 5	
	Concessional Development	14, 15	3	3	2, 4, 5	1, 7, 8, 9	3, 6	2, 3, 5	
Medium Flood Risk	Critical Uses & Facilities								
	Sensitive Uses & Facilities								
	Subdivision				1, 4, 5			1, 6	1, 2, 3
	Residential	2, 6, 15	3	1	2, 4, 5	2, 3, 6, 7, 8	3, 6		1, 2, 3
	Commercial & Industrial	11, 15	3	1	2, 4, 5	2, 3, 6, 7, 8	4, 6	2, 3, 5	1, 2, 3
	Tourist Related Development	2, 6, 15	3	1	2, 4, 5	2, 3, 6, 7, 8	3, 6	2, 3, 5	1, 2, 3
	Recreation & Non-Urban	2, 7	3	1	2, 4, 5	1, 5, 7, 8	6, 8	2, 3, 5	1, 2, 3
	Concessional Development	14, 15	3	1	2, 4, 5	1, 7, 8, 9	3, 8	2, 3, 5	1, 2, 3
High Flood Risk	Critical Uses & Facilities								
	Sensitive Uses & Facilities								
	Subdivision								
	Residential								
	Commercial & Industrial								
	Tourist Related Development								
	Recreation & Non-Urban	2, 7	3	1	1, 4, 5	1, 5, 7, 8	6, 8	2, 3, 5	1, 2, 3
	Concessional Development	14, 15	3	1	1, 4, 5	1, 7, 8, 9	3, 6	2, 3, 5	1, 2, 3

Key:

- Not Relevant
- Unsuitable Land Use
- 1, 2, 3 Control reference number relevant to the particular planning consideration (see Table 6)
- (++) Attached dwellings, Dwelling houses, dual occupancies, multi unit dwelling housing, residential flat buildings (not including development for the purpose of group homes or seniors housing), Secondary dwellings and Semi-detached dwellings are exempt from these controls

Table 4 Georges River Floodplain (Includes Harris Ck and Williams Ck, lower parts of Anzac Ck, but not Cabramatta Creek)

Flood Risk Category	Land Use Risk Category	Planning Controls							
		Flood Level	Building Components	Structural Soundness	Flood Effects	Car Parking & Driveway Access	Evacuation	Management & Design	Fencing
Low Flood Risk	Critical Uses & Facilities								
	Sensitive Uses & Facilities	13	4	4	2, 4, 5	2, 3, 6, 7, 8	6, 8, 9	2, 4	
	Subdivision				2, 4, 5			1	
	Residential (++)	2, 6	2	3	2, 4, 5	2, 3, 6, 7, 8	6, 9		
	Commercial & Industrial	4, 8, 15	2	3	2, 4, 5	2, 3, 6, 7, 8	(4 or 9), 6	2, 3, 5	
	Tourist Related Development	2, 6, 15	2	3	2, 4, 5	2, 3, 6, 7, 8	6, 9	2, 3, 5	
	Recreation & Non-Urban	2, 7	2	3	2, 4, 5	1, 5, 7, 8	6, 8	2, 3, 5	
	Concessional Development	14, 15	2	3	2, 4, 5	1, 7, 8, 9	6, 9	2, 3, 5	
Medium Flood Risk	Critical Uses & Facilities								
	Sensitive Uses & Facilities								
	Subdivision				1, 4, 5			1	1, 2, 3
	Residential	2, 6, 15	2	2	2, 4, 5	2, 3, 6, 7, 8	6, 9		1, 2, 3
	Commercial & Industrial	8, 4, 15	2	2	2, 4, 5	2, 3, 6, 7, 8	4, 6	2, 3, 5	1, 2, 3
	Tourist Related Development	2, 6, 15	2	2	2, 4, 5	2, 3, 6, 7, 8	6, 9	2, 3, 5	1, 2, 3
	Recreation & Non-Urban	2, 7	2	2	2, 4, 5	1, 5, 7, 8	6, 8	2, 3, 5	1, 2, 3
	Concessional Development	14, 15	2	2	2, 4, 5	1, 7, 8, 9	8, 9	2, 3, 5	1, 2, 3
High Flood Risk	Critical Uses & Facilities								
	Sensitive Uses & Facilities								
	Subdivision								
	Residential								
	Commercial & Industrial								
	Tourist Related Development								
	Recreation & Non-Urban	2, 7	2	2	1, 4, 5	1, 5, 7, 8	6, 8	2, 3, 5	1, 2, 3
	Concessional Development	14, 15	2	2	1, 4, 5	1, 7, 8, 9	6, 9	2, 3, 5	1, 2, 3

Key:

Not Relevant

Unsuitable Land Use

1, 2, 3 Control reference number relevant to the particular planning consideration. (see Table 6)

(++) Attached dwellings, Dwelling houses, dual occupancies, multi unit dwelling housing, residential flat buildings (not including development for the purpose of group homes or seniors housing). Secondary dwellings and Semi-detached dwellings are exempt from these controls.

Table 5 Local Overland Flooding

Flood Risk Category	Land Use Risk Category	Planning Controls							
		Floor Level	Building Components	Structural Soundness	Flood Effects	Car Parking & Driveway Access	Evacuation	Management & Design	Fencing
Local Overland Flood Risk	Critical Uses & Facilities	13	4	5	3	4, 7, 8	7	3, 5	2, 4
	Sensitive Uses & Facilities	13	4	5	3	4, 7, 8	7	3, 5	2, 4
	Subdivision				3		5	1	2, 4
	Residential	3, 5	1	6	3	4, 7, 8	5		2, 4
	Commercial & Industrial	10	1	6	3	4, 7, 8	5	3, 5	2, 4
	Tourist Related Development	3, 5	1	6	3	4, 7, 8	5	3, 5	2, 4
	Recreation & Non-Urban	3, 5	1	6	3	4, 7, 8	5	3, 5	2, 4
	Concessional Development	14	1	6	3	4, 7, 8	5	3, 5	2, 4

Key:

Not Relevant

1, 2, 3 Control reference number relevant to the particular planning consideration

Table 6 Explanation of Development Controls

Ref No	Controls
Floor level	
1	All floor levels to be as high as practical but not less than the 20% AEP flood level.
2	Non habitable floor levels to be as high as practical but no less than the 5% AEP flood level.
3	Non-habitable floor levels to be not less than the 1% AEP flood.
4	The level of Non-habitable and general Industrial floor areas to be as high as practical but not less than the 2% AEP flood. Where this is impractical for single lot developments within an existing developed area, the floor shall be as high as practical but no less than the 5% AEP flood.
5	Habitable floor levels to be equal to or greater than the 1% AEP flood level plus 300mm freeboard.
6	Habitable floor levels to be equal to or greater than the 1% AEP flood level plus 500mm freeboard.
7	Habitable floor levels to be no lower than the 1% AEP flood plus 500mm freeboard unless justified by site specific assessment.
8	Habitable and general commercial floor levels to be as high as practical but no lower than the 1% AEP flood plus 500mm freeboard unless justified by site specific assessment.
9	The level of habitable floor areas to be equal to or greater than the 1% AEP flood level plus 500mm freeboard. If this level is impractical a lower floor level may be considered provided the floor level is as high as possible but no less than the 5% AEP flood level.
10	All floor levels to be equal to or greater than the 1% AEP flood level plus 300mm freeboard. Freeboard may be reduced if justified by site specific assessment.
11	All floor levels to be no lower than the 1% AEP flood plus 500mm freeboard. Freeboard may be reduced if justified by site specific assessment.
12	All floor levels to be equal to or greater than the PMF level. If this level is impractical a lower floor level may be considered provided the floor level is as high as possible but no less than the 1% AEP flood level plus 500mm freeboard.

Ref No	Controls
13	Floor levels to be no lower than the PMF level unless justified by a site specific assessment.
14	Floor levels to be equal to or greater than the minimum requirements normally applicable to this type of development. Where this is not practical due to compatibility with the height of adjacent buildings, or compatibility with the floor level of existing buildings, or the need for access for persons with disabilities, a lower floor level may be considered. In these circumstances, the floor level is to be as high as practical, and, when undertaking alterations or additions no lower than the existing floor level.
15	A restriction is to be placed on the title of the land, pursuant to S.88B of the <i>Conveyancing Act</i> , where the lowest habitable floor area is elevated more than 1.5m above finished ground level, confirming that the undercroft area is not to be enclosed.
Building Components & Method	
1	All structures to have flood compatible building components below the 1% AEP flood level plus 300mm freeboard.
2	All structures to have flood compatible building components below the 1% AEP flood level plus 500mm freeboard.
3	All structures to have flood compatible building components below the 1% AEP flood level plus 500mm freeboard or a PMF if required to satisfy evacuation criteria (see below).
4	All structures to have flood compatible building components below the PMF level.
Structural Soundness	
1	Applicant to demonstrate that the structure can withstand the forces of floodwater, debris and buoyancy up to and including a 1% AEP flood plus 500mm freeboard or a PMF if required to satisfy evacuation criteria (see below). An engineer's report may be required.
2	Engineer's report to certify that the structure can withstand the forces of floodwater, debris and buoyancy up to and including a 1% AEP flood plus 500mm freeboard.
3	Applicant to demonstrate that the structure can withstand the forces of floodwater, debris and buoyancy up to and including a 1% AEP flood plus 500mm freeboard.
4	Applicant to demonstrate that any structure can withstand the forces of floodwater, debris and buoyancy up to and including a PMF. An engineer's report may be required.
5	Applicant to demonstrate that any structure can withstand the forces of floodwater, debris and buoyancy up to and including a PMF.
6	Applicant to demonstrate that the structure can withstand the forces of floodwater, debris and buoyancy up to and including a 1% AEP flood plus 300mm freeboard.
Flood Effects	
1	Engineers report required to certify that the development will not increase flood effects elsewhere, having regard to: (i) loss of flood storage; (ii) changes in flood levels, flows and velocities caused by alterations to flood flows; and (iii) the cumulative impact of multiple similar developments in the floodplain.
2	The flood impact of the development to be considered to ensure that the development will not increase flood effects elsewhere, having regard to: (i) loss of flood storage; (ii) changes in flood levels and velocities caused by alterations to the flood conveyance; and (iii) the cumulative impact of multiple potential developments in the floodplain. An engineer's report may be required.
3	The flood impact of the development to be considered to ensure that the development will not increase flood affectation elsewhere having regard to changes in flood levels and velocities caused by alteration of conveyance of flood waters. An engineer's report may be required if Council considers a significant affectation is likely. The unmitigated obstruction, concentration or diversion of overland

Ref No	Controls
	flow paths to adjacent property shall not be permitted.
4	A floodway or boundary of significant flow may have been identified in this catchment. This area is the major conveyance area for floodwaters through the floodplain and any structures placed within it are likely to have a significant impact on flood behaviour. Within this area no structures other than concessional development, open type structures or small non habitable structures (not more than 30sqm) to support agricultural uses will normally be permitted. Development outside the Boundary of Significant flow may still increase flood effects elsewhere and therefore be unacceptable
5	Any filling within the 1% AEP flood will normally be considered unacceptable unless compensatory excavation is provided to ensure that there is no net loss of floodplain storage volume below the 1% AEP flood.
Car Parking and Driveway Access	
1	The minimum surface level of open car parking spaces, carports or garages, shall be as high as practical.
2	The minimum surface level of a car parking space, which is not enclosed (e.g. open car parking space or carport) shall be as high as practical, but no lower than the 5% AEP flood level or the level of the crest of the road at the highest point where the site can be accessed. In the case of garages, the minimum surface level shall be as high as practical, but no lower than the 5% AEP flood.
3	Garages capable of accommodating more than 3 vehicles on land zoned for urban purposes, or basement car parking, must be protected from inundation by floods equal to or greater than the 1% AEP flood plus 0.1m freeboard.
4	Basement car parking shall be protected from inundation by the 1% AEP flood.
5	The driveway providing access between the road and car parking space shall be as high as practical and generally rising in the egress direction.
6	The level of the driveway providing access between the road and car parking space shall be no lower than 0.3m below the 1% AEP flood or such that depth of inundation during a 1% AEP flood is not greater than either the depth at the road or the depth at the car parking space. A lesser standard may be accepted for single detached dwelling houses where it can be demonstrated that risk to human life would not be compromised.
7	Basement car parking or car parking areas accommodating more than 3 vehicles (other than on Rural zoned land) with a floor level below the 5% AEP flood or more than 0.8m below the 1% AEP flood level; shall have adequate warning systems, signage and exits.
8	Barriers to be provided to prevent floating vehicles leaving a site during a 1% AEP flood.
9	Driveway and car parking space levels shall be no lower than the minimum requirements normally applicable to this type of development. Where this is not practical, a lower level may be considered. In these circumstances, the level is to be as high as practical and, when undertaking alterations or additions no lower than the existing level.
Evacuation	
1	Reliable access for pedestrians required during a 1% AEP flood.
2	Reliable access for pedestrians or vehicles is required from the building, commencing at a minimum level equal to the lowest habitable floor level to an area of refuge above the PMF level, or a minimum of 20% of the habitable floor area is above the PMF.
3	Reliable access for pedestrians or vehicles is required from the building to an area of refuge above the PMF level, or a minimum of 20% of the habitable floor area is above the PMF
4	Reliable access for pedestrians or vehicles required during a 1% AEP flood to a publicly accessible location above the PMF.

Ref No	Controls
5	The evacuation requirements of the development during flooding shall be considered.
6	The development is to be consistent with any relevant flood evacuation strategy or similar plan.
7	The evacuation requirements of the development are to be considered up to the PMF level.
8	The evacuation requirements of the development are to be considered. An engineer's report will be required if circumstances are possible where the evacuation of persons might not be achieved within the effective warning time.
9	Adequate flood warning is available to allow safe and orderly evacuation without increased reliance upon the SES or other authorised emergency services personnel.
Management and Design	
1	Applicant to demonstrate that potential development as a consequence of a subdivision proposal can be undertaken in accordance with this DCP.
2	Site Emergency Response Flood Plan required where floor levels are below the design floor level, (except for single dwelling-houses).
3	Applicant to demonstrate that area is available to store goods above the 1% AEP flood level plus 500mm freeboard.
4	Applicant to demonstrate that area is available to store goods above the PMF level.
5	No storage of materials below the design floor level which may cause pollution or be potentially hazardous during any flood.
6	Finished land levels in new release areas shall be not less than the 1% AEP flood unless justified by site specific assessment. A surveyor's certificate will be required upon completion certifying that the final levels are not less than the required level.
Fencing	
1	Fencing within a High Flood Risk area, Boundary of Significant Flow or floodway will not be permitted except for permeable open type fences.
2	Fencing is to be constructed in a manner that does not obstruct the flow of floodwaters so as to have an adverse impact on flooding.
3	Fencing shall be constructed to withstand the forces of floodwaters or collapse in a controlled manner so as not to obstruct the flow of water, become unsafe during times of flood or become moving debris.
4	Fencing shall be constructed to withstand the forces of floodwaters.

9.6 Controls Applicable to the Moorebank Floodway

1. Notwithstanding any other provision where a property is identified within the Moorebank Voluntary Acquisition Scheme area, Council will only consent to further development as noted in Table 7.

Table 7 Controls applicable to the Moorebank Floodway

Control	
Development	Development is only for minor works such as small awnings over existing first floor balconies or in-ground swimming pools The capital investment shall not materially increase the acquisition costs of the property.

Council will not permit any type of development which would be inconsistent with the objective of discouraging further development in areas of high risk and with Council's commitment to the Moorebank Voluntary Acquisition Scheme.

4/24/2014

NSW Legislation



[Whole title](#) [Parent Act](#) [Historical versions](#) [Historical notes](#) [Search title](#) [Maps](#)

Results: Document Types="EPIs", Exact Phrase="liverpool", Search In="Text"
 Result titles | Result hits

Liverpool Local Environmental Plan 2008

Current version for 4 April 2014 to date (accessed 24 April 2014 at 10:04)

[Part 7](#) > [Division 2](#) > [Clause 7.8](#)

<< page >>

7.8 Flood planning

- (1) The objectives of this clause are:
 - (a) to maintain the existing flood regime and flow conveyance capacity, and
 - (b) to avoid significant adverse impacts on flood behaviour, and
 - (c) to limit uses to those compatible with flow conveyance function and flood hazard, and
 - (d) to minimise the risk to human life and damage to property from flooding.
- (2) Despite any other provision of this Plan, development consent is required for development for the following purposes on land in a flood planning area:
 - (a) earthworks,
 - (b) the erection of a building,
 - (c) the carrying out of a work,
 - (d) flood mitigation works (other than those carried out by a public authority).
- (2A) Development consent must not be granted to development in a flood planning area for the purposes of residential accommodation unless the consent authority is satisfied that the development:
 - (a) will not adversely affect flood behaviour and increase the potential for flooding to detrimentally affect other development or properties, and
 - (b) will not significantly alter flow distributions and velocities to the detriment of other properties or the environment, and
 - (c) will enable the safe occupation and evacuation of the land, and
 - (d) will not have a significant detrimental affect on the environment or cause avoidable erosion, siltation, destruction of riparian vegetation or a reduction in the stability of any riverbank or watercourse, and
 - (e) will not be likely to result in unsustainable social and economic costs to the flood affected community or general community as a consequence of flooding, and
 - (f) if located in the floodway, will be compatible with the flow of flood waters and with any flood

4/24/2014

NSW Legislation

hazard on that floodway.

- (3) Development consent must not be granted to development on flood prone land (other than development for the purposes of residential accommodation) unless the consent authority is satisfied that the development:
- (a) will not adversely affect flood behaviour and increase the potential for flooding to detrimentally affect other development or properties, and
 - (b) will not significantly alter flow distributions and velocities to the detriment of other properties or the environment, and
 - (c) will enable the safe occupation and evacuation of the land, and
 - (d) will not have a significant detrimental affect on the environment or cause avoidable erosion, siltation, destruction of riparian vegetation or a reduction in the stability of any riverbank or watercourse, and
 - (e) will not be likely to result in unsustainable social and economic costs to the flood affected community or general community as a consequence of flooding, and
 - (f) if located in the floodway, will be compatible with the flow of flood waters and with any flood hazard on that floodway.

[Top of page](#)