



Australian Consulting Engineers Pty Ltd

A.C.N: 084 059 941

A.B.N: 82 084 059 941

Ref: Anthony Hasham (10AH454)

CEJ Constructions Pty Limited
7 Charles Street
Parramatta NSW 2124

1 October 2014

181 James Ruse Drive, Camellia West – “Construction Exclusion Zones”

Dear Sirs,

I refer to my plans dated 26 June 2012 “Issue H”, in particular I refer to the notation on those drawings located at the edge of Environmental Cells 1, 2 and 3, which I have described as a “construction exclusion zone”.

To clarify, the “construction exclusion zone” of 7.0m is to be a clear zone during the construction of the environmental cells. This exclusion zone is to be maintained for the period from the commencement of bulk excavation until completion of construction of the environmental cells.

The purpose of the 7.0m Construction Exclusion Zone is to provide a factor of safety for any excavation wall collapse during excavation, installation of shoring and construction of the cell walls.

After the cells have been completely constructed, the “Construction Exclusion Zone” will thereby be redundant, and will not preclude any future building alignment from being located in this zone.

This clarification is now noted on the revised drawings, “Issue I” dated 1 October 2014.

Kind regards;

Australian Consulting Engineers Pty Ltd

Dr. Anthony S. Hasham

B.E., M.E., M.B.A. Ph.D., F.I.E. Aust., C.P.Eng., N.P.E.R., R.P.E.Q.
Civil/Structural Engineer, Accredited Certifier
Managing Director

HEAD OFFICE

Suite 2, 141 Concord Road,
North Strathfield, NSW, 2137
P. +61 2 9763 1500
F. +61 2 9763 1515

CANBERRA OFFICE

81A Denison Street,
Deakin, ACT, 2600
P. +61 2 6162 1735
F. +61 2 9763 1515

CENTRAL COAST OFFICE

Unit 49/26 Watt Street
Gosford, NSW, 2250
P. +61 2 4322 5222
F. +61 2 9763 1515

E. info@aceeng.com.au W. www.aceeng.com.au