

## Preliminary Enquiry – Response Letter



24 November 2021

Webform ref: 286537

ADW Johnson Pty Ltd  
Attention: Adam Gaul  
Via email: adamg@adwjohnson.com.au

Premises address: **NELSON BAY ROAD, BOBS FARM**

Ausgrid AE Reference: **700007563**

Dear Adam

I refer to your preliminary enquiry regarding the electricity connection at the above address and provide the following information.

- ☐ Ausgrid kiosk substation HS78867 feeding lot 51 DP1175028 is a 1000kVA kiosk substation with a 1200 amp low voltage supply to site. The peak load is 233 amps (23.01.2020). If the new development is the same developer/owner, the new site could be supplied from the existing site main switchboard providing compliance with AS3000 service rules can be achieved and electrician approves total load of 1200A for entire site. Site lots may need to be consolidated into 1 lot.
- ☐ Alternatively, the new site can be supplied by a new kiosk substation or street supply depending on the load required on site. The existing site and new site would remain segregated by the existing property line. Ideally lots 3622 and 2 would be consolidated.
- ☐ There is sufficient 11kV capacity for the expected new load.
- ☐ An extension/augmentation of the Ausgrid network is Contestable and requires the customer to engage accredited service providers to undertake the design and construction of the required works. Information on how to connect to the Ausgrid network can be found on our website at the following link: <https://www.ausgrid.com.au/Connections>
- ☐ Ausgrid is unable to provide costs or timeframes for Contestable works. However, accredited service providers may be able to provide the information.
- ☐ The electrical connection will require Ausgrid to provide auxiliary services that only Ausgrid can provide. The auxiliary services and the associated fee are detailed in the Ausgrid document **Alternative control services fee schedule**. The document is available on our website at the following link: <https://www.ausgrid.com.au/Connections/charges>
- ☐ To proceed further in obtaining a new or altered electrical connection to the property a Connection Application will need to be submitted. The various application forms are available on our website at the following link: <https://www.ausgrid.com.au/Connections>

It should be noted that the above advice is based on Ausgrid's policies and network status as of today and are subject to change.

Connections to the Ausgrid network are governed by a set of laws and rules referred to as the National Energy Customer Framework (NECF). Included in the NECF is the National Electricity Rules (NER). Under these rules, a binding contract may only be formed after a connection application is lodged and Ausgrid has made a connection offer in response to that application. Accordingly, to make arrangements for the electricity connection of the development to the Ausgrid network you should lodge a completed connection application.

Should you require any further information please contact me.

