












- NOTES:
1. TRENCH WIDTH MAY NEED TO BE INCREASED SUBJECT TO ACHIEVING ADEQUATE COMPACTION.
 2. MINIMUM PIPE COVER NOT UNDER ROADS = 300mm UNDO.
 3. THE CONTRACTOR SHALL ENSURE THAT THE SHORING OF TRENCHES IS INSTALLED AS REQUIRED BY STATUTORY REQUIREMENTS.
 4. ENSURE BACKFILLING OF TRENCHES NOT UNDER PAVEMENTS IS COMPACTED TO 95% SMD.

 MARTENS & ASSOCIATES PTY LTD Sustainable Solutions Environmental - Geotechnical - Civil Hydraulic - Wastewater Engineers 607 Leighton Place North Sydney NSW 1585 Phone: (02) 9476 8767 Fax: (02) 9476 8767 Email: info@martensassociates.com.au Internet: www.martensassociates.com.au	CLIENT/PROJECT		TITLE	DESIGNED:		DATUM:	SHEET	REV.	DESCRIPTION	DATE	ISSUED
			MACKENZIE ARCHITECTS / PACIFIC HWY TURRAMURRA	ADJ DRAWN: KT		H.M.L. HORIZONTAL RATIO 1:100 @ A1 1:200 @ A3	23 OF 24	1 2	DRAFT PLAN SET REVISED LAYOUT - AUGUST 2012	26.9.11 28.8.12	GT GT
		PROJECT MANAGER: GRAY TAYLOR	DRAWING NUMBER: P1002932/008/01		VERTICAL RATIO: 1:100 @ A1 1:200 @ A3		PAPER SIZE: A1 / A3				
THIS PLAN MUST NOT BE USED FOR CONSTRUCTION UNLESS SIGNED AND APPROVED BY PRINCIPAL CERTIFYING AUTHORITY											