

- The external wall adjacent the meeting room (no. SG371068) on ground floor is to achieve an FRL of at least 120/120/120, for a distance of at least 4m past the glazing to the meeting room.




Figure 14: Part Ground Floor Plan

- The glazed wall bounding the courtyard, which forms part of the fire wall separating the ward areas, is to be protected with internal wall wetting sprinklers.

The glazed walls bounding the courtyard adjacent the fire wall shall be protected with internal wall wetting sprinklers for a distance of at least 4m past the fire wall.

All glazing is to comprise of at least 6mm fixed toughened safety glass fitted in non-combustible frames.




Figure 15: Part Ground Floor Plan

### 8.3 REQUIRED FIRE SAFETY SYSTEMS

The following fire safety systems are to be installed throughout new Rehabilitation Unit:

- Wall Wetting Sprinklers - AS 2118.2 (2010).
- Fire Hydrants - BCA Clause E1.3, AS 2419.1 (2005).
- Fire Hose Reels - BCA Clause E1.4, 2441 (2005), and as varied within this Report.
- Portable Fire Extinguishers - BCA Clause E1.6, AS 2444 (2001), and as varied within this Report.
- Automatic Smoke Detection and Alarm System - BCA Spec E2.2a, AS 1670.1 (2004).
- Emergency Lighting - BCA Clauses E4.2 & E4.4, AS 2293.1 (2005).
- Exit Signs - BCA Clauses E4.5, E4.6 & E4.8, AS 2293.1 (2005).
- Sound System and Intercom System for Emergency Purposes - BCA Clause E4.9, AS 1670.4 (2004).

*NOTE: Refer to BCA Assessment Report for complete list of required fire safety systems / measures.*

### 8.4 SUMMARY OF ALTERNATIVE SOLUTIONS

Table 4 below provides a summary of the proposed Alternative Solutions and associated BCA Performance Requirements.

**Table 4: Summary of Alternative Solutions and Associated Performance Requirements**

Alternative Solution	Variation to BCA DTS Provisions	BCA Performance Requirements
1	To relocate an existing single storey demountable building of lightweight construction, where it will be located less than 3m from an existing building.	CP1, CP2
2	To construct a fire wall that is not continuous from the floor of the lowest level to the roof of the highest level.	CP2
3	<p>To have the glazed wall of the link to the new Rehabilitation Unit located within 4m of the existing hospital, which are to be considered as different fire compartments.</p> <p>To have the doorways to the new Rehabilitation Unit from the link fitted with glazed doors, in lieu of self-closing fire doors with an FRL of at least -/120/30.</p> <p>To have the glazed wall of a meeting room on ground floor located within 4m of the existing hospital, which are to be considered as different fire compartments.</p> <p>To have parts of the glazed walls bounding the courtyard within 4m of the 1 hour fire wall that separates the ward areas on ground floor.</p>	CP2
4	To not construct the egress stair on the southern side of the Rehabilitation Unit as a fire-isolated exit.	DP5



---

## **9.0 APPROACHES AND METHODS OF ANALYSIS**

---

### **9.1 APPROACHES**

The Fire Engineering Analysis will utilise an Absolute Approach to assess the proposed Alternative Solutions.

An Absolute Approach is where an Alternative Solution is assessed against the relevant Performance Requirements of the BCA, as permitted under Clause A0.5(b)(i) of the BCA.

### **9.2 METHODS OF ANALYSIS**

For each Alternative Solution, a Qualitative Analysis will be undertaken against the relevant Performance Requirements of the BCA, as permitted under Clause A0.9(b)(ii) of the BCA.

## 10.0 DESIGN FIRE SCENARIOS AND ACCEPTANCE CRITERIA

### 10.1 DESIGN FIRE SCENARIOS

#### *General*

To assess the Alternative Solutions, the following fire scenarios will be considered:

1. A fire within the relocated demountable building.
2. A fire within the existing building to the north of the relocated demountable building.
3. A fire within the existing building, immediately adjacent to and within 4m of the new Rehabilitation Unit.
4. A fire within the new Rehabilitation Unit, immediately adjacent to and within 4m of the existing building.
5. A fire within the ward area on ground floor adjacent to the glazed walls bounding the courtyard, and a fire within 4m of the 1 hour fire wall that separates the ward areas.

#### *Design Fires*

Considering that fire sprinklers will not be installed within the subject development, a fire can be expected to grow to flashover conditions involving a majority of the combustible items within the area of fire origin.

As a qualitative analysis will be used to assess the proposed Alternative Solutions, quantified design fires will not be adopted for the analysis.

### 10.2 ACCEPTANCE CRITERIA

Table 5 below provides a summary of the Acceptance Criteria when assessing the Alternative Solutions against the relevant Performance Requirements of the BCA.

**Table 5: Summary of Acceptance Criteria**

Alternative Solution	Acceptance Criteria
1	<p>The Alternative Solution is to be shown to comply with BCA Performance Requirement CP1 and CP 2, in terms of:</p> <ul style="list-style-type: none"> <li>• Maintaining structural stability in the event of fire to the degree necessary.</li> <li>• Avoiding the spread of fire and smoke to the degree necessary.</li> </ul> <p>The analysis will consider the provision of a 2 hour fire rated external wall to the southern side of the existing building, which will be located adjacent to the relocated demountable.</p>

Table 5: Summary of Acceptance Criteria

Alternative Solution	Acceptance Criteria
2	<p>The Alternative Solution is to be shown to comply with BCA Performance Requirement CP2, in terms of:</p> <ul style="list-style-type: none"> <li>Avoiding the spread of fire to the degree necessary.</li> </ul> <p>The analysis will consider the characteristics and use of the building, and the various fire safety systems installed to mitigate the spread of fire.</p>
3	<p>The Alternative Solution is to be shown to comply with BCA Performance Requirement CP2, in terms of:</p> <ul style="list-style-type: none"> <li>Avoiding the spread of fire to the degree necessary.</li> </ul> <p>The analysis will consider the characteristics and use of the building, and the various fire safety systems installed to mitigate the spread of fire.</p>
4	<p>The Alternative Solution is to be shown to comply with BCA Performance Requirement DP5, in terms of:</p> <ul style="list-style-type: none"> <li>Protecting evacuating occupants from a fire in the building to the degree necessary.</li> </ul> <p>The analysis will consider the characteristics of the stairway, and the level of separation provided from the remainder of the building whilst occupants are evacuating.</p> <p>The analysis will also consider the provision of an additional exit from ground floor, which exceeds the minimum DTS provisions of the BCA.</p>



## 11.0 FIRE ENGINEERING ANALYSIS (ALTERNATIVE SOLUTION 1)

### 11.1 GENERAL

This Fire Engineering Analysis will consider whether the proposed Alternative Solution will achieve compliance with Performance Requirements CP1 and CP2 of the BCA.

### 11.2 BCA DTS PROVISIONS

In relation to the subject development, Clause C1.1 of the BCA requires the single storey demountable building to be of Type C construction in accordance with Specification C1.1 of the BCA. For buildings of Type C construction, external walls that are located between 1.5m and 3m from a fire source feature must achieve an FRL of at least 60/60/60 from the outside only.

As the relocated demountable will be located between 1.5m and 3m of an existing building to the north, the northern external wall is required to achieve an FRL of at least 60/60/60 from the outside.

### 11.3 BASIS OF BCA DTS PROVISIONS

The Guide to the BCA states that the intent of BCA Clause C1.1 is ***"To establish the minimum fire-resisting construction required for Class 2-9 buildings"***.

The Guide to the BCA further states ***"When using an Alternative Solution, Part C1 does not apply and there is no need to refer to the types of construction"***.

### 11.4 PROPOSED VARIATION TO BCA DTS PROVISIONS

As detailed in Section 6, it is proposed to relocate an existing single storey demountable building of lightweight non fire rated construction, where it will be located less than 3m from an existing building. The external walls of the single storey demountable, which will be located within 3m of the existing building, will not achieve an FRL.

### 11.5 ASSESSMENT OF ALTERNATIVE SOLUTION

The assessment of the Alternative Solution considers the following:

#### ***Fire in Relocated Demountable***

- In the event of fire within the relocated demountable building, the external walls (which do not achieve an FRL) could fail due to the effects of fire under flashover conditions.

For the subject demountable, such a scenario is allowable under the DTS provisions of the BCA as the external walls in a building of Type C construction are not required to have an FRL from the inside.

However as the external wall to the adjacent existing building to the north will have an FRL of at least 120/120/120, fire spread from the relocated demountable to the existing building is expected to be mitigated.

### ***Fire in Existing Building (adjacent Relocated Demountable)***

- In the event of fire within the existing building to the north of the relocated demountable, fire spread to the relocated demountable is expected to be mitigated. This is due to the external wall of the existing building, facing the demountable, achieving an FRL of at least 120/120/120.

In consideration of the above, the provision of a 120/120/120 FRL to the external wall of the existing building (that faces the relocated demountable) will mitigate the potential for fire spread between the 2 buildings.

Refer also Figures 16 & 17 below.




Figure 16: Part Site Plan




Figure 17: Part Site Plan



## 11.6 SATISFYING BCA PERFORMANCE REQUIREMENTS

The proposed Alternative Solution has been assessed against BCA Performance Requirements CP1 and CP2, as shown in Tables 6 and 7 below.

**Table 6: Assessment of Compliance with the BCA Performance Requirement CP1**

Performance Requirement CP1	Discussion
<b><i>A building must have elements which will, to the degree necessary, maintain structural stability during a fire appropriate to -</i></b>	
(a) the function or use of the building; and	As discussed in Section 11.5.
(b) the fire load; and	Considered at least equivalent to the DTS provisions of the BCA.
(c) the potential fire intensity; and	Considered at least equivalent to the DTS provisions of the BCA.
(d) the fire hazard; and	Considered at least equivalent to the DTS provisions of the BCA.
(e) the height of the building; and	Considered at least equivalent to the DTS provisions of the BCA.
(f) its proximity to other property; and	As discussed in Section 11.5.
(g) any active fire safety systems installed in the building; and	Considered at least equivalent to the DTS provisions of the BCA.
(h) the size of any fire compartment; and	Considered at least equivalent to the DTS provisions of the BCA.
(i) fire brigade intervention; and	Considered at least equivalent to the DTS provisions of the BCA.
(j) other elements they support; and	Considered at least equivalent to the DTS provisions of the BCA.
(k) the evacuation time.	Considered at least equivalent to the DTS provisions of the BCA.

**Table 7: Assessment of Compliance with the BCA Performance Requirement CP2**

Performance Requirement CP2	Discussion
<b><i>(a) A building must have elements which will, to the degree necessary, avoid the spread of fire -</i></b>	
(i) to exits; and	N/A
(ii) to sole-occupancy units and public corridors; and	N/A
(iii) between buildings; and	As discussed in Section 11.5.
(iv) in a building.	N/A
<b><i>(b) Avoidance of the spread of fire referred to in (a) must be appropriate to -</i></b>	
(i) the function or use of the building; and	As discussed in Section 11.5.
(ii) the fire load; and	Considered at least equivalent to the DTS provisions of the BCA.
(iii) the potential fire intensity; and	Considered at least equivalent to the DTS provisions of the BCA.



Table 7: Cont'd

Performance Requirement CP2	Discussion
(iv) the fire hazard; and	Considered at least equivalent to the DTS provisions of the BCA.
(v) the number of storeys in the building; and	Considered at least equivalent to the DTS provisions of the BCA.
(vi) its proximity to other property; and	As discussed in Section 11.5.
(vii) any active fire safety systems installed in the building; and	Considered at least equivalent to the DTS provisions of the BCA.
(viii) the size of any fire compartment; and	Considered at least equivalent to the DTS provisions of the BCA.
(ix) fire brigade intervention; and	Considered at least equivalent to the DTS provisions of the BCA.
(x) other elements they support; and	Considered at least equivalent to the DTS provisions of the BCA.
(xi) the evacuation time.	Considered at least equivalent to the DTS provisions of the BCA.

## 12.0 FIRE ENGINEERING ANALYSIS (ALTERNATIVE SOLUTION 2)

### 12.1 GENERAL

This Fire Engineering Analysis will consider whether the proposed Alternative Solution will achieve compliance with Performance Requirement CP2 of the BCA.

### 12.2 BCA DTS PROVISIONS


In relation to the subject development, Clause C2.7 of the BCA requires a fire wall to extend through all storeys and spaces in the nature of storeys that are common to that part and any adjoining part of the building. The fire wall must also be carried through to the underside of the roof covering.

### 12.3 BASIS OF BCA DTS PROVISIONS

The Guide to the BCA states that the intent of BCA Clause C2.7 is ***“To explain that buildings separated by a fire wall maybe considered as fire compartments or be regarded as separate buildings”***.

In relation to the separation of buildings, the Guide to the BCA states: ***“C2.7(b) indicates the extent a fire wall divides a building into separate buildings for the Deemed-to-Satisfy Provisions of Sections C, D and E.***

***The fire wall must extend through all storeys and similar spaces which are common to the subject parts of the building, and any adjoining part of the building, through to the underside of any roof covering...”***





## 12.4 PROPOSED VARIATION TO BCA DTS PROVISIONS

As detailed in Section 6, it is proposed construct a fire wall that is not continuous from the floor of the lowest level to the roof of the highest level.

## 12.5 ASSESSMENT OF ALTERNATIVE SOLUTION

The assessment of the Alternative Solution considers the following:

- For the proposed building design, the firewall does not consist of a continuous vertical wall, but separate fire walls interconnected to a floor slab that achieves the same FRL. The fire walls are expected to act in a similar manner to that identified by Figure C2.7(1) from the Guide to the BCA, as outlined above.
- The minor horizontal component (i.e the floor slab) will achieve the required FRL of 120/120/120 for a fire wall, and is considered to prevent the spread of fire between the structures to an equivalent degree as complying vertical separation.
- For the new Rehabilitation Unit to be considered as a separate building to that of the existing building, a fire within the new building should not affect the existing building or vice versa. It is considered improbable that a fire will grow sufficiently to cause the failure of the fire separation walls provided between the 2 buildings for the following reasons:
  - Any openings or penetrations through the separating fire walls will be suitably protected and / or fire stopped in accordance with the relevant deemed to satisfy provisions of the BCA for a fire wall.
  - The doorways providing access between the 2 buildings will be protected with self-closing fire doors to AS 1905.1, with an FRL of at least -/120/30.
  - Given the proposed construction of the building and the fire safety systems to be installed, it is improbable that a fire will develop to a level that would prevent fire brigade intervention.

In consideration of the above, the proposed construction of the separating fire walls will mitigate the potential for fire spread between buildings to the degree necessary.

## 12.6 SATISFYING BCA PERFORMANCE REQUIREMENTS

The proposed Alternative Solution has been assessed against BCA Performance Requirement CP2, as shown in Table 8 below.

**Table 8: Assessment of Compliance with the BCA Performance Requirement CP2**

Performance Requirement CP2	Discussion
<b><i>(a) A building must have elements which will, to the degree necessary, avoid the spread of fire -</i></b>	
(i) to exits; and	N/A
(ii) to sole-occupancy units and public corridors; and	N/A
(iii) between buildings; and	As discussed in Section 12.5.
(iv) in a building.	As discussed in Section 12.5.

Table 8: Assessment of Compliance with the BCA Performance Requirement CP2

Performance Requirement CP2	Discussion
<b><i>(b) Avoidance of the spread of fire referred to in (a) must be appropriate to -</i></b>	
(i) the function or use of the building; and	Considered at least equivalent to the DTS provisions of the BCA.
(ii) the fire load; and	Considered at least equivalent to the DTS provisions of the BCA.
(iii) the potential fire intensity; and	Considered at least equivalent to the DTS provisions of the BCA.
(iv) the fire hazard; and	Considered at least equivalent to the DTS provisions of the BCA.
(v) the number of storeys in the building; and	Considered at least equivalent to the DTS provisions of the BCA.
(vi) its proximity to other property; and	As discussed in Section 11.5.
(vii) any active fire safety systems installed in the building; and	Considered at least equivalent to the DTS provisions of the BCA.
(viii) the size of any fire compartment; and	Considered at least equivalent to the DTS provisions of the BCA.
(ix) fire brigade intervention; and	Considered at least equivalent to the DTS provisions of the BCA.
(x) other elements they support; and	Considered at least equivalent to the DTS provisions of the BCA.
(xi) the evacuation time.	Considered at least equivalent to the DTS provisions of the BCA.



## 13.0 FIRE ENGINEERING ANALYSIS (ALTERNATIVE SOLUTION 3)

### 13.1 GENERAL

This Fire Engineering Analysis will consider whether the proposed Alternative Solution will achieve compliance with Performance Requirement CP2 of the BCA.

### 13.2 BCA DTS PROVISIONS

In relation to the subject development, Clause C3.3 of the BCA states that the distance between parts of external walls and any openings within them in different fire compartments separated by a fire wall must not be less than that set out in Table C3.3 (*being 4m for the subject building*), unless -

- those parts of each wall have an FRL not less than 60/60/60; and
- any openings protected in accordance with C3.4.

Clause C3.4 of the BCA nominates acceptable methods of protection that are required under Clause C3.3, and for windows include:

- External wall wetting sprinklers that are used with windows that are automatic closing or permanently fixed in the closed position.
- Fire rated windows with an FRL of at least -/60/-.
- Automatic closing fire shutters with an FRL of at least -/60/-.

In relation to the subject development, Clause C3.5 of the BCA states that a doorway in a fire wall must be protected by a single fire door or fire shutter which has an FRL of not less than that required by Specification C1.1 for the fire wall except that each door or shutter must have an insulation level of at least 30.

### 13.3 PROPOSED VARIATION TO BCA DTS PROVISIONS

As detailed in Section 6:

- It is proposed to have the glazed wall of the link to new Rehabilitation Unit located within 4m of the existing hospital, which are considered as different fire compartments.

Furthermore, it is proposed to have the doorway to the new Rehabilitation Unit from the link fitted with glazed doors, in lieu of self-closing fire doors with an FRL of at least -/120/30.

- It is proposed to have the glazed wall of a meeting room on ground floor located within 4m of the existing hospital, which are considered as different fire compartments.
- It is proposed to have parts of the glazed walls bounding the courtyard within 4m of the 1 hour fire wall that separates the ward areas on ground floor.





### Meeting Room

- In the event of fire within the new Rehabilitation Unit (refer Figure 19 below), the glazed wall of the meeting room is likely to crack and eventually “blow out” under flashover conditions, resulting in flames and hot gases venting through the opening.

As the wall to the adjacent building will have an FRL of at least 120/120/120, fire spread from the new Rehabilitation Unit to the existing building is expected to be mitigated.

Furthermore, heat from the hot gases venting through the openings are expected to dissipate to the atmosphere, with little or no impact on the adjacent building where the exposed wall achieves an FRL of at least 120/120/120.

- In the event of fire within the existing building (refer Figure 20 below), fire spread to the new Rehabilitation Unit is expected to be mitigated due to the wall of the existing building achieving an FRL of at least 120/120/120.




Figure 19: Part Ground Floor Plan




Figure 20: Part Ground Floor Plan

### Ward Area

- In the event of fire adjacent the glazed walls bounding the courtyard, forming part of or located adjacent to the fire wall (refer Figure 21 below), fire spread between compartments via the glazing is expected to be mitigated due to the provision of internal wall wetting sprinklers to the glazed walls.

The provisions of wall wetting sprinklers is expected to maintain the integrity of the glazing panels in the event of fire, thereby mitigating the spread of fire between compartments to the degree necessary.

The effect of wall wetting sprinklers is to provide a curtain of water over the glazing panels. The curtain of water serves 2 purposes; it cools the glazing to maintain its integrity in the event of fire, and provides attenuation to received radiation from a fire.




Figure 21: Part Ground Floor Plan



### 13.5 SATISFYING BCA PERFORMANCE REQUIREMENT

The proposed Alternative Solution has been assessed against BCA Performance Requirement CP2, as shown in Table 9 below.

**Table 9: Assessment of Compliance with the BCA Performance Requirement CP2**

Performance Requirement CP2	Discussion
<b><i>(a) A building must have elements which will, to the degree necessary, avoid the spread of fire -</i></b>	
(i) to exits; and	N/A
(ii) to sole-occupancy units and public corridors; and	N/A
(iii) between buildings; and	N/A
(iv) in a building.	As discussed in Section 13.4.
<b><i>(b) Avoidance of the spread of fire referred to in (a) must be appropriate to -</i></b>	
(i) the function or use of the building; and	As discussed in Section 13.4.
(ii) the fire load; and	Considered at least equivalent to the DTS provisions of the BCA.
(iii) the potential fire intensity; and	As discussed in Section 13.4.
(iv) the fire hazard; and	Considered at least equivalent to the DTS provisions of the BCA.
(v) the number of storeys in the building; and	Considered at least equivalent to the DTS provisions of the BCA.
(vi) its proximity to other property; and	N/A
(vii) any active fire safety systems installed in the building; and	As discussed in Section 13.4.
(viii) the size of any fire compartment; and	Considered at least equivalent to the DTS provisions of the BCA.
(ix) fire brigade intervention; and	Considered at least equivalent to the DTS provisions of the BCA.
(x) other elements they support; and	N/A
(xi) the evacuation time.	Considered at least equivalent to the DTS provisions of the BCA.

## 14.0 FIRE ENGINEERING ANALYSIS (ALTERNATIVE SOLUTION 4)

### 14.1 GENERAL

This Fire Engineering Analysis will consider whether the proposed Alternative Solution will achieve compliance with Performance Requirement DP5 of the BCA.

### 14.2 BCA DTS PROVISIONS

In relation to the subject development, Clause D1.3 of the BCA states that a stairway serving as a required exit within a patient care area must be constructed as a fire-isolated exit.

### 14.3 BASIS OF BCA DTS PROVISIONS

The Guide to the BCA states that the intent of BCA Clause D1.3 is ***"To indicate when fire-isolated stairways and ramps are required to enable safe egress in case of a fire"***.

The Guide to the BCA states that the purpose of fire-isolated exits in multi-storey buildings is to enable people to evacuate past a storey on fire.

### 14.4 PROPOSED VARIATION TO BCA DTS PROVISIONS

As detailed in Section 6, it is not proposed to construct the egress stair on the southern side of the new Rehabilitation Unit as a fire-isolated exit

### 14.5 ASSESSMENT OF ALTERNATIVE SOLUTION

The assessment of the Alternative Solution considers the following:

- The egress stair on the southern side of the Rehabilitation Unit, although discharging to the undercroft level, only serves a single level being ground floor. That is, the egress stair does not serve as a required exit from the undercroft level.
- The discharge point from the egress stair on the undercroft level is located more than 6m from the building containing openings. Therefore, the exposure of evacuating occupants to a fire within the undercroft level will be at least equivalent to the DTS provisions of the BCA.


Therefore occupants will not be evacuating through or past a storey on fire, which satisfies the intent of the BCA as outlined above.

- An alternative exit will be provided from the ward area on ground floor, on the northern side into the existing building. This exit, although not required under the DTS provisions of the BCA, will serve as an alternative exit.


Therefore if the southern egress stair becomes untenable, occupants can evacuate through the additional alternative exit.

In consideration of the above, it is not considered necessary to construct the egress stair on the southern side of the Rehabilitation Unit as a fire-isolated exit.





**Figure 22: Part Undercroft Level**



**Figure 23: Part Ground Floor Plan**

## 14.6 SATISFYING BCA PERFORMANCE REQUIREMENT

The proposed Alternative Solution has been assessed against BCA Performance Requirement DP5, as shown in Table 10 below.

**Table 10: Assessment of Compliance with the BCA Performance Requirement DP5**

Performance Requirement DP5	Discussion
<i>To protect evacuating occupants from a fire in the building exits must be fire-isolated, to the degree necessary, appropriate to -</i>	
(a) the number of storeys connected by the exits; and	As discussed in Section 14.5.
(b) the fire safety system installed in the building; and	Considered at least equivalent to the DTS provisions of the BCA.
(c) the function or use of the building; and	As discussed in Section 14.5.
(d) the number of storeys passed through by the exits; and	As discussed in Section 14.5.
(e) fire brigade intervention.	Considered at least equivalent to the DTS provisions of the BCA.



---

## 15.0 MANAGEMENT AND USE

---

### 15.1 CERTIFICATION OF FIRE ENGINEERING DESIGN

This Fire Engineering Report shall form part of the Fire Safety Schedule for the subject building, and shall be certified annually as part of the Annual Fire Safety Statement (AFSS).

### 15.2 BUILDING CHANGES AND MODIFICATIONS

Should the subject building undergo a change in use or classification, or be modified internally, the Fire Engineering Designs for the building are to be re-evaluated.

### 15.3 MAINTENANCE AND SERVICING

All fire safety measures installed throughout the subject building are to be maintained and serviced in accordance with the relevant Australian Standards and manufacturers guidelines, and be included in an AFSS.

---

## 16.0 CONCLUSION

---

A Fire Engineering Analysis has been undertaken for the construction of a new Rehabilitation Unit at Goulburn Hospital.

The Fire Engineering Analysis relates to:

- Fire resisting construction.
- Separation by fire walls.
- Separation of external walls and associated openings in different fire compartments.
- Doorways in fire walls.
- When fire-isolated stairways and ramps are required.

Based on the Fire Engineering Analysis presented in this report, it is the opinion of Impact Fire Pty Ltd that the proposed Alternative Solutions will satisfy BCA Performance Requirements CP1, CP2 and DP5, subject to the implementation of the Fire Engineering Scope of Works presented in the Executive Summary.



---

## APPENDIX A - LIST OF REFERENCED DRAWINGS

---

Table 11: List of Referenced Architectural Drawings

Drawing No.	Issue	Title	Revision Date
A2200	F	General Arrangement Plan - Undercroft	24-01-2012
A2201	H	General Arrangement Plan - Ground Floor	25-01-2012
A2700	D	Fire Compartments	14-11-2011

# MEMO



## Goulburn Hospital Sub Acute Unit

To: Dianne James, Goulburn Mulwaree Council  
Cc: Malcolm Hughes, SCA

---

From: Brian Geddes

Date: 15 February 2012

---

Re: DA No DA\0174\1112, Goulburn Base Hospital

---

Further to the recent correspondence regarding the Sydney Drinking Water Catchment SEPP for the above we wish to resubmit the MUSIC model based on reuse of the stormwater for irrigation and toilet flushing within the new unit.

The new model meets the criteria requirements of the SCA and request approval to proceed with the new arrangement within the development.

The reason for the change is that the client does not see the irrigation of the site around the helipad as an appropriate usage of the stormwater collection and has accepted that reuse for toilet flushing can be achieved without their earlier concerns of discolouring to the pans.

We hope this is acceptable and approval of the DA application can proceed.

Regards

Brian Geddes  
Aurora Projects  
0416 191 386