JOINT REGIONAL PLANNING PANEL

(Sydney West Region)

JRPP No	2015SYW097 - ADDENDUM TO ASSESSMENT REPORT
Date	11 February 2016
DA No.	DA/310/2015
LGA	Parramatta
Proposed development	Multi storey car park and associated works
Street address	1 Parramatta Park Land, Parramatta
Property Description	MS 80-3000
Applicant	Parramatta Leagues Club
Owner	Parramatta Park Trust
Recommendation	Deferred Commencement approval
Report by	Brad Roeleven, Executive Planner
,	<u>'</u>

1. Background

A report on this application was scheduled for consideration by the Sydney West Joint Regional Planning Panel (the Panel) on 9 December 2015. At that meeting, and following a request from the Chief Executive Officer of Parramatta City Council dated 8 December 2015, the Panel resolved to:

The purpose of this report is to supplement the original assessment by addressing relevant matters since 9 December 2015.

2. Matters addressed in this report

This report considers the following:

A submission by the applicant to Council dated 4 February 2016

DA/310/2015 Page 1 of 38

[&]quot;....defer the development application for an additional submission from Parramatta Council."

- A submission by Parramatta City Council to DA 310/2015 dated 13 January 2016
- A submission by the applicant to the Panel dated 7 December 2015;

2.1 Submission by the applicant to Council dated 4 February 2016

The original report recommends a deferred commencement approval requiring the removal of five upper levels of car park as the application and early traffic reports had failed to justify the supply of 1001 parking spaces. The justification for this approach is shown at <u>Parking</u> Supply pages 19-22 of the original report.

On 4 February the applicant submitted an additional letter from Parking and Traffic Consultants (PTC) providing an analysis of more recent parking survey data. The response seeks to address previous criticism of the early traffic reports and establish a more accurate picture of peak demand.

Parking surveys were undertaken on three days when there was activity at the stadium (Thursday 24th Dec 2015, Friday 1st Jan 2016 and Saturday 16th Jan 2016). Given that the demand for the car park exceeded supply on each of these days intercept surveys of members using the club were undertaken in conjunction with physical surveys of the car park. The letter concludes that given the number of days that there will be activity at the stadium it is reasonable to assume that the club will experience this level of demand regularly during the sports season (up to three times per month).

The Council's Service Manager, Traffic and Transport, has reviewed the information and has concluded that the report received on the 4 February adequately justifies the proposed 773 car spaces.

It is noted that the applicant wishes to remove the two basement levels of parking to achieve the 773 spaces, not including the 94 temporary surface spaces (letter to Council 18 December 2015 and reissued 4 February 2016).

2.2 Submission of Parramatta City Council to DA 310/2015 dated 13 January 2016

Background

No submissions were received following public notification of this development application. However, subsequent to publication of the assessment report, and ahead of the Panel's meeting for 9 December 2015, the Council at its meeting on 7 December 2015 made the following resolution:

"To request the Joint Regional Planning Panel to defer consideration of the development application until after the 14 December 2015, so that the Council can make a submission."

The Chief Executive Officer of Council subsequently provided a letter dated 8 December, 2015 to the Chair of the JRPP advising it of the Council's resolution.

DA/310/2015 Page 2 of 38

As noted at its meeting on 9 December 2015 the Panel then resolved to defer determination of the application until after it had received a submission from the Council.

At its meeting on 14 December 2015 Council further resolved:

"That Council support the application as lodged".

That resolution was then formalised via a submission of support for the application dated 13 January, 2016 (Attachment 1).

Review of the submission

The issues raised within that submission are summarised and addressed below:

Issue 1 This is an ideal location for additional car parking to support both the operation of the Club and the adjoining and nearby uses associated with the Parramatta stadium and Parramatta Park. The car park would be ideally located for the future Stadium as recently announced by the State government. Additional parking in this location would be supported by public transport with the proposed light rail route servicing this area of the City.

Response

It is agreed that, in terms of site planning and operational considerations, the proposed location of the parking facilities for the Club is appropriate. The additional information provided by the applicant now justifies the reduced demand being sought by the applicant and the scheme can be supported.

Issue 2 The location and design of the car park means it will have no impact upon the heritage significance of adjoining properties nor is it within an area which will affect the world heritage values of Old Government House and its domain.

Response

Agreed - refer to section 8.7 of the original assessment report.

2.3 Submission of applicant to the Panel, dated 7 December 2015

This submission (Attachment 2) was prepared after publication of Council's assessment report, and before the Panel's meeting on 9 December 2015, and comprises multiple documents from the applicant's project team.

Council technical staff did not have time evaluate this submission prior to the meeting of 9 December, 2015. Those documents have now been reviewed, and key documents that have not been superseded by the above assessment are discussed below:

Letter from Parramatta Leagues Club 7.12.15		
Issue - Proposed conditions	Response	

DA/310/2015 Page 3 of 38

Proposed conditions of consent are problematic as it is not practical to not use heavy machinery or cease work for 3 months

Comment – The Grey Headed Flying Fox (GHFF) colony adjacent to the site is listed as 'Endangered' under the NSW Threatened Species Conservation Act 1995 and Commonwealth Environment Protection & Biodiversity Conservation Act 1999. Condition 6 in the original assessment report was drafted to be consistent with the applicant's own expert report (Cumberland Ecology -26.11.15), the only exception being 6(c) which prevents certain works during the GHFF breeding period. (Sept- Nov).

Given that the applicant has agreed to remove the basement levels, the Council's Open Space & Natural Area Planner agrees to revising condition 6(c) as drafted in the recommendation to this report. However if the application is approved with the basement retained, then Council's Open Space & Natural Area Planner requires condition 6(c) to remain unaltered.

Proposed conditions to reduce the number of spaces make the project uneconomical as the interruption to club business operations outweigh the return for a car park.

Noted – this is matter for the applicant.

It is not realistic, nor legally accurate to take the view there is no link between the Club and the stadium regarding parking or permissibility. The Club leases the stadium for Eels home games and therefore the stadium forms part of the club's facilities for members and guests. Therefore members visiting the stadium constitutes a permissible use and it is unrealistic to suggest otherwise

Disagree – The stadium is:

- On land which was excised from Parramatta Park;
- Managed by Venues NSW under a specific Act
- On land that is separate to that of the Club and which is not a part of this application.
 The 'owners consent' provided with this application does apply to the stadium lands.

Further discussion on the issue of permissibility is provided below.

Issue - Significance of the club

Response

A district rugby league competition was formed in 1910. Parramatta Eels was founded in 1947. The Parramatta Leagues Club was granted a liquor license in 1959, and the Club is the sole owner of the Parramatta Eels NRL franchise. The long term stability of the Club depends upon providing suitable and profitable facilities for member.

Noted – However this is not a matter for consideration in the assessment of the application.

DA/310/2015 Page 4 of 38

Janua Economia quatainahilitu	Beanance
Issue – Economic sustainability	Response
The Club has a lease until 2049, with an option to renew for a further 49 years. Future profitability is function of revenue growth and diversification. Lack of parking is critical to retaining and supporting new growth. It is obvious the Club needs additional parking given its tenure, history and annual growth in membership. That quantum of parking should consider the Club's tenure of the site.	Additional traffic work has since been provided and the provision of 773 parking spaces can now be justified.
Issue – Car parking	Response
The car park regularly exceeds its capacity as reflected in responses to a members' survey expressing difficulty in finding parking, and the low levels of revenue increases experienced by the Club.	As above.
With expected growth in the surrounding area, we need to plan against assuming those areas will be able to accommodate parking demand for members.	Noted.
Whilst a survey of current usage shows periods when the car park is not fully occupied the survey will not capture the number of person who choose not to attend the site because of parking difficulties. It is short sighted to fail to consider the predictable future demands of the Club.	Additional traffic work has since been provided and the provision of 773 parking spaces can now be justified.
Issue – Planned development	Response
A separate DA will be progressed for a leisure centre consistent with securing additional attractions for sustained growth. That DA is the result of years of masterplaning.	Noted

Letter from Hassell - 7.12.15			
Issue – Design amendment to achieve 773 spaces	Response		
This submission provides further architectural support relative to the applicant's offer to delete the two basement levels to achieve a reduced parking supply of 773 spaces within the multistorey car park.	deleting basement levels for the purposes of reducing the number of parking spaces.		

DA/310/2015 Page 5 of 38

overall parking supply.

The submission identifies key design criteria that would be maintained by adopting this approach instead of that nominated at the recommendation to the assessment report – being to reduce parking supply by deleting levels 2-7 of the structure.

Letter from Hall and Wilcox - 7.12.15				
Issue - Permissibility	Response			
This part of the submission is a legal opinion from Hall and Wilcox (Attachment 2) which in summary contends:	The Hall and Wilcox opinion was reviewed by Council's Legal Services Manager, (Attachment 3). In summary that opinion contends:			
 Clubs, stadiums and recreational facilities are all permitted uses within the RE2 Private Recreation zone of Parramatta LEP 2011; The proposed car park is ancillary to all three permitted uses i.e. – the Club, stadium and recreation facilities; Therefore the car park can be used by patrons of all three developments; and The payment of a fee to operate the car park is not relevant. 	 There is inadequate detail to support the proposition that the car park would be ancillary to the Park; The contention that the link between the club and the stadium is achieved because both uses are on land with the same zone, and both are permissible uses within that zone, is incorrect; and The stadium is an independent use on a parcel of land that was excised from the Park. The stadium land does not form part of the DA and therefore the car park is not ancillary to the use of the stadium land. 			

3 Summary and conclusion

Consideration of the additional traffic information provided by the applicant demonstrates that the club generates sufficient demand to justify the provision of 773 parking spaces in a new car park and the retention of 94 spaces within the altered surface car park.

Given that it is now the intention to remove the two levels of basement parking to achieve the agreed parking supply the previous deferred commencement conditions as proposed in the original report needs to be altered.

RECOMMENDATION - DEFERRED COMMENCEMENT APPROVAL

A. Pursuant to Section 80(3) of the Environmental Planning and Assessment Act, 1979:

That The Sydney West Joint Regional Planning Panel, as the consent authority, grant deferred commencement development consent to Development Application 310/2015 subject to the conditions in Schedule 1.

DA/310/2015 Page 6 of 38

Following full satisfaction of the matters in Schedule 1 within a period of 24 months from the date on the Notice of Determination the consent will become operative, subject to the conditions in Schedule 2.

Physical commencement is to occur within five (5) years from the date on the Notice of Determination.

DEVELOPMENT APPLICATION 310/2015

SCHEUDLE 1 – DEFERRED COMMENCEMENT CONDITIONS

- Amended architectural plans, to the satisfaction of the Director, Strategic Outcomes and Development, shall be submitted to Council which satisfy the following requirements:
 - a) A total of 867 onsite parking spaces, comprising 94 temporary surface spaces and 773 spaces within the multi-storey parking facility.
 - b) The design shall be amended to reconfigure the stairs to the Basement 1 fire pump room to avoid creating a concealed stairwell;
 - The external presentation of the facility shall maintain the composition of external materials and finishes as shown on the plans lodged with the application;
 - d) The twisted steel façade screening treatment shall be extended to enclose and secure the western edge of the ground level, returning along the northern edge to meet the driveway exit;
 - e) The design of the Eels Place extension shall be modified generally in accordance with the arrangements in the submission by Taylor Thomson Whitting, dated 26 October, 2015, to ensure a continuous, unobstructed 2.5m wide footpath is provided along the northern boundary connecting O'Connell Street with Parramatta Park; and
- 2. Amended landscape plans, to the satisfaction of the Director, Strategic Outcomes and Development, shall be submitted to Council which satisfy the following requirements:
 - a) Delete the landscape mounding treatment along the southern and western edges
 of the site in favour of treatment which maintains clear lines of sight from Little
 Coogee walk to the car park;
 - b) Improved delineation of pedestrian areas within the transition zone between the car park and the Club entry; and

DA/310/2015 Page 7 of 38

- c) Plantings along the northern edge of Eels Place new plantings shall be within a linear garden bed instead of comprising individual plantings.
- 3. An amended Plan Of Management, to the satisfaction of the Director, Strategic Outcomes and Development, shall be submitted to Council which satisfies the following requirements:
 - a) The version and date of the Plan shall be clearly noted on each page;
 - b) The Plan shall be unambiguous that parking is only for the use of club staff, club members or visitors to the club and that no public parking is permitted;
 - c) The Plan shall state that no commercial operator will be engaged by the Club for the purpose of managing the car park; and
 - d) The Plan shall state that the car park is only to be used and operated in accordance with the consent granted to Development Application 310/2015, and as modified by any future approval granted by Council.
- 4. A Plan of Management shall be submitted for service vehicles attending the existing loading dock.
- 5. A revised Detailed Cost Estimate shall be provided relative to the scope of the project as amended by the recommendation to this report.

SCHEUDLE 2 - CONDITIONS TO APPLY UPON SATISFACTION OF SCHEDULE 1.

GENERAL MATTERS

1. The development is to be carried out in accordance with the following plans endorsed with Council's Stamp as well as the documentation listed below, except where amended by other conditions of this consent and/or any plan annotations:

Architectural plans

Drawing No.	Prepared By	Dated
TO BE COMPLETED		
FOLLOWING SATISFACTION OF		
SCHEDULE 1		

DA/310/2015 Page 8 of 38

Landscape plans

Document(s)	Prepared By	Dated
TO BE COMPLETED		
FOLLOWING SATISFACTION OF		
SCHEDULE 1		

Note: In the event of any inconsistency between the architectural plan(s) and

the landscape plan(s) and/or stormwater disposal plan(s) (if applicable), the architectural plan(s) shall prevail to the extent of the inconsistency.

Reason: To ensure the work is carried out in accordance with the approved plans.

 The development shall be completed in accordance with the General Terms of Approval issued by the Department of Primary Industries (Water) dated 17 July, 2015, a copy of which is attached with this Notice.

No Construction Certificate shall be issued until such time as all relevant conditions of those GTA's has been satisfied. The development shall otherwise be undertaken in accordance with those GTAs and the terms of this Determination.

- 3. This application grants consent to the provision of 867 onsite parking spaces, comprising 773 within the multi storey structure, and 94 temporary surface parking spaces. The 94 surface parking spaces are temporary only, and are not entitled to be replaced in conjunction with any future development applications. Any future increases in parking shall be determined only with regard to demand associated with proposed additional floor space.
- 4. All building work must be carried out in accordance with the current provisions of the Building Code of Australia (National Construction Code).

Reason: To comply with the Environmental Planning & Assessment Act 1979, as amended and the Environmental Planning & Assessment Regulation 2000.

5. Prior to commencement of any construction works associated with the approved development (including excavation if applicable), it is mandatory to obtain a Construction Certificate. Plans, specifications and relevant documentation accompanying the Construction Certificate must include any requirements imposed by conditions of this Development Consent.

Reason: To ensure compliance with legislative requirements.

DA/310/2015 Page 9 of 38

- 6. To ensure that impacts upon the Grey-headed Flying Fox colony are minimised the development shall be undertaken to satisfy the following requirements:
 - a) No materials, vehicles, refuse skips and the like are to be placed or stored within 25m of the Grey-headed Flying Fox Camp.
 - b) A suitably qualified ecologist is to undertake regular monitoring of the Greyheaded Flying Fox Camp for the duration of works in accordance with a monitoring plan to be approved by Councils Open Space and Natural Resources delegate prior to the commencement of works.
 - c) Construction works involving the use of heavy machinery and/or large plant equipment above the level of the adjacent brick wall can only be undertaken during September to November provided all such equipment is located behind the car parking structure to the south east of the construction site.
 - d) Placement of large machinery and plant equipment must be minimised in the north-western portion of the development site.
 - e) Pump silencers are to be used on all large concrete pumps to the southeast side of the construction site
 - g) Construction works are to be minimised during dawn and dusk periods when Grey-headed Flying Fox are leaving or returning to their camp.
 - h) Lighting is to be designed to minimise light spill into the ecologically sensitive river riparian corridor to prevent disturbance of the Grey-headed Flying Fox camp.

Reason: To ensure protection of endangered species and minimise the impacts of the development.

- 7. The development must be constructed within the confines of the property boundary. No portion of the proposed structure, including footings/slabs, gates and doors during opening and closing operations must encroach upon Council's footpath area or the boundaries of the adjacent properties.
 - **Reason:** To ensure no injury is caused to persons and the building is erected in accordance with the approval granted within the boundaries of the site.
- Demolition work must be carried out in accordance with Australian Standard 2601-2001 - Demolition of Structures and the requirements of the NSW WorkCover Authority.

Reason: To ensure appropriate demolition practices occur

8.

10. Following issuing of any operative consent for the site physical commencement must occur in accordance with the requirements of Section 95(4) of the Environmental Planning and Assessment Act within 5 years of the date of the issue of the deferred commencement consent. In this regard should physical commencement not occur by (insert date 5 years from issue of deferred consent) the consent will lapse.

Reason: To provide certainty to the community as to when physical commencement must occur.

DA/310/2015 Page 10 of 38

PRIOR TO THE ISSUE OF A CONSTRUCTION CERTIFICATE

- 11. Prior to the release of any Construction Certificate the following action shall be completed:
 - (a) Preparation of a Stage 2 Environmental Site Assessment to address the data gaps in that Stage 1 report, by Environmental Investigation Services lodged with application (Ref: E28152KHrpt dated 18 March 2015);
 - (b) Prepare a Remediation Action Plan (RAP) to outline remedial measures for the site or an Environmental Management Plan (EMP) for the ongoing management of contamination remaining on site.
 - (c) Undertake those works identified within the RAP or EMP which must be completed before works can otherwise commence;
 - (d) Provide the Principal Certifying Authority with a Validation Assessment (VA) report on completion of any remediation works which confirms the site is suitable for the approved by this Notice.
- 12. The applicant shall obtain an approval under section 90 of the National Parks and Wildlife Act 1974 for the removal of aboriginal archaeological evidence (aboriginal Heritage Impact Permit).
 - If archaeological evidence of aboriginal occupation or resource acquisition are recovered then interpretation detailing the sites use shall be required, subject to consultation with local Aboriginal groups. Measures to implement interpretation of the archaeological evidence shall be submitted to and approved by Council, and all measures implemented prior to the issue of an Occupation Certificate.
- 13. The applicant shall obtain an approval under section 140 of the Heritage Act 1977 for the removal of aboriginal archaeological evidence.
 - If archaeological evidence of Government Farm, the Government Watermill or substantial evidence of associated with the early use of Parramatta Park are recovered then interpretation detailing these historic phases shall be required. Measures to implement interpretation of the archaeological evidence shall be submitted to and approved by Council, and all measures implemented prior to the issue of an Occupation Certificate
- 14. The Construction Certificate is not to be issued unless the Certifying Authority is satisfied the required levy payable, under Section 34 of the Building and Construction Industry Long Service Payments Act 1986, has been paid.

Reason: To ensure that the levy is paid.

15. All building work must be carried out in accordance with the current provisions of the Building Code of Australia (National Construction Code).

Reason: To comply with the Environmental Planning and Assessment Act 1979, as amended and the Environmental Planning and Assessment Regulation 2000.

DA/310/2015 Page 11 of 38

16. A monetary contribution comprising [amount to be inserted upon satisfaction of Schedule 1, condition 4] is payable to Parramatta City Council in accordance with Section 94A of the Environmental Planning and Assessment Act 1979 and the Parramatta Section 94A Development Contributions Plan (Amendment No. 4). Payment must be by EFTPOS, bank cheque or credit card only.

The contribution is to be paid to Council prior to the issue of a construction certificate.

The contribution levy is subject to indexation on a quarterly basis in accordance with movements in the Consumer Price Index (All Groups Index) for Sydney issued by the Australian Statistician. At the time of payment, the contribution levy may have been the subject of indexation.

Parramatta Section 94A Development Contributions Plan (Amendment No. 4) can be viewed on Council's website at:

http://www.parracity.nsw.gov.au/build/forms and planning controls/developer contributions

Reason: To comply with legislative requirements.

17. All outdoor lighting must comply with the relevant provisions of ASINZ1158.3: 1999 Pedestrian Area (Category P) Lighting and AS4282: 1997 Control of the Obtrusive Effects of Outdoor Lighting.

Details demonstrating compliance with these requirements must accompany the Construction Certificate application and be to the satisfaction of the Certifying Authority.

Reason: To provide high quality external lighting for security without adverse effects on public amenity from excessive illumination levels.

18. Access and services for people with disabilities shall be provided to the 'affected part' of the building in accordance with the requirements of the Access to Premises Standard 2010 and the National Construction Code 2013. Detailed plans, documentation and specification must accompany the application for a Construction Certification to the satisfaction of the Certifying Authority. To this end regard shall also be had for the recommendations within the report accompanying the application by Morris-Goding Accessibility Consulting dated14 April, 2015.

Reason: To ensure the provision of equitable and dignified access for all people in accordance with disability discrimination legislation and relevant Australian Standards.

19. An Environmental Enforcement Service Charge must be paid to Council prior to the issue of a Construction Certificate. The fee will be in accordance with Council's adopted 'Fees and Charges' at the time of payment.

Note: Council's Customer Service Team can advise of the current fee and can

be contacted on 9806 5524.

Reason: To comply with Council's adopted Fees and Charges Document and to ensure compliance with conditions of consent.

DA/310/2015 Page 12 of 38

20. An Infrastructure and Restoration Administration Fee must be paid to Council prior to the issue of a Construction Certificate.

The fee will be in accordance with Councils adopted 'Fees and Charges' at the time of payment.

Note: Council's Customer Service Team can advise of the current fee and can

be contacted on 9806 5524.

Reason: To comply with Council's adopted Fees and Charges Document and to

ensure compliance with conditions of consent.

21. A noise management plan must be submitted to Council for approval prior to any work commencing and complied with during any construction works. The plan must be prepared by a suitably qualified person, who possesses qualifications to render them eligible for membership of the Australian Acoustic Society, Institution of Engineers Australia or the Australian Association of Acoustic Consultants.

The plan must include, but not be limited to the following:

- (a) Confirmation of the level of community engagement that has, is and will be undertaken with the Building Managers/occupiers of the main adjoining noise sensitive properties likely to be most affected by site works and the operation of plant/machinery particularly during the demolition and excavation phases.
- (b) Confirmation of noise, vibration and dust monitoring methodology that is to be undertaken during the main stages of work at neighbouring noise sensitive properties during the main stages of work at neighbouring noise sensitive
- (c) What course of action will be taken following receipt of a complaint concerning site noise, dust and vibration?
- (d) Details of any noise mitigation measures that have been outlined by an acoustic engineer or otherwise that will be deployed on site to reduce noise impacts on the occupiers of neighbouring properties to a minimum.
- (e) What plant and equipment is to be used on the site, the level of sound mitigation measures to be undertaken in each case and the criteria adopted in their selection taking into account the likely noise impacts on the occupiers of neighbouring properties and other less intrusive technologies available.

Reason: To maintain appropriate amenity to nearby occupants.

22. In accordance with Section 80A(6)(a) of the Environmental Planning and Assessment Act 1979, security bonds payable to Council for the protection of the adjacent road pavement and public assets during construction works. The bond(s) are to be lodged with Council prior to the issue of any application/approval associated with the allotment, (being a Hoarding application, Construction Certificate) and prior to any demolition works being carried out where a Construction Certificate is not required.

The bond may be paid, by EFTPOS, bank cheque, or be an unconditional bank guarantee.

Should a bank guarantee be lodged it must:

(a) Have no expiry date;

DA/310/2015 Page 13 of 38

- (b) Be forwarded directly from the issuing bank with a cover letter that refers to Development Consent DA 310/2015;
- (c) Specifically reference the items and amounts being guaranteed. If a single bank guarantee is submitted for multiple items it must be itemised.

Should it become necessary for Council to uplift the bank guarantee, notice in writing will be forwarded to the applicant fourteen days prior to such action being taken. No bank guarantee will be accepted that has been issued directly by the applicant.

Bonds shall be provided as follows:

Bond Type	Amount
Development Site Bond and Bank Guarantees	\$20,000

A dilapidation report is required to be prepared prior to any work or demolition commencing. This is required to be submitted to Parramatta City Council with the payment of the bond/s.

The dilapidation report is required to document/record any existing damage to kerbs, footpaths, roads, nature strips, street trees and furniture within street frontage/s bounding the site up to and including the centre of the road.

Reason: To safe guard the public assets of council and to ensure that these assets are repaired/maintained in a timely manner so as not to cause any disruption or possible accidents to the public.

23. The building must include a flood warning alarm system activated by a float valve. Details must be provided with the Construction Certificate plans and documentation to the satisfaction of the Certifying Authority.

Reason: To ensure the flood warning system is installed.

24. Retaining wall for excavation shall be constructed when cut or fill exceeds 600mm. Where necessary to prevent damage to the adjoining properties all approved retaining walls associated with the approved development are to be constructed up to the construction of the ground floor.

Reason: To prevent damage to the adjoining properties.

25. The approved plans must be submitted to a Sydney Water Quick Check agent or Sydney Water Customer Centre to determine whether the development will affect Sydney Water's sewer and water mains, storm water drains and/or easements, and if further requirements need to be met. This process will result in the plans being appropriately stamped.

The Principal Certifying Authority must ensure the plans are stamped by Sydney Water prior to the issue of any Construction Certificate and works commencing on site.

Notes: For Quick Check agent details please refer to the web site www.sydneywater.com.au – see Building and Developing – then Quick Check or telephone 13 20 92. For Guidelines for Building Over/Adjacent

DA/310/2015 Page 14 of 38

to Sydney Water Assets - see Building and Developing - then Building and Renovating or telephone 13 20 92.

Reason: To ensure the requirements of Sydney Water have been complied with.

- 26. No work shall commence on the storm water system until the detailed final storm water plans have been approved by the Principal Certifying Authority. Prior to the approval of storm water drainage plans, the person issuing the Construction Certificate shall ensure that:
 - (a) The final drainage plans are consistent with the submitted Drainage Plans i.e. the drawing titled ""Stormwater Plan", (Drawing reference # SKC04), Revision "P10" dated 09/10/2015 prepared by Taylor Thomson Whitting (note: number of sheets, revision number and date will change subject to amendments on the plan), together with the notes and rectification as required address the issues.

i. Basement car-park drainage plan and pump-out tank details

The details of the drainage plan for the basement level car parks including the basement pump-out tank layout and cross-sectional details should be prepared and included as a part of the stormwater plan.

ii. Hydraulic grade line

The sectional profile (long-section) of the water quality treatment devices, OSD tank/system and the downstream disposal point should show respective levels and the hydraulic grade line up to the disposal location (connection to Council's stormwater pipe). The hydraulic grade line should be appropriate for proper hydraulic functionality of the systems.

iii. Appropriate ventilation for the OSD underground tanks

The OSD tanks lack proper ventilation. Appropriate ventilations need to be provided by additional openings. The spacing of the openings should be not more than 5m centres.

iv. Inconsistency between the stormwater plan and architectural plans.

Any inconsistency between the stormwater plan and other plans shall be eliminated. The amendments made on the stormwater plan shall be incorporated into other plans as well.

Note: The referenced stormwater Plans shall be amended to incorporate the rectification requirements (if any) and address the above issues prior to submission with the application for Construction Certificate to the Principal Certifying Authority for approval.

(b) The proposed On-Site Detention (OSD) System has been designed by a suitably qualified Hydraulic Engineer, in accordance with the Upper Parramatta River Catchment Trust "On-Site Detention Handbook" and Council's stormwater Drainage Guidelines.

DA/310/2015 Page 15 of 38

- (c) The OSD design achieves, when using the Extended/Flood detention method (4th edition of UPRTC's handbook), the Site Reference Discharge (Lower Storage), SRD_L of 40 I/s/ha, Site Storage Requirement (Lower Storage) SSR_L of 300 m³/ha and Site Reference Discharge (Upper Storage), SRD_U of 150 I/s/ha, Site Storage Requirement (Total) SSR_T of 455 m³/ha with the primary storage (Extended Detention) volumes of 318.5m³, secondary storage (Flood Detention) of 164.5m³ and with Total Storage of at least 483m³ as specified on the OSD design calculation sheet.
- (d) The wall of the OSD tanks are to be constructed of reinforced cement concrete (RCC) or solid brick or concrete, with waterproofing and water retaining capability to comply with Australian Standard: AS3600-2009-concrete structures and AS3700-2001-Masonry structures. The base of the OSD tank shall be constructed of RCC slab. No other construction materials other than those specified in this paragraph shall be used to construct the OSD tank. Failure to comply with the requirements in this condition will result in Council issuing an order to the Applicant requiring demolition of any non-complying components and reconstruction with complying materials.
- (e) Detailed Stormwater plans with cross sectional details of control pit and the OSD storage areas; pits etc., the OSD Detailed Design Submission (Form B9) and OSD Detailed Calculation Summary Sheets are to be submitted with the documentation accompanying he construction certificate application.
- (f) A calculation table showing the available storage volume with the pyramid volume and prismatic volume calculation method is to be shown on the plan.
- (g) Changes or alterations to the approved design are not permitted. Any changes, other than that are of minor nature (such as minor relocation of pits and pipes), or the changes that affect the approved landscaping require prior approval from the council.

Reason: To minimise the quantity of storm water run-off from the site, surcharge from the existing drainage system and to manage downstream flooding.

27. As the underground OSD tank forms the OSD storage, the tank structures shall be designed and certified by a Certified Practicing Structural Engineer, taking into account of the structural loads including dead load and live load from the above and surrounding areas/structures, which exert load on the tank structures. The principal certifying authority shall ensure that the designer has taken account of all loads influencing the tank structures, duly certified and provided the structural design certificate.

Upon completion of construction, a Certified Practicing Engineer to the satisfaction of the principal certifying authority shall certify the work. The principal certifying authority shall ensure that a practicing certified Engineer upon completion of the works duly certifies the construction works.

Reason: To ensure that the structural stability of the underground tank structure.

DA/310/2015 Page 16 of 38

28. The stormwater management systems are designed in accordance with the water sensitive urban design principles and shall comply with the **section 3.3.6 of Parramatta City Council's Development Control Plan 2011**. The quality of the stormwater flow from the developed site shall be improved to achieve following pollutant retention target prior to discharge into the council's drainage/ creek system. The designer shall ensure and certify that the stormwater management system will achieve these following objectives.

Gross Pollutants: 90% reduction in the post development mean annual

load of total gross pollutant load (greater than 5mm)

Total Suspended Solids: 85% reduction in the post development mean annual

load of Total Suspended Solids (TSS)

Total Phosphorus: 60% reduction in the post development mean annual

load of Total Phosphorus (TP)

Total Nitrogen 45% reduction in the post development mean annual

load of Total Nitrogen (TN)

Hydrocarbons, motor oils,

oil and grease etc. No visible oils for flows up to 50% of the one-year

ARI peak flow specific for service stations, depots, vehicle body repair workshops, vehicle repair stations, vehicle sales or hire premises, car parks associated with retail premises, places of public worship, tourist and visitor accommodation,

registered clubs and pubs

Reason: To ensure that the water quality management

29. As a part accomplishment of Water Sensitive Urban Design principles under section 3.3.6.1 of Parramatta City Council Development Control Plan 2011, the following pollution reduction and improvement in stormwater quality measures shall be implemented in accordance with the stormwater plan. Special consideration shall be given to the consistency in the Hydraulic Grade line (HGL) at various critical points of each components.

i. High-Flow bypass chamber for the Filtration Units

The filtration system is to treat the "First Flush" runoff which contains high concentration of pollutant i.e. the flow equivalent to the stormwater runoff generated from 1 in 3 month's storm event with a duration equivalent to time of concentration (t_c) for that sub-catchment.

(Note: Flows generated from the runoff event higher than this, is generally considered, to contain low concentration of pollutant due to dilution. Hence, to direct the "First flush" into the filtration system and bypass the excess flow directly into the OSD system, a high-flow bypass chamber shall be installed at the upstream side of the filtration system).

The dimensions of the chamber, size of orifice shall be in accordance with that shown on the approved plan. The invert level of chamber floor and outlet pipe shall higher than the downstream water level. No variations to the approved parameters shall be permitted unless the requirements are demonstrated for justification.

DA/310/2015 Page 17 of 38

ii. Filtration Units/ system

As a component of the Stormwater Quality Improvement Devices (SQID's) the filtration system, shall have sufficient flow and loading capacity appropriate for the treatment of inflow (first flush) and shall be installed in accordance with the manufacturer's installation instruction. The size (capacity) of the filtration system including holding chamber (if any) shall be such that no overflow of the untreated portion of the first flush occurs that bypass treatment system.

No variation in the levels of the various components of the filtration units shall be accepted unless the requirements are demonstrated. The notes and rectification requirements as annotated on the approved plan shall be incorporated with the details of the proposed units which shall be submitted for the approval of the Principal Certifying Authority prior to the determination of the Construction Certificate. The certifier shall ensure that the designer has designed the unit(s) in accordance with the manufacturer's/ supplier's specifications and complied with all the requirements specified by the manufacturer/ supplier of the unit(s) and incorporated all the notes and rectification requirements as annotated on the approved plan.

The installation shall be carried out in accordance with the manufacturer's installation specification. Upon completion of installation, installation completion certification and performance certificate shall be obtained from the manufacturer and a copy be submitted to Council.

iii. Standard Operation and maintenance procedure

"Standard Operation & Maintenance Procedure Manual" with the "operation procedure and maintenance schedule" for each of the component and the system as a whole shall be prepared and submitted to the Principal certifying authority for its approval. The certifier shall ensure that a copy of the manual shall be submitted to the council prior to issue of the Construction Certificate. Provisions shall be made to ensure that the occupant and/or the person/ body responsible for maintenance of the Stormwater system shall obtain a copy of the manual.

Reason: To ensure that the water quality management measures are implemented.

30. A heavy duty vehicular crossing shall be constructed in accordance with Council's Standard Drawing numbers DS9 & DS10 at the entry and exit to the car-park. Details must accompany an application for a Construction Certificate to the satisfaction of the Certifying Authority.

A Vehicle Crossing application must be submitted to Council together with the appropriate fee as outlined in Council's adopted Fees and Charges prior to any work commencing.

Reason: To ensure appropriate vehicular access is provided.

DA/310/2015 Page 18 of 38

31. All mechanical exhaust ventilation from the car park is to be ventilated away from the property boundaries of the adjoining dwellings, and in accordance with the provisions of AS1668.1 - 1998 – 'The use of ventilation and air conditioning in buildings' – 'Fire and smoke control in multi-compartmented buildings'. Details showing compliance are to accompany an application for a Construction Certificate.

Reason: To preserve community health and ensure compliance with acceptable standards.

32. Where work is likely to disturb or impact upon a utility installations, (e.g. power pole, telecommunications infrastructure etc.) written confirmation from the affected utility provider that they raise no objections to the proposed works must accompany an application for a Construction Certificate to the satisfaction of the Certifying Authority.

Reason: To ensure no unauthorised work to public utility installations and to minimise costs to Council.

33. Council property adjoining the construction site must be fully supported at all times during all demolition, excavation and construction works. Details of any required shoring, propping and anchoring devices adjoining Council property, are to be prepared by a qualified structural or geotechnical engineer. These details must accompany an application for a Construction Certificate and be to the satisfaction of the Principal Certifying Authority (PCA). A copy of these details must be forwarded to Council prior to any work being commenced.

Backfilling of excavations adjoining Council property or any void remaining at the completion of the construction between the building and Council property must be fully compacted prior to the completion of works.

Reason: To protect Council's infrastructure.

34. Foundations adjacent to a drainage easement are to be constructed in accordance with Council's Code "Foundation Requirements for Structures Adjacent to Council Stormwater Drainage Easements – Parramatta City Council Code E-3". The engineering details are to form part of the Construction Certificate documentation.

Reason: To ensure Council's assets are not damaged.

- 35. Foundations adjacent to the Council's existing drainage pipe, within the site must be protected by creation of easement of width appropriate to the size of pipe ((approval for the appropriateness of the easement width should be obtained from council's Civil Infrastructure Unit) and by constructing the foundation in accordance with Council's Code, "Foundation Requirements for Structures Adjacent to Council Stormwater Drainage Easements". Details must accompany an application for a Construction Certificate.
- 36. Motorcycle and bicycle spaces are to be provided on-site and used accordingly. The dimensions and layout of the motorcycle spaces and bicycle storage/racks are to comply with Clause 2.4.7 and Figure 2.7 of AS 2890.1- 2004 and Sections 2 and 3 and Appendix B of AS 2890.3-2015 respectively. Details are to be illustrated on plans submitted with the construction certificate.

DA/310/2015 Page 19 of 38

Reason: To comply with Council's parking requirements.

37. Parking spaces are to be provided in accordance with the approved plans referenced in condition 1 and with AS 2890.1, AS2890.2 and AS 2890.6. Details are to be illustrated on plans submitted with the construction certificate.

Reason: To comply with Council's parking requirements and Australian Standards.

38. Prior to the issue of the construction certificate, the PCA shall ascertain that any new element in the basement carpark not illustrated on the approved plans such as columns, garage doors, fire safety measures and the like do not compromise appropriate manoeuvring and that compliance is maintained with AS 2890.1, AS2890.2 and AS 2890.6. Details are to be illustrated on plans submitted with the construction certificate.

Reason: To ensure appropriate vehicular manoeuvring is provided

39. The zebra crossing at the entrance to the carpark shall be provided with appropriate signage to highlight the pedestrian crossing and potential pedestrian activity to motorists, and be appropriately lit, in accordance with the Roads and Maritime Services requirements and Austroads guidelines. Details are to be illustrated on plans submitted with the construction certificate.

Reason: To comply with Australian Standards, Roads and Maritime Services requirements; Austroads design guidelines and ensure pedestrian safety.

40. A splay extending 2m from the driveway edge along the front boundary and 2.5m from the boundary along the driveway in accordance with Figure 3.3 of AS2890.1 shall be provided to give clear sight lines of pedestrians from vehicles exiting the site from Eels Place. This shall be illustrated on plans submitted with the construction certificate and not be compromised by the landscaping, signage fences, walls or display materials.

Reason: To comply with Australian Standards and ensure pedestrian safety.

- 41. A Pedestrian Management and Safety Plan must be submitted to the satisfaction of the Principal Certifying Authority prior to the commencement of any works on site. It must include details of the:
 - a) Proposed ingress and egress of vehicles to and from the construction site
 - b) Proposed protection of pedestrians adjacent to the site
 - c) Proposed pedestrian management whilst vehicles are entering and leaving the site
 - d) Proposed route of construction vehicles to and from the site
 - e) Proposed measures to protect workers and pedestrians from overhead hazards.

The Management Plan shall be implemented during all phases of the development until the Occupation Certificate is issued.

Reason: To comply with Australian Standards and ensure pedestrian safety.

DA/310/2015 Page 20 of 38

PRIOR TO WORK COMMENCING

- 42. Prior to commencement of work, the person having the benefit of the Development Consent and Construction Certificate approval must:
 - (a) Appoint a Principal Certifying Authority (PCA) and notify Council in writing of the appointment (irrespective of whether Council or an accredited private certifier) within 7 days; and
 - (b) Notify Council in writing a minimum of 48 hours prior to work commencing of the intended date of commencement.

The Principal Certifying Authority must determine and advise the person having the benefit of the Construction Certificate when inspections, certification and compliance certificates are required.

Reason: To comply with legislative requirements.

43. The site must be enclosed by a 1.8m high security fence erected wholly within the confines of the site to prevent unauthorised access. The fence must be installed to the satisfaction of the Principal Certifying Authority prior to the commencement of any work on site.

Reason: To ensure public safety.

- 44. Prior to the commencement of any works on site, the applicant must submit a Construction and/or Traffic Management Plan to the satisfaction of the Principle Certifying Authority. The following matters must be specifically addressed in the Plan:
 - (a) Construction Management Plan for the Site. A plan view of the entire site and frontage roadways indicating:
 - (i) Dedicated construction site entrances and exits, controlled by a certified traffic controller, to safely manage pedestrians and construction related vehicles in the frontage roadways,
 - (ii) Turning areas within the site for construction and spoil removal vehicles, allowing a forward egress for all construction vehicles on the site,
 - (iii) The locations of proposed Work Zones in the egress frontage roadways,
 - (iv) Location of any proposed crane standing areas,
 - (v) A dedicated unloading and loading point within the site for all construction vehicles, plant and deliveries,
 - (vi) Material, plant and spoil bin storage areas within the site, where all materials are to be dropped off and collected,
 - (vii) The provisions of an on-site parking area for employees, tradesperson and construction vehicles as far as possible.
 - (viii) A detailed description and route map of the proposed route for vehicles involved in spoil removal, material delivery and machine floatage and a copy of this route is to be made available to all contractors.
 - (ix) A detailed description of locations that will be used for layover for trucks waiting to access the construction site.
 - (b) Written concurrence from Council's Traffic and Transport Services in relation to installation of a proposed 'Works Zone' restriction in the egress frontage roadways of the development site.

DA/310/2015 Page 21 of 38

Application fees and kerbside charges for 6 months (minimum) are to be paid in advance in accordance with the Council's Fees and Charges. The 'Works Zone' restriction is to be installed by Council once the applicant notifies Council in writing of the commencement date (subject to approval through Parramatta Traffic Committee processes). Unused fees for kerbside charges are to be refunded once a written request to remove the restriction is received by Council.

- (c) Traffic Control Plan(s) for the site:
 - (i) All traffic control devices installed in the road reserve shall be in accordance with the NSW Transport Roads and Maritime Services publication 'Traffic Control Worksite Manual' and be designed by a person licensed to do so (minimum RMS 'red card' qualification) The main stages of the development requiring specific construction management measures are to be identified and specific traffic control measures identified for each.
 - (ii) Approval shall be obtained from Parramatta City Council for any temporary road closures or crane use from public property.
- (d) Where applicable, the plan must address the following:
 - Evidence of RTA concurrence where construction access is provided directly or within 20 m of an Arterial Road,
 - (ii) A schedule of site inductions shall be held on regular occasions and as determined necessary to ensure all new employees are aware of the construction management obligations.
 - (iii) Minimising construction related traffic movements during school peak periods,

The Construction and Traffic Management Plan shall be prepared by a suitably qualified and experienced traffic consultant and be certified by this person as being in accordance with the requirements of the abovementioned documents and the requirements of this condition.

Reason: To ensure that appropriate measures have been considered during all phases of the construction process in a manner that maintains the environmental amenity and ensures the ongoing safety and protection of people.

- 45. Prior to the commencement of any works on site, the applicant must submit a Construction Management Plan to the satisfaction of the Principle Certifying Authority. The following matters must be specifically addressed in the Plan:
 - (a) An overall construction management program;
 - (b) Construction traffic management;
 - (c) Construction zones;
 - (d) Pedestrian management;
 - (e) Hoardings;
 - (f) Dust management;
 - (g) Hours of work;

DA/310/2015 Page 22 of 38

- (h) Noise and vibration management measures;
- (i) Dilapidation reports;
- (j) Identification and disposal of hazardous materials/demolition materials;
- (k) Materials handling, waste management and recycling;
- (I) Disposal of excavated materials; and
- (m) Unexpected archaeological finds
- (n) Specific matters nominated within the consent notice.
- 46. Prior to the commencement of any excavation works on site, the applicant must submit for approval by the Principal Certifying Authority (with a copy forwarded to Council) a dilapidation report on the visible and structural condition of all neighbouring structures within the 'zone of influence' of the excavation face to a depth of twice that of the excavation.

The report must include a photographic survey of the adjoining properties detailing their physical condition, both internally and externally, including such items as walls, ceilings, roof, structural members and other similar items. The report must be completed by a consulting structural/geotechnical engineer in accordance with the recommendation of the geotechnical report. A copy of the dilapidation report must be submitted to Council.

In the event access to adjoining allotments for the completion of a dilapidation survey is denied, the applicant must demonstrate in writing that all reasonable steps have been taken to advise the adjoining allotment owners of the benefit of this survey and details of failure to gain consent for access to the satisfaction of the Principle Certifying Authority.

Note: This documentation is for record keeping purposes only, and can be made available to an applicant or affected property owner should it be requested to resolve any dispute over damage to adjoining properties arising from works. It is in the applicant's and adjoining owner's interest for it to be as detailed as possible.

Reason: Management of records.

47. The applicant must apply for a road-opening permit where a new pipeline is proposed to be constructed within or across Council owned land. Additional road opening permits and fees may be necessary where connections to public utilities are required (e.g. telephone, electricity, sewer, water or gas).

No drainage work can be carried out within the Council owned land without this permit being issued. A copy is required to be kept on site.

Reason: To protect Council's assets throughout the development process.

- 48. Prior to the commencement of any excavation works on site the applicant must submit, for approval by the Principal Certifying Authority (PCA), a geotechnical/civil engineering report which addresses (but is not limited to) the following:
 - (a) The type and extent of substrata formations. A minimum of 4 representative bore hole logs which are to provide a full description of all material from the

DA/310/2015 Page 23 of 38

- ground surface to a minimum of 1.0m below the finished basement floor level. The report is to include the location and description of any anomalies encountered in the profile, and the surface and depth of the bore hole logs shall be to Australian Height Datum.
- (b) Having regard to the findings of the bore hole testing, details of the appropriate method of excavation/shoring together with the proximity to adjacent property and structures can be ascertained. As a result potential vibration caused by the method of excavation and how it will impact on nearby footings/foundations must be established together with methods to ameliorate any impact.
- (c) The proposed methods for temporary and permanent support required by the extent of excavation can be established.
- (d) The impact on groundwater levels in relation to the basement structure.
- (e) The drawdown effects if any on adjacent properties (including the road reserve), resulting from the basement excavation will have on groundwater together with the appropriate construction methods to be utilised in controlling groundwater.

Where it is considered there is potential for the excavation to create a "dam" for natural groundwater flows, a groundwater drainage system must be designed to transfer groundwater through or under the proposed development. This design is to ensure there is no change in the range of the natural groundwater level fluctuations. Where an impediment to the natural flow path of groundwater results, artificial drains such as perimeter drains and through drainage may be utilised.

(f) The recommendations resulting from the investigations are to demonstrate the works can be satisfactorily implemented. An implementation program is to be prepared along with a suitable monitoring program (where required) including control levels for vibration, shoring support, ground level and groundwater level movements during construction.

The implementation program is to nominate suitable hold points for the various stages of the works in order verify the design intent before certification can be issued and before proceeding with subsequent stages.

The geotechnical report must be prepared by a suitably qualified consulting geotechnical/hydrogeological engineer with demonstrated experience in such investigations and reporting. It is the responsibility of the engaged geotechnical specialist to undertake the appropriate investigations, reporting and specialist recommendations to ensure a reasonable level of protection to adjacent properties and structures both during and after construction. The report must contain site specific geotechnical recommendations and must specify the necessary hold/inspection points by relevant professionals as appropriate. The design principles for the geotechnical report are as follows:

(i) No ground settlement or movement is to be induced which is sufficient enough to cause an adverse impact to adjoining property and/or infrastructure.

DA/310/2015 Page 24 of 38

- (ii) No changes to the ground water level are to occur as a result of the development that is sufficient enough to cause an adverse impact to the surrounding property and infrastructure.
- (iii) No changes to the ground water level are to occur during the construction of the development that is sufficient enough to cause an adverse impact to the surrounding property and infrastructure.
- (iv) Vibration is to be minimised or eliminated to ensure no adverse impact on the surrounding property and infrastructure occurs, as a result of the construction of the development.
- (v) Appropriate support and retention systems are to be recommended and suitable designs prepared to allow the proposed development to comply with these design principles.
- (vi) An adverse impact can be assumed to be crack damage which would be classified as Category 2 or greater damage according to the classification given in Table CI of AS 2870 - 1996.

Reason: To ensure the ongoing safety and protection of property.

- 49. Prior to commencement of works and during construction works, the development site and any road verge immediately in front of the site must be maintained in a safe and tidy manner. In this regard the following must be undertaken:
 - (a) all existing buildings are to be secured and maintained to prevent unauthorised access and vandalism
 - (b) all site boundaries are to be secured and maintained to prevent unauthorised access to the site:
 - (c) all general refuge and/or litter (inclusive of any uncollected mail/advertising material) is to be removed from the site on a fortnightly basis;
 - (d) the site is to be maintained clear of weeds; and
 - (e) all grassed areas are to be moved on a monthly basis.

Reason: To ensure public safety and maintenance of the amenity of the surrounding environment.

- 50. If development involves excavation that extends below the level of the base, of the footings of a building on adjoining land, the person having the benefit of the development consent must, at the persons own expense:
 - (a) Protect and support the adjoining premises from possible damage from the excavation
 - (b) Where necessary, underpin the adjoining premises to prevent any such damage.

Note: If the person with the benefit of the development consent owns the adjoining land or the owner of the adjoining land has given consent in writing to the condition not applying, this condition does not apply.

Reason: As prescribed under the Environmental Planning and Assessment Regulation 2000.

51. Unless otherwise specifically approved in writing by Council, all works, processes, storage of materials, loading and unloading associated with the development are to occur entirely within the property boundaries. The applicant, owner or builder must

DA/310/2015 Page 25 of 38

apply for specific permits if the following activities are required seeking approval pursuant to Section 138 of the Roads Act 1993:

- (a) On-street mobile plant:
 - E.g. Cranes, concrete pumps, cherry-pickers, etc. restrictions apply to the hours of operation and the area where the operation will occur, etc. Separate permits are required for each occasion and each piece of equipment. It is the applicant's, owner's and builder's responsibilities to take whatever steps are necessary to ensure the use of any equipment does not violate adjoining property owner's rights.
- (b) Storage of building materials and building waste containers (skips) on Council's property.
- (c) Permits to utilise Council property for the storage of building materials and building waste containers (skips) are required for each location they are to be stored. Failure to obtain the relevant permits will result in the building materials or building waste containers (skips) being impounded. Storage of building materials and waste containers within Council's open space areas, reserves and parks is prohibited.
- (d) Kerbside restrictions construction zones:

The applicant's attention is drawn to the possible existing kerbside restrictions adjacent to the development. Should the applicant require alteration of existing kerbside restrictions, or the provision of a work zones, the appropriate application must be made to Council and the fee paid. Applicants should note that the alternatives of such restrictions may require referral to Council's Traffic Committee. An earlier application is suggested to avoid delays in construction programs..

The application is to be lodged with Council's Customer Service Centre.

Reason: Proper management of public land.

52. All works associated with the construction and/or extension of a driveway crossover/layback within Council owned land requires an application to be lodged and approved by Council.

All footpath crossings, laybacks and driveways are to be constructed according to Council's Specification for Construction or Reconstruction of Standard Footpath Crossings and in compliance with Standard Drawings DS1 (Kerbs & Laybacks); DS7 (Standard Passenger Car Clearance Profile); DS8 (Standard Vehicular Crossing); DS9 (Heavy Duty Vehicular Crossing) and DS10 (Vehicular Crossing Profiles).

The application for a driveway crossing requires the completion of the relevant application form and accompanied by plans, grades/levels and specifications. A fee in accordance with Councils adopted 'Fees and Charges' will need to be paid at the time of lodgement.

- Note 1: This development consent is for works wholly within the property. Development consent does not imply approval of the footpath or driveway levels, materials or location within the road reserve, regardless of whether the information is shown on the development application plans.
- **Note 2:** Council's Customer Service Team can advise of the current fee and can be contacted on 9806 5524

DA/310/2015 Page 26 of 38

Reason: To provide suitable vehicular access without disruption to pedestrian and vehicular traffic.

53. The proposed pipe connection into the council's existing pipe system shall comply with the following requirements:

a. The connection to the existing pit

The connection to the council's existing inlet pit shall be made in accordance with Council Standard Plan (Please contact to council's Civil Infrastructure Unit for connection type and drawing).

b. The drawings including connection details.

The drawings of the proposed connection and pipeline (if any) should show the Connection details into the existing pit/new pit.

The drawings including the construction and connection details shall be submitted to the satisfaction of council's **Civil Infrastructure Unit** for approval. No pipe works shall commence until the approval is obtained.

Upon completion of the work separate Work-As-Executed plan shall be prepared on the approved stormwater plan and submitted to council for record and sign off.

Reason: To ensure that the stormwater work comply with council's requirements.

54. Prior to commencement of any works, including demolition and excavation, the applicant is to submit to the Council of documentary evidence including photographic evidence of any existing damage to Council's property. Council's property includes footpaths, kerbs, gutters, drainage pits, pipes etc. A dilapidation survey of Council's assets, including photographs and written record, must be prepared by a suitably qualified person and submitted to Council prior to the commencement of works. Failure to identify any damage to Council's assets will render the applicant liable for the costs associated with any necessary repairs

Reason: To ensure that the applicant bears the cost of all restoration works to Council's property damaged during the course of this development.

- 55. Certification by a suitably qualified person shall be provided to the Principal Certifying Authority confirming all tree protection measures, as identified in the report by New Leaf Arboriculture, dated 19 March 2015, have been installed.
- 56. To control the spread of weeds or exotic seeds into the nearby Cumberland Riverflat Forest Endangered Ecological Community, a strip of filter fabric is to be attached to the sediment fence prior to the commencement of demolition, excavation or building works. The filter fabric is to be a minimum of 50mm into the existing ground, to extend a minimum 150mm above existing ground and securely attached to the entire length of the sediment fence. The build-up of sediment against the filter fabric is to be regularly removed and disposed of responsibly off site to ensure on-going effectiveness. Details demonstrating compliance is to be submitted to the Principal Certifying Authority.

Reason: To ensure protection of bushland and minimise the impacts of the development.

DA/310/2015 Page 27 of 38

- 57. A sign must be erected in a prominent position on any site involving excavation, erection or demolition of a building in accordance with Clause 98 A (2) of the Environmental Planning and Assessment Regulations 2000 detailing:
 - (a) Unauthorised entry of the work site is prohibited;
 - (b) The name of the principal contractor (or person in charge of the work site), their telephone number enabling 24hour contact; and
 - (c) The name, address and telephone number of the Principal Certifying Authority;
 - (d) The development consent approved construction hours;

The sign must be maintained during excavation, demolition and building work, and removed when the work has been completed.

This condition does not apply where works are being carried.

Reason: Statutory requirement.

- 58. The basement stormwater pump-out system, must be designed and constructed to include the following:
 - (a) A holding tank capable of storing the run-off from a 100 year ARI (average reoccurrence interval) 2 hour duration storm event, allowing for pump failure.
 - (b) A two pump system (on an alternate basis) capable of emptying the holding tank at a rate equal to the lower of:
 - (i) The permissible site discharge (PSD) rate; or
 - (ii) The rate of inflow for the one hour, 5 year ARI storm event.
 - (c) An alarm system comprising of basement pump-out failure warning sign together with a flashing strobe light and siren installed at a clearly visible location at the entrance to the basement in case of pump failure.
 - (d) A 100 mm freeboard to all parking spaces.
 - (e) Submission of full hydraulic details and pump manufacturers specifications.
 - (f) Pump out system to be connected to a stilling pit and gravity line before discharge to the street gutter.

Plans and design calculations along with certification from the designer indicating that the design complies with the above requirements are to be submitted to the satisfaction of the Principal Certifying Authority prior to issue of the Construction Certificate.

Reason: To ensure satisfactory storm water disposal.

59. Erosion and sediment control measures are to be installed in accordance with the publication 'Urban Stormwater: Soils and Construction "The Blue Book" 2004 (4th edition) prior to the commencement of any demolition, excavation or construction works upon the site. These measures are to be maintained throughout the entire works.

Reason: To ensure soil and water management controls are in place before site works commence.

- 60. Public risk insurance in the amount of not less than \$20 million or such other amount as Council may require by notice) must be obtained and furnished to Council before any works authorised by this consent are conducted:
 - (a) Above;

DA/310/2015 Page 28 of 38

- (b) Below; or
- (c) On

Any public land owned or controlled by Council. The public risk insurance must be maintained for the period during which these works re being undertaken.

The public risk insurance must be satisfactory to Council and list Council as an insured and/or interested party.

A copy of the insurance policy obtained must be forwarded to Council before any of the works commence.

Note: Applications for hoarding permits, vehicular crossing etc. will require evidence of insurance upon lodgement of the application.

Reason: To ensure the community is protected from the cost of any claim for damages arising from works authorised by this consent conducted above, below or on any public land owned or controlled by Council.

61. A noise management plan must be submitted to Council for approval prior to any work commencing and complied with during any construction woks. The plan must be prepared by a suitably qualified person, who possesses qualifications to render them eligible for membership of the Australian Acoustic Society, Institution of Engineers Australia or the Australian Association of Acoustic Consultants.

The plan must include, but not be limited to the following:

- (a) Identify sensitive location near the site;
- (b) Identify potential impacts (i.e. exceedance of the goals at the identified locations);
- (c) Mitigation measures to control noise and dust from the site, the noise reduction likely and the feasibility and reasonableness of these measures;
- (d) Selection criteria for plant and equipment;
- (e) Community consultation;
- (f) Details of work schedules for all construction phases;
- (g) Selection of traffic routes to minimise residential noise intrusion;
- (h) Schedule of plant and equipment use and maintenance programs;
- (i) Noise monitoring techniques and method of reporting results;
- (j) The methodology to be employed for handling and investigating any complaints should they arise;
- (k) Site induction details for employees and contractors; and
- (I) A declaration of available technologies and the reason for the selection of the preferred technology from a noise generating perspective should be included.

Reason: To maintain appropriate amenity to nearby occupants.

DURING WORK

62. A copy of this development consent together with the stamped plans, referenced documents and associated specifications is to be held on-site during the course of any works to be referred to by all contractors to ensure compliance with the approval and the associated conditions of consent.

Reason: To ensure compliance with this consent.

DA/310/2015 Page 29 of 38

- 63. Ensure all relevant recommendations identified in the report by New Leaf Arboriculture, dated 19 March 2015, are implemented.
- 64. The applicant is to ensure no storage or stockpiling of building materials, excavated fill or topsoil during the site works shall take place within 50m of the Grey-headed Flying Fox camp for the duration of on-site works.

Reason: To ensure protection of bushland and minimise the impacts of the development.

- 65. Prior to the removal of identified hollow bearing trees, the applicant shall:
 - (a) Install replacement nesting boxes on a retained mature tree within the property at a suitable height and orientation. Information on nesting boxes can be obtained from WIRES (http://www.wires.org.au) or Birdlife Australia (www.birdlife.org.au), (insert height, orientation and location of boxes) within the site;
 - (b) Capture wildlife from the hollows with traps set at a minimum of two nights and relocate into a nesting box;
 - (c). Trees to be removed in sections by a qualified tree surgeon in the presence of a 'Wildlife Carers' organisation to assist in the event of fauna injury. Note: 'WIRES' (Wildlife Rescue) volunteers can be contacted on 8977 3333. 'Wildlife Services Sydney Metropolitan' volunteers can be contacted on 9413 4300. Information on animal nesting boxes can be obtained from WIRES, Kalkari Information Centre in Ku-Ring-Gai Chase National Park or Birds Australia www.birdsaustralia.com.au.

Reason: To ensure protection of native wildlife

66. All machinery is to be cleaned of soil and debris before entering the site to prevent the spread of weed and fungal pathogens such as Cinnamon Fungus (*Phytophthora cinnamomi*) and Chytrid Fungus (*Batrachochytrium dendrobatidis*)

Reason: To ensure protection of bushland and minimise the impacts of the development.

- 67. To minimise disturbance to nearby Cumberland Riverflat Forest along the Parramatta River riparian corridor, no excavation shall take place within the critical root zone (CRZ)*, measured as a radius from the centre of the trunk of the tree. Excavation may occur between the critical and primary root zones (PRZ)*, but only by hand under the supervision of an experienced arborist. In the event that major structural of feeder roots (>50mm in diameter) are encountered between the critical and primary root zones, the consulting arborist is to implement appropriate measures to ensure the long term retention of the tree. (Note: Council's Tree Management Officers maybe contacted for advice regarding appropriate tree protection measures).
 - critical root zone = 5 x trunk diameter 1400mm from ground level (measured as a radius from the centre of the trunk).
 - primary root zone = 10 x trunk diameter 1400mm from ground level (measured as a radius from the centre of the trunk).

Reason: To ensure adequate protection of existing environmental assets and to maintain public amenity.

DA/310/2015 Page 30 of 38

68. Dust control measures shall be implemented during all periods of earth works, demolition, excavation and construction to minimise the dust nuisance on surrounding properties. In this regard, dust minimisation practices must be carried out in accordance with Council's Guidelines for Controlling Dust from Construction Sites and Section 126 of the Protection of the Environment Operations Act 1997.

Reason: To protect the amenity of the area.

69. No building materials skip bins, concrete pumps, cranes, machinery, temporary traffic control, signs or vehicles associated with the construction, excavation or demolition shall be stored or placed on/in Council's footpath, nature strip, roadway, park or reserve without the prior approval being issued by Council under section 138 of the Roads Act 1993.

Reason: To ensure pedestrian access.

70. The applicant must not enter or undertake any work within any adjoining public parks or reserves without the prior written consent of Council.

Reason: Protection of existing public infrastructure and land and to ensure public safety and proper management of public land.

71. All work (excluding demolition which has seperate days and hours outlined below) including building, and excavation work; and activities in the vicinity of the site generating noise associated with preparation for the commencement of work (e.g. loading and unloading of goods, transferring of tools, machinery etc.) in connection with the proposed development must only be carried out between the hours of 7.00am and 5.00pm on Monday to Fridays inclusive, and 8.00am to 5.00pm on Saturday. No work is to be carried out on Sunday or public holidays.

Demolition works are restricted to Monday to Friday between the hours of 7.00am to 5.00pm. No demolition works are to be undertaken on Saturdays, Sundays or Public Holidays.

72. Noise emissions and vibration must be minimised, work is to be carried out in accordance with the NSW Department of Environment, Climate Change and Water's Interim Noise Construction Guidelines 2009 for noise emissions from demolition, excavation and construction activities.

Vibration levels resulting from demolition and excavation activities must not exceed 5mm/sec peal particle velocity (PPV) when measured at the footing of any nearby building.

Reason: To protect the amenity of the area.

73. Any damage to Council assets that impacts on public safety during construction is to be rectified immediately to the satisfaction of Council with all costs to be borne by the person having the benefit of the Development Consent.

Reason: To protect public safety.

DA/310/2015 Page 31 of 38

74. Works are not to result in sedimentation and or run-off from the approved works onto the adjoining properties and or public lands. The person having the benefit of this consent must ensure sediment is not tracked out from the development site.

Reason: To ensure no adverse impacts on neighbouring properties.

75. A **250mm** wide grated channel/trench drain with a heavy-duty removable galvanised steel grate shall be provided to the full driveway width **of ramp at the base of basement access ramp** to collect driveway runoff. The **grated/channel** drain shall be connected to the **basement pump-out tank** and shall have an outlet of minimum diameter **150mm** to prevent blockage by silt and debris.

Reason: Stormwater control & runoff management

76. A **200mm** wide grated channel/trench drain with a heavy-duty removable galvanised steel grate shall be provided to the full width of the driveway at the front of the entry and exit point or any appropriate location(s) to collect driveway runoff. The grated drain shall be connected to the main system outlet and shall have a minimum diameter **100mm dia pipe** to prevent blockage by silt and debris.

Reason: Stormwater control & runoff management

77. Any damage to Council assets that impacts on public safety of Council with all costs to be borne by the person having the benefit of the Development Consent.

Reason: To protect public safety

78. During construction of all public area civil and drainage works a qualified civil engineer must supervise the work to ensure it is completed in accordance with Council's "Guidelines for Public Domain Works". Certification is required to be provided with the Occupation Certificate.

Reason: To ensure Council's assets are appropriately constructed

79. Oversized vehicles using local roads require Council's approval. The applicant is to be required to submit an application for an Oversize Vehicle Access Permit through Council's Traffic and Transport Services, prior to driving through local roads within Parramatta LGA.

Reason: To ensure maintenance of Council's assets.

80. Standard Kerb Ramps are to be constructed in accordance with Council Plan No. DS4. Details must be submitted to and be approved by Council prior to construction. All costs must be borne by the applicant.

Reason: To provide adequate access.

81. A survey certificate is to be submitted to the Principal certifying Authority at footing and/or formwork stage. The certificate must indicate the location of the building in relation to all boundaries, and must confirm the ground and first floor level is consistent with that approved under this consent prior to any further work proceeding on the building.

Reason: To ensure the development is being built as per the approved plans.

DA/310/2015 Page 32 of 38

PRIOR TO THE ISSUE OF AN OCCUPATION CERTIFICATE

82. An evacuation report and procedure shall be prepared by an appropriate consulting engineer. This report is to demonstrate how the occupants of the development will egress the site in the early stages of a storm event, together with how they will seek refuge in a peak stormwater event (i.e. first floor of the building etc.). The report shall be submitted to the Principal Certifying Authority prior to the issue of the Occupation Certificate. A copy of the report shall be attached to the Occupation Certificate when forwarded to Council.

Reason: To make property owners/residents aware of the procedure in the case of flood.

83. The existing council stormwater pipeline shall be protected by creation of drainage easement of appropriate width based on the size of the stormwater relevant infrastructures such pits and stormwater pipes (approval for the appropriateness of the easement width should be obtained from the council's Civil Infrastructure Unit). Prior to issue of occupation certificate the documentary evidence showing the creation of appropriate layout and width of required drainage easement shall be submitted to council as well as to the principal certifying authority.

Reason: To protect council's asset/ infrastructure.

84. All redundant lay-backs and vehicular crossings must be reinstated to conventional kerb and gutter, foot-paving or grassed verge in accordance with Council's Standard Plan No. **DS01**. The reinstatement must be completed prior to the issue of an Occupation Certificate. All costs must be borne by the applicant.

Reason: To provide satisfactory drainage.

85. A Section 73 Compliance Certificate under the Sydney Water Act 1994 must be obtained prior to the issue of any Occupation Certificate. The application must be made through an authorised Water Servicing Coordinator. Please refer to "Your Business" section of Sydney Water's web site at www.sydneywater.com.au then the "e-developer" icon or telephone 13 20 92.

Reason: To ensure the requirements of Sydney Water have been complied with.

- 86. Works-As-Executed stormwater plans shall be submitted to the Principal Certifying Authority prior to the issue of the Occupation Certificate, certifying that the stormwater drainage system has been constructed and completed in accordance with the approved stormwater plans. The person issuing the Occupation Certificate shall ensure that the following documentation is completed and submitted
 - (a) Stormwater system including On-Site Detention systems have been built according to and comply with the requirements including the OSD storage volume as shown on the approved stormwater plan.
 - (b) The Work-As-Executed plans are prepared on the copies of the approved drainage plans issued with the Construction Certificate with the variations marked in red ink.
 - (c) The Work-As-Executed plans have been prepared by a registered surveyor certifying the accuracy of dimensions, levels, storage volumes, etc.

DA/310/2015 Page 33 of 38

- (d) The "As-built" On-Site Detention (OSD) storage volumes are to be presented in a tabular form using the pyramid volume and prismatic volume calculation method.
- (e) OSD WAE Survey certification form and WAE dimensions form (Form B10 and attachment B. Refer to UPRCT Handbook).
- (f) Certificate of Hydraulic Compliance (Form B11) from a qualified drainage / hydraulic engineer (refer to UPRCT Handbook). The person issuing Hydraulic certificate shall ensure that all the works have been completed and comply with the approved plans.
- (g) Approved verses installed Drainage Design (OSD) Calculation Sheet certified by a qualified practicing Hydraulic Engineer.
- (h) Structural Engineer's Certificate for the OSD tank structure, basement pump out tank structure, OSD basin (retaining) wall etc.

The above is to be submitted to the Principal Certifying Authority prior to the issue of an occupation certificate and another set of the documents shall be submitted to Council.

Reason: To ensure works comply with approved plans and adequate information are available for Council to update the Upper Parramatta River Catchment Trust.

87. Prior to the issue of an Occupation Certificate a Positive Covenant and Restriction on the Use of Land under Section 88E of the Conveyancing Act 1919 must be created, burdening the owner with the requirement to maintain the on-site stormwater detention facilities on the lot.

The terms of the instruments are to be generally in accordance with Council's "draft terms of Section 88B instrument for protection of on-site detention facilities" to Council's satisfaction.

Where a Title exists, the Positive Covenant and Restriction on the Use of Land is to be created through via an application to the Land Titles Office using forms 13PC and 13RPA. Accompanying this form is the requirement for a plan to scale showing the relative location of the On-Site Detention facility, including its relationship to the building footprint.

Registered title documents showing the covenants and restrictions must be submitted to and approved by the Principal Certifying Authority prior to Occupation or use of onsite.

Reason: To ensure maintenance of on-site detention facilities.

88. Prior to the issue of any Occupation Certificate, an application is required to be obtained from Council for any new, reconstructed or extended sections of driveway crossings between the property boundary and road alignment.

All footpath crossings, laybacks and driveways are to be constructed according to Council's Specification for Construction or Reconstruction of Standard Footpath Crossings and in compliance with Standard Drawings DS1 (Kerbs & Laybacks); DS7

DA/310/2015 Page 34 of 38

(Standard Passenger Car Clearance Profile); DS8 (Standard Vehicular Crossing); DS9 (Heavy Duty Vehicular Crossing) and DS10 (Vehicular Crossing Profiles).

The application for a driveway crossing requires the completion of the relevant application form and be accompanied by detailed plans showing, grades/levels and specifications that demonstrate compliance with Council's standards, without conflict with all internal finished surface levels. The detailed plan must be submitted to Council's Civil Assets Team for approval prior to commencement of the driveway crossing works. A fee in accordance with Councils adopted 'Fees and Charges' will need to be paid at the time of lodgement.

Note 1: This development consent is for works wholly within the property. Development consent does not imply approval of the footpath or driveway levels, materials or location within the road reserve, regardless of whether the information is shown on the development application plans.

Note 2: Council's Customer Service Team can advise of the current fee and can be contacted on 9806 5524.

Reason: Pedestrian and Vehicle safety.

- 89. The applicant shall engage a suitably qualified person to prepare a post construction dilapidation report at the completion of the construction works. This report is to ascertain whether the construction works created any structural damage to adjoining buildings, infrastructure and roads. The report is to be submitted to the PCA. In ascertaining whether adverse structural damage has occurred to adjoining buildings, infrastructure and roads, the PCA must:
 - (a) compare the post-construction dilapidation/damage report with the pre-construction dilapidation/ damage report, and
 - (b) have written confirmation from the relevant authority that there is no adverse structural damage to their infrastructure and roads.
 - (c) carry out site inspection to verify the report and ensure that any damage to the public infrastructure as a result of the construction work have been rectified immediately by the developer at his/her cost.
 - (d) Forward a copy of the dilapidation report with the PCA's comparison and assessment review report to Council.

Reason: To establish the condition of adjoining properties prior building work and ensure any damage as a result of the construction works have been rectified.

- 90. The Principal Certifying Authority shall ensure that the required number of accessible parking spaces is provided and suitable identified to meet statutory requirements.
- 91. Prior to the issue of the occupation certificate, a convex mirror is to be installed within the ramp access (one near the entry driveway & one at the bottom of the ramp access) with its height and location adjusted to allow an exiting driver a full view of the driveway in order to see if another vehicle is coming through.

DA/310/2015 Page 35 of 38

92. The applicant shall install and maintain surveillance cameras and recorders to monitor and record all entrance and exit points to the car park being the driveway/paystation areas, lobby spaces to all lift cores, and entry doors to all fire stairs.

The system shall be designed and operated to enable recordings (24) hours a day seven (7) days a week. The time and date must automatically be recorded. All recordings are to be kept for a minimum period of thirty (30) days before they can be reused or destroyed.

The CCTV control system should be located within a secured area of the premise and only accessible by authorised personnel.

- 93. The lift external walls of the lift cores should be painted a bright colour, or otherwise treated, to assist in way finding thought the basement.
- 94. Each level of the car park shall be provided with distinctive colouring and numbering to assist with way finding.
- 95. Signage warning of CCTV coverage shall be displayed in proximity to the car park driveway/paystation areas, lobby spaces to all lift cores, and entry doors to all fire stairs.
- 96. An Occupation Certificate shall not be issued until all works within the approved landscape plans have been completed.
- 97. Submission of documentation confirming satisfactory arrangements have been made for the provision of electricity services from an approved electrical energy provider prior to the issue of an Occupation Certificate.

Reason: To ensure appropriate electricity services are provided

98. Occupation or use of the building or part is not permitted until an Occupation Certificate has been issued in accordance with Section 109H of the Environmental Planning and Assessment Act 1979.

Reason: To complying with legislative requirements of the Environmental Planning and Assessment Act 1979.

99. A light spillage diagram is required to be prepared by a suitably qualified lighting engineer and submitted to the Principal Certifying Authority prior to the issue of the Occupation Certificate. This diagram is to demonstrate light spillage generated by the proposed floodlighting system complies with the requirements of Australian Standard AS4284 - Control of Obtrusive Effects of Outdoor Lighting. Light spillage mitigating measures shall be maintained, at all times.

Reason: To prevent light spillage onto adjoining properties.

100. A written application to Council's Civil Assets Team for the release of a bond must quote the following:

DA/310/2015 Page 36 of 38

- (a) Council's Development Application number; and
- (b) Site address.

The bond is refundable only where Council is satisfied the public way has been adequately reinstated, and any necessary remediation/rectification works have been completed.

An Occupation Certificate is not to be issued until correspondence has been issued by Council detailing the bond has been released.

Note: Council's Civil Assets Team will take up to 21 days from receipt of the

request to provide the written advice.

Reason: To safe guard the public assets of council and to ensure that these assets

are repaired/maintained in a timely manner.

101. Prior to the issue of any Construction Certificate appropriate signs are to be installed at the Grose Street and O'Connell Street intersection towards the entry to the carpark to warn vehicles of a full or closed car park.

Reason: to comply with Council's parking requirements and ensure appropriate vehicular manoeuvring is provided.

102. The applicant shall engage a suitably qualified person to prepare a post construction dilapidation report at the completion of the construction works. This report is to ascertain whether the construction works created any structural damage to adjoining buildings and or infrastructure.

The report is to be submitted to the PCA prior to the issue of the occupation certificate. In ascertaining whether adverse structural damage has occurred to adjoining buildings/ infrastructure, the PCA must compare the post-construction dilapidation report with the pre-construction dilapidation report, and

A copy of this report is to be forwarded to Council.

Reason: To establish any damage caused as a result of the building works.

THE USE OF THE SITE

- 103. The car parking approved by this application, being 94 surface spaces and 437 spaces within the multi-storey facility shall only be used by staff of the club, members of the club, and visitors to the club. No public parking shall be provided.
- 104. Management of the parking facilities shall not be outsourced to a commercial cark operator or any other party.
- 105. The car parking shall be managed and maintained in accordance with the terms of the Plan of Management approved to satisfy Condition 1, Schedule 1, of the Notice of Determination.
- 106. The service dock shall be operated in accordance with Plan of Management approved to satisfy the relevant condition in Schedule 1.

DA/310/2015 Page 37 of 38

107. The property owner/operator of the facility is to ensure the flood warning system is in good working order, through regular testing and maintenance.

Reason: To ensure the integrity of the flood warning system.

108. All landscape works shall be maintained for a minimum period of two (2) years following the issue of a Final Occupation Certificate, in accordance with the approved landscape plan and conditions

Reason: To ensure restoration of environmental amenity.

109. No advertisement/signage shall be erected on or in conjunction with the development without prior consent.

Reason: To comply with legislative controls.

ADVISORY NOTES

A. Threatened Species Conservation Act 1995 – Advisory Note

The applicant is advised that the subject site is located in proximity to Cumberland Riverflat Forest that is listed as an Endangered Ecological Community, and Greyheaded Flying Fox which are listed as a threatened species under the *Threatened Species Conservation Act 1995*. This Act prohibits the disturbance of threatened species, endangered populations, ecological communities, or their habitat, without the approval of the 'NSW Office of Environment and Heritage' where such activities are not authorised by a development consent under the *Environmental Planning and Assessment Act 1979*. Actions such as tree removal, understory slashing or mowing, or removal of dead trees within this vegetation would likely impact upon this listed species and/or ecological community. Such actions would qualify as illegally picking or disturbing habitat and could render any person who carried out such an action as LIABLE FOR PROSECUTION.

DA/310/2015 Page 38 of 38