

The road widening dedication shall be 1.785 metres (not 1.5 metres) and the face of integral kerb and gutter in Humphries Lane shall be 0.5 metres from the new property boundary in Humphries Lane. An extra kerb inlet pit will be required in front of the electrical transformer to provide for the change of alignment of the kerb to match the existing roll back kerb in front of Lot 1 in Humphries Lane. The existing roll back kerb in Humphries Lane will need removal and the centre of the new RCP will align with the existing drainage pit. Offset drainage will not be permitted as indicated on this drawing. The construction of a new trench immediately adjacent to the existing kerb creates a maintenance problem for Council with differential compaction.

DRG C3.02 Rev C & C3.03 Rev B.

The same issues as drawing C3.01 above, with widening and offset pipe alignment not approved.

DRG C3.05 Rev B

Change road reserve widening in Humphries Lane from 1.5 metres to 1.785 metres. Concrete footpath paving required minimum 0.35 meters between back of kerb and the face of the building for both laneway frontages.

7.3 Road-works

- 7.3.1 Road pavements are to be designed by a Professional Civil Engineer in accordance with the current version of Council's Engineering Guide for Developments and based upon soil tests performed by a registered NATA soils Laboratory and the traffic loadings listed in "Scope of Engineering Works" of this consent. The pavement designs must be lodged with Council for approval prior to issue of the Construction Certificate for Engineering works.
- 7.3.2 A Traffic Management / Control Plan shall be included as part of the Roads Act Approval for road and drainage works to be carried out within public road reserves in strict compliance with the requirements of current Australian Standard 1742.3 (Traffic Control Devices for Works on Roads) and current RTA Traffic Control at Work Sites manual. Any persons preparing such traffic control layout plans shall be RTA accredited.
- 7.3.3 Dedication at no cost to Council of 5m x 5m splay corners on each street laneway intersection (First Avenue/Zolyomi Lane and Humphries Lane/Zolyomi Lane). Road design plans are to reflect the need for this dedication.

7.4 Erosion and Sediment Control

- 7.4.1 Soil erosion and sediment control measures for road, drainage, On Site Stormwater Detention and earth works shall be designed in accordance with Council's Soil Erosion and Sediment Control Policy and Engineering Guide for Development. Details are to be included with the plans and specifications to accompany any Construction Certificate.

These conditions are imposed for the following reasons:

- (a) To ensure compliance with the terms of the relevant Environmental Planning Instruments and/or the Building Code of Australia and/or Council's codes, policies and specifications.
- (b) To ensure that no injury is caused to the amenity of the area, to other persons or to private and public property.
- (c) It is in the public interest that they be imposed.

Kerry Robinson
GENERAL MANAGER

Per _____
Blacktown City Council

7.5 On-Site Detention

- 7.5.1 On-site detention systems within private or common courtyard areas shall be designed so they do not impact on the amenity of the development or the use of such areas.
- 7.5.2 A certificate from a Registered Engineer (NPER) to be submitted to Council certifying that the structures associated with the on-site detention system have been designed to withstand all loads likely to be imposed on them during their lifetime.
- 7.5.3 A certificate from a Professional Civil Engineer/Registered Surveyor must be obtained verifying that the On Site Detention system will function hydraulically in accordance with the requirements of Upper Parramatta River Catchment Trust and Council's current development guide.
- 7.5.4 Any Construction Certificate issued for or including an On-site Stormwater Detention (OSD) System must be accompanied by;
- a. A Drainage Design Summary Sheet per Appendix B1 of the Upper Parramatta River Catchment Trust Handbook, Version 3.
 - b. Full drainage calculations and details for all weirs overland flow-paths and diversion/catch drains - including catchment plans and areas, times of concentration and estimated peak run-off volumes.
 - c. A completed OSD Detailed Design Submission and Checklist per Appendix B9 of the above-mentioned Handbook.
 - d. A complete address of Council's OSD General Guidelines and Checklist requirements.
 - e. A Maintenance Schedule is to be presented with the designer's name, his signature and date on it in accordance with the Upper Parramatta River Catchment Trust handbook guideline. (If an underground tank is involved this must include reference to WorkCover Authority of NSW Occupational Health & Safety Act 1983 and Confined Spaces Regulation.)

7.6 Compaction Requirements

- 7.6.1 Special attention is drawn to the following requirements of Council's current Works Specification – Civil.
- (i) Submission of compaction certificates for road subgrade.
 - (ii) Submission of compaction certificates for road pavement materials.
 - (iii) Certificates from road material suppliers.

7.8 Asset Management

These conditions are imposed for the following reasons:

- (a) To ensure compliance with the terms of the relevant Environmental Planning Instruments and/or the Building Code of Australia and/or Council's codes, policies and specifications.
- (b) To ensure that no injury is caused to the amenity of the area, to other persons or to private and public property.
- (c) It is in the public interest that they be imposed.

Kerry Robinson
GENERAL MANAGER

Per _____
Blacktown City Council

- 7.8.1 A detailed estimate of the cost of civil engineering work must be submitted to Council prior to the issue of the Construction Certificate for engineering works. If engineering works are of a value greater than \$25,000; documentary proof of payment of the levy required by the Building and Construction Industry Long Service Payments Act must be provided to Council prior to any approval of engineering plans either by Council or an appropriately accredited certifier.

7.9 Other Approvals/Clearances/Adjoining Owners Permission.

- 7.9.1 Sydney Water Corporation approval in the form of appropriately stamped Construction Certificate Plans is to be obtained to verify that the proposed works meets the Corporation's requirements relating to water or sewer mains.

7.10 Ancillary Works

- 7.10.1 Ancillary works shall be undertaken at no cost to Council to make the engineering works required by this consent effective. Such works shall include but are not limited to the following:

(a) the relocation of underground services where required by the positioning of new drainage and road infrastructure.

(b) the relocation of above ground power and telephone services.

(c) the matching of new infrastructure into existing or future designed infrastructure.

7.11 Scope of Engineering Works

The following scope of works shall be included in the design documentation accompanying the Construction Certificate for engineering works:

7.11.1 Road and Drainage works

- 7.11.1.1 Proposed new road(s) must be constructed generally as follows:

Name	Width (m)	Length (m)	Formation (m)	Traffic Loading N(E.S.A)
Humphries Lane	1.785m	56m	Widen existing	2 x 10 ⁶

- 7.11.1.2 Redundant gutter and/or footway crossing(s) must be replaced with integral kerb and gutter.

- 7.11.1.3 Humphries Lane must be constructed for the full length of the development on the new road alignment. Appropriate engineering plans are to be submitted and approved prior to construction. The drainage line must be located underneath the kerb line.

- 7.11.1.4 Road widening along Humphries Lane is to be dedicated to Council for public road.

These conditions are imposed for the following reasons:

- (a) To ensure compliance with the terms of the relevant Environmental Planning Instruments and/or the Building Code of Australia and/or Council's codes, policies and specifications.
(b) To ensure that no injury is caused to the amenity of the area, to other persons or to private and public property.
(c) It is in the public interest that they be imposed.

Kerry Robinson
GENERAL MANAGER

Per _____
Blacktown City Council

- 7.11.1.5 Drainage from the site must be connected into Council's existing drainage system in Humphries Lane as described by Warren Smith and Partners Concept Stormwater Management Drawing No. C3.01 Revision C. A detailed application under Section 138 of the Roads Act 1993 for these drainage works will include detailed plans as modified for alignment as required by conditions of this consent.

7.11.2 On Site Stormwater Detention System

7.11.2.1 On Site Detention

(A) On-site detention of stormwater runoff from the site must be provided to achieve the following nominated permissible site discharge and site storage capacity for the following percentages of site area draining to the system. (Absolute minimum site draining area is 80%)

Nominated Discharge PSD: 95 l/s/ha for 100%; 65 l/s/ha for 90%; 36 l/s/ha for 80%.

Nominated Storage SSR: 343 cu.m/ha for 100%; 429 cu.m/ha for 90%; 580 cu.m/ha for 80%.

Intermediate values can be interpolated linearly for PSD and a fair curve through the 3 values for SSR.

Council electronic OSD calculation spread sheet is available for calculating the above parameters. This electronic spread sheet can be obtained upon request from Council Development Services Unit.

- (B) Council acknowledges the submission of the On-site Stormwater Detention concept plans Reference No. C3.01(Rev C), C3.02 (Rev C), C3.03 (Rev B), C4.01 (Rev B), C4.02 (Rev A). The Construction Certificate issued in this regard must generally be in accordance with these concepts.

This plan is considered sufficient in detail for the purpose of issuing Consent the final plan however will need to vary from this concept as follows;

- (i) Calculations as prescribed elsewhere in this consent.

- (C) Any variation to the following design parameters of the above mentioned concept plan will require a lodgement of a Section 96 application to Council for amendment of the consent;

(i) location of storage area

(ii) alteration of the type of storage - i.e changing from above ground to below ground storage

(iii) location of discharge outlet from the system.

- (D) Professional accreditation of OSD designers and certifiers must be in accordance with the requirements of Council's Policy.

These conditions are imposed for the following reasons:

- (a) To ensure compliance with the terms of the relevant Environmental Planning Instruments and/or the Building Code of Australia and/or Council's codes, policies and specifications.
(b) To ensure that no injury is caused to the amenity of the area, to other persons or to private and public property.
(c) It is in the public interest that they be imposed.

Kerry Robinson
GENERAL MANAGER

Per _____
Blacktown City Council

- (E) The concept plan referred to above is for Development Application purposes only and is not to be used for construction.
- (F) Comprehensive design plans showing full construction details must be prepared by an accredited OSD designer to be issued with a Construction Certificate under the Environmental Planning and Assessment Act 1979 prior to the commencement of works.

NOTE: Council has preference for a fully above ground On-site Stormwater Detention system. This type of system would significantly reduce confined space issues and may have cost saving advantages in comparison with a below ground storage system.

7.11.3 Vehicular Crossings

- 7.11.3.1 Construction of Council's standard commercial and industrial vehicular footway crossing(s), with the following nominated width(s) at the property boundary in accordance with Council plan A(BS)103S.

Nominated Widths: as nominated on the plan

7.11.4 Footpaths

- 7.11.4.1 The construction of path paving is to be provided to the following nominated street(s)/road(s):

Laneways 0.35 metres minimum width

- 7.11.4.2 Any footway area must be constructed to CBD standards from the property boundary to the back of kerb. The design is to be in accordance with the specifications attached to this consent (plan no. A(BS)178M Rev 1.
- 7.11.4.3 The existing layback located on the First Avenue frontage (near Zolyomi Lane) is to be removed and replaced with kerb and gutter. The footway area may need to be reinstalled to meet new levels.

7.11.5 Finished Boundary Levels

- 7.11.5.1 Finished levels of all internal works at the road boundary of the property must be:

(a) 4% above the top of the kerb.

(b) 4% above the top of the kerb edge of the existing concrete path paving on the property side.

(c) Fixed by Council's Manager Investigation and Design who can be contacted on 9839 6000

These conditions are imposed for the following reasons:

- (a) To ensure compliance with the terms of the relevant Environmental Planning Instruments and/or the Building Code of Australia and/or Council's codes, policies and specifications.
- (b) To ensure that no injury is caused to the amenity of the area, to other persons or to private and public property.
- (c) It is in the public interest that they be imposed.

Kerry Robinson
GENERAL MANAGER

Per _____
Blacktown City Council

8 PRIOR TO DEVELOPMENT WORKS

8.1 Safety/Health/Amenity

- 8.1.1 Toilet facilities shall be provided on the land at the rate of 1 toilet for every 20 persons or part thereof employed at the site.

Each toilet provided shall be:

- (a) a standard flushing toilet, or
- (b) a temporary on-site toilet which is regularly maintained and the waste disposed to an approved sewerage management facility.

- 8.1.2 A sign is to be erected and maintained in a prominent position on the site in accordance with Clause 98 A (2) of the Environmental Planning and Assessment Regulations 2000 indicating:

- (a) the name, address and telephone number of the principal certifying authority for the work, and
- (b) the name of the principal contractor (if any) for the building work and a telephone number on which that person may be contacted outside working hours, and
- (c) stating that unauthorised entry to the work site is prohibited.

This condition does not apply to:

- (a) building work carried out inside an existing building, or
- (b) building work carried out on premises that are to be occupied continuously (both during and outside working hours) while the work is being carried out.

- 8.1.3 Should the development work:

- (a) be likely to cause pedestrian or vehicular traffic in a public place to be obstructed or rendered inconvenient, or
- (b) involve the enclosure of a public place,

a hoarding or protective barrier shall be erected between the work site and the public place. Such hoarding or barrier shall be designed and erected in accordance with Council's current Local Approvals Policy under the Local Government Act 1993.

Where necessary, an awning shall be erected, sufficient to prevent any substance from, or in connection with, the work falling into the public place.

The hoarding, awning or protective barrier shall be effectively illuminated between sunset and sunrise where it may be hazardous to any person in the public place.

These conditions are imposed for the following reasons:

- (a) To ensure compliance with the terms of the relevant Environmental Planning Instruments and/or the Building Code of Australia and/or Council's codes, policies and specifications.
- (b) To ensure that no injury is caused to the amenity of the area, to other persons or to private and public property.
- (c) It is in the public interest that they be imposed.

Kerry Robinson
GENERAL MANAGER

Per _____
Blacktown City Council

- 8.1.4 Soil erosion and sediment control measures shall be provided in accordance with Council's Soil Erosion and Sediment Control Policy.
- 8.1.5 All soil erosion and sedimentation control measures indicated in the documentation accompanying the Construction Certificate shall be installed prior to the commencement of development works.
- 8.1.6 A single vehicle/plant access to the land shall be provided to minimise ground disturbance and transport of soil onto any public place. Such access shall be provided in accordance with the requirements of Appendix "F" of Council's Soil Erosion and Sediment Control Policy. Single sized 40mm or larger aggregate placed 150mm deep, and extending from the street kerb/road shoulder to the land shall be provided as a minimum.
- 8.1.7 Any excavation and/or backfilling associated with the development shall be executed safely and in accordance with appropriate professional standards, with any excavation properly guarded and protected to prevent such work being dangerous to life or property.
- 8.1.8 Should any excavation associated with the development extend below the level of the base of the footings of a building or any other structure on any adjoining allotment of land (including a public place), that building or structure:
- (a) shall be preserved and protected from damage, and
 - (b) if necessary, shall be underpinned and supported in accordance with structural design details accompanying the Construction Certificate, and
 - (c) the owner(s) of which shall, at least 7 days before any such excavation or supporting work commences, be given notice of such intention and particulars of the excavation or supporting work.

8.2 Notification to Council

- 8.2.1 The person having the benefit of this consent shall, at least 2 days prior to work commencing on site, submit to Council a notice under Clauses 135 and 136 of the Environmental Planning and Assessment Regulation 2000, indicating details of the appointed Principal Certifying Authority and the date construction work is proposed to commence.
- 8.2.2 At least five (5) full working days written notice must be given for the commencement of engineering works. Such notice must be accompanied by evidence of the contractors Public Liability and Workers Compensation Insurances. For Public Liability Insurance this should be a minimum amount of \$20,000,000.

8.3 Sydney Water Authorisation

- 8.3.1 Sydney Water Corporation's approval, in the form of appropriately stamped Construction Certificate plans, shall be obtained and furnished to the Principal Certifying Authority to verify that the development meets the Corporation's

These conditions are imposed for the following reasons:

- (a) To ensure compliance with the terms of the relevant Environmental Planning Instruments and/or the Building Code of Australia and/or Council's codes, policies and specifications.
- (b) To ensure that no injury is caused to the amenity of the area, to other persons or to private and public property.
- (c) It is in the public interest that they be imposed.

Kerry Robinson
GENERAL MANAGER

Per _____
Blacktown City Council

requirements concerning the relationship of the development to any water mains, sewers or stormwater channels.

OR

The approved plans are to be submitted to a Sydney Water Customer Centre or Quick Check Agent, to determine whether the development will affect Sydney Water's sewer and water mains, stormwater drains and/or easements and if further requirements need to be met. The plans must be appropriately stamped and all amended plans will require restamping. For Quick Check Agent details, please refer to the "Building Plumbing and Developing" Section of the website www.sydneywater.com.au, then follow the "Developing Your Land" link or telephone 13 20 92 for assistance.

8.4 Construction Details

- 8.4.1 Structural details of the nominated building component(s), prepared and/or certified by a professional engineer or other appropriately qualified person, shall be lodged with Council prior to commencing or erecting that portion of the approved development.

Nominated Component

- (a) Footing piers
- (b) Footing system
- (c) Floor slab
- (d) Structural concrete
- (e) Wall frame bracing
- (f) Roof trusses
- (g) Structural steelwork
- (h) Retaining walls

8.5 Use of Crane

- 8.5.1 Any crane used in the construction of this development must have approval under the Roads Act 1993 from Council to swing over public air spaces.
- 8.5.2 The crane used must be provided with a light in accordance with the requirements of the Civil Aviation Authority (CASA) requirement. This may require a separate approval from CASA.

9 DURING CONSTRUCTION (BUILDING)

9.1 Safety/Health/Amenity

- 9.1.1 The required toilet facilities shall be maintained on the land at the rate of 1 toilet for every 20 persons or part of 20 persons employed at the site.

These conditions are imposed for the following reasons:

- (a) To ensure compliance with the terms of the relevant Environmental Planning Instruments and/or the Building Code of Australia and/or Council's codes, policies and specifications.
- (b) To ensure that no injury is caused to the amenity of the area, to other persons or to private and public property.
- (c) It is in the public interest that they be imposed.

Kerry Robinson
GENERAL MANAGER

Per _____
Blacktown City Council

- 9.1.2 A sign is to be erected and maintained in a prominent position on the site in accordance with Clause 98 A (2) of the Environmental Planning and Assessment Regulations 2000 indicating:
- (a) the name, address and telephone number of the principal certifying authority for the work, and
 - (b) the name of the principal contractor (if any) for the building work and a telephone number on which that person may be contacted outside working hours, and
 - (c) stating that unauthorised entry to the work site is prohibited.
- 9.1.3 Should the development work:
- (a) be likely to cause pedestrian or vehicular traffic in a public place to be obstructed or rendered inconvenient, or
 - (b) involves the enclosure of a public place,
- the required hoarding, awning or protective barrier shall be maintained between the land and the public place.
- The hoarding, awning or protective barrier shall be effectively illuminated between sunset and sunrise where it may be hazardous to persons in the public place.
- 9.1.4 Soil erosion and sediment control measures (including the connection of roofwater downpipes to stormwater drainage lines upon fixing of roof covering) shall be maintained during the development works.
- 9.1.5 All measures specified in the Construction Certificate to control soil erosion and sedimentation shall be maintained throughout development works.
- 9.1.6 A single vehicle/plant access to the land shall be maintained to minimise ground disturbance and transport of soil onto any public place. Such access shall be maintained in accordance with the requirements of Appendix "F" of Council's Soil Erosion and Sediment Control Policy. As a minimum, single sized 40mm or larger aggregate placed 150mm deep, and extending from the street kerb/road shoulder to the land shall be provided.
- 9.1.7 Any excavation and/or backfilling associated with the ongoing development works shall be executed safely and in accordance with appropriate professional standards, with any excavation properly guarded and protected to prevent them from being dangerous to life or property.
- 9.1.8 Should any excavation associated with the ongoing development works extend below the level of the base of the footings of a building or any other structure on any adjoining allotment of land (including a public place), that building or structure:
- (a) shall be preserved and protected from damage, and
 - (b) if necessary, shall be underpinned and supported in accordance with

These conditions are imposed for the following reasons:

- (a) To ensure compliance with the terms of the relevant Environmental Planning Instruments and/or the Building Code of Australia and/or Council's codes, policies and specifications.
- (b) To ensure that no injury is caused to the amenity of the area, to other persons or to private and public property.
- (c) It is in the public interest that they be imposed.

Kerry Robinson
GENERAL MANAGER

Per _____
Blacktown City Council

- (c) structural design details accompanying the Construction Certificate, and the owner(s) of which shall, at least 7 days before any such excavation or supporting works be given notice of such intention and particulars of the excavation or supporting works.

9.1.9 Building and construction materials, plant, equipment and the like shall not to be placed or stored at any time on Council's footpath, roadway or any public place.

9.2 Building Code of Australia Compliance

9.2.1 All building work shall be carried out in accordance with the provisions of the Building Code of Australia.

9.3 Surveys

9.3.1 The building(s) shall be set out by a registered surveyor and a survey report lodged with the Principal Certifying Authority to verify the approved position of each structure in relation to the property boundaries.

9.3.2 A registered surveyor's report confirming the approved design ground and/or floor levels, shall be lodged with the Principal Certifying Authority prior to work proceeding above floor level.

9.4 Nuisance Control

9.4.1 Any objectionable noise, dust, concussion, vibration or other emission from the development works shall not exceed the limit prescribed in the Protection of the Environment Operations Act 1997.

9.4.2 The hours of any offensive noise-generating development works shall be limited to between 7.00am to 6.00pm, Mondays to Fridays: 8.00am to 1pm, Saturdays; and no such work to be undertaken at any time on Sundays or public holidays.

9.4.3 Construction work on all buildings (except that on single dwelling houses and associated structures on the on the site of a single dwelling house) shall not occur on Saturdays and Sundays on weekends adjacent to a public holiday.

9.5 Stormwater Drainage

9.5.1 Stormwater, surface water and sub-surface seepage (other than natural flows) shall be prevented from entering the building or being diverted onto any adjoining land (as applicable) by:

- (a) the floor level being a minimum 225mm above the adjoining finished ground level, and/or
- (b) being drained to an effective drainage system.

9.6 Waste Control

These conditions are imposed for the following reasons:

- (a) To ensure compliance with the terms of the relevant Environmental Planning Instruments and/or the Building Code of Australia and/or Council's codes, policies and specifications.
- (b) To ensure that no injury is caused to the amenity of the area, to other persons or to private and public property.
- (c) It is in the public interest that they be imposed.

Kerry Robinson
GENERAL MANAGER

Per _____
Blacktown City Council

- 9.6.1 The waste material sorting, storage and re-use requirements of the approved Waste Management Plan and Council's Site Waste Management and Minimisation Development Control Plan shall be implemented during the course of development works.

9.7 Construction Inspections

- 9.7.1 The person having the benefit of this consent is required to notify the Principal Contractor for the building construction project that various mandatory and critical stage inspections must be conducted by an accredited certifier, and may include inspections (where applicable):

(a) After excavation for, and prior to placement of, any footings; and

(b) Prior to pouring any in-situ reinforced concrete building element; and

(c) Prior to the covering of the framework for any floor, wall roof or other building element, and prior to covering waterproofing in any wet areas; and

(d) Prior to covering waterproofing in any wet areas (but for a minimum of 10% of rooms with wet areas in any class 2,3 or 4 building); and

(e) Prior to covering any stormwater drainage connections; and

(f) After the building work has been completed and prior to any Occupation Certificate being issued in relation to the building.

The critical stage inspection "(f)" must be carried out by the Principal Certifying Authority.

Any inspection conducted by an accredited other than the nominated PCA for the project must be verified by way of a Compliance Certificate issued for the relevant works.

Note: Failure to ensure the relevant inspections are conducted will preclude the issue of an Occupation Certificate.

9.8 Site Contamination

- 9.8.1 All areas identified as being contaminated shall be remediated in accordance with the recommendations of the submitted Remediation Action Plan (RAP) prepared by Douglas Partners (Project 85295.02 dated February 2016) and held at Enclosure 116A on Council's file JRPP-15-2087/4.

- 9.8.2 Upon completion of the remediation an appropriately qualified environmental consultant shall prepare a validation report. The validation report shall be carried out in accordance with:

These conditions are imposed for the following reasons:

- (a) To ensure compliance with the terms of the relevant Environmental Planning Instruments and/or the Building Code of Australia and/or Council's codes, policies and specifications.
- (b) To ensure that no injury is caused to the amenity of the area, to other persons or to private and public property.
- (c) It is in the public interest that they be imposed.

Kerry Robinson
GENERAL MANAGER

Per _____
Blacktown City Council

- NSW Environment Protection Authority's *Guidelines for Consultants Reporting on Contaminated Sites* (1997)
- NSW Environment Protection Authority's *Contaminated Sites Sampling Design Guidelines* (1995).
- Australian and New Zealand Environment and Conservation Council and National Health and Medical Research Council's *Australian and New Zealand Guidelines for the Assessment and Management of Contaminated Sites* (1992).

A suitably qualified environmental consultant shall review the validation report and submit to Council a Site Audit Statement. The Site Audit Statement shall verify that the investigation, remediation and validation was carried out in accordance with the aforementioned guidelines and that the site is suitable for the proposed use.

- 9.8.3 Should any further contaminated material be unearthed or fly-tipped rubbish be encountered during construction, all works are to cease immediately. In this situation, an amended Remediation Action Plan (RAP) is to be submitted to Council's Manager, Development Services for further consideration and all potentially contaminated material is to be tested, removed or undergo remediation. In this regard, the environmental consultant engaged for this project is to be on site for regular monitoring of the approved site works.
- 9.8.4 Throughout the duration of the works, the applicant is to demonstrate compliance with the following approval parameters:
- a) The applicant is to ensure that validation for the entire subject site can be prepared by a suitably qualified environmental consultant in accordance with Council's Contamination Land Policy.
 - b) The applicant is to ensure that the site has been satisfactorily secured so as to prevent any unauthorised dumping of illegal fill/waste building materials (i.e. non-V.E.N.M soils) from entering onto the development site.
 - c) Appropriate dust suppression measures are to be incorporated into the site works process, so as to ensure that adjoining properties in the local vicinity are not negatively impacted upon by dust generated from the development site.
 - d) Any filling shall be undertaken in accordance with the fill protocol approved by Council's Manager, Development Assessment.

Should Council receive any complaints regarding non-compliance with any of the above matters or other such operational type matters, then Council will have no alternative but to fully investigate the complaint and pursue an appropriate course of action.

9.5 Aboriginal Archaeology

- 9.5.1 Should any archaeological material be uncovered during construction activities on

These conditions are imposed for the following reasons:

- (a) To ensure compliance with the terms of the relevant Environmental Planning Instruments and/or the Building Code of Australia and/or Council's codes, policies and specifications.
- (b) To ensure that no injury is caused to the amenity of the area, to other persons or to private and public property.
- (c) It is in the public interest that they be imposed.

Kerry Robinson
GENERAL MANAGER

Per _____
Blacktown City Council

any location within the approved development, then all works are to cease immediately and representatives of the Office of Environment & Heritage (OEH) and a member of each of the Western Sydney Aboriginal Stakeholder Groups is to be contacted.

9.6 Salinity and Aggressive Soil Management

- 9.6.1 All salinity management measures provided in the Geotechnical and Salinity Assessment Report required by the 'Pre-Construction Certificate' condition of this consent shall be implemented during construction.

9.7 Waste Management

- 9.7.1 The measures outlined in the submitted Waste Management Plan, must be implemented during the demolition and construction phases of the development. This includes the sorting and storage of waste and recyclable building materials on site for collection and disposal by the nominated waste/recycling contractor to the nominated disposal site.

Note: The developer is to retain receipts from the waste/recycling disposal contractor or some form of evidence of compliance with the Waste Management Plan. This information is to be submitted to Council prior to issue of any Occupation Certificate.

10 DURING CONSTRUCTION (ENGINEERING)

10.1 Notice of work Commencement

- 10.1.1 At least 5 full working days written notice shall be given of the commencement of engineering works. Such notice shall be accompanied by evidence of the contractor's Public Liability and Workers Compensation Insurances. For Public Liability Insurance this should be a minimum of \$20,000,000.

10.2 Service Authority Approvals

- 10.2.1 Prior to commencement of construction of footway crossings a clearance shall be obtained from the relevant telecommunications carriers and Integral Energy that all necessary ducts have been provided under the proposed crossing.

10.3 Boundary Levels

- 10.3.1 Any construction at the property boundary, including fences and driveways shall not be carried out until alignment levels have been fixed.

10.4 Compaction Requirements

- 10.4.1 Removal of any unsuitable soil and/or fill material and its replacement with suitable material compacted in accordance with the current version of Council's "Works Specification - Civil".

These conditions are imposed for the following reasons:

- (a) To ensure compliance with the terms of the relevant Environmental Planning Instruments and/or the Building Code of Australia and/or Council's codes, policies and specifications.
- (b) To ensure that no injury is caused to the amenity of the area, to other persons or to private and public property.
- (c) It is in the public interest that they be imposed.

Kerry Robinson
GENERAL MANAGER

Per _____
Blacktown City Council

10.4.2 Special attention is drawn to the following requirements of Council's Works Specification - Civil (Current Version):

(a) Submission of compaction certificates for fill within road reserves.

(b) Submission of compaction certificates for road sub-grade.

(c) Submission of compaction certificates for road pavement materials (sub-base and base courses).

(d) Compliance Certificates from road material suppliers.

10.5 Maintenance of Soil Erosion Measures

10.5.1 Soil erosion and sediment control measures shall be implemented in accordance with Council's Soil Erosion and Sediment Control Policy.

10.5.2 All required soil erosion and sediment control measures are to be maintained during the entire construction period until disturbed areas are restored by turfing paving or revegetation. Infringement Notices incurring a monetary penalty may be issued by Council where the maintenance of measures is inadequate.

10.6 Filling of Land & Compaction

10.6.1 Regular wetting down of the site must be undertaken during the course of works being carried out in order to control wind blown dust from the site.

10.6.2 Roads adjoining the site must be kept clean and free of all excavated /transportable spoil materials.

10.6.3 Trucks transporting fill must have their loads covered

10.6.4 Provisions of "Shaker Pads" and wash-down areas for trucks leaving the site details are to be shown on plans.

10.6.5 Only clean fill shall be deposited on site in accordance with Council's Works Specification - Civil (Current Version). Note: dry builder's waste i.e. bricks plaster and timber industrial waste or putrescible materials are not to be deposited on site.

10.7 Inspections of Works

10.7.1 Inspection Compliance Certificates issued by a Registered Engineer (NPER) or Registered Surveyor or Compliance Certificates issued by an accredited certifier, under Part A of Environmental Planning and Assessment Act 1979 as amended, are to be issued for works covered by the Construction Certificate for engineering works at the completion of the following mandatory inspection stages: -

These conditions are imposed for the following reasons:

- (a) To ensure compliance with the terms of the relevant Environmental Planning Instruments and/or the Building Code of Australia and/or Council's codes, policies and specifications.
- (b) To ensure that no injury is caused to the amenity of the area, to other persons or to private and public property.
- (c) It is in the public interest that they be imposed.

Kerry Robinson
GENERAL MANAGER

Per _____
Blacktown City Council

(i) Soil Erosion and Sediment Control

- (a) Implementation of erosion and sediment control
- (b) Revegetation of disturbed areas
- (c) Construction of major controls (i.e gabions mattresses shotcreting etc)
- (d) Removal of sediment basins/ fencing etc.
- (e) Internal sediment/ pollution control devices
- (f) Final Inspection

(ii) Traffic Control

- (a) Implementation of traffic control
- (b) Maintenance of traffic control during works
- (c) Removal of traffic control

(iii) Construction of Drainage works

- (a) Pipes before backfilling including trench excavation and bedding
- (b) Sand Backfilling
- (c) Final pipe inspection
- (d) Pit bases and headwall aprons
- (e) Pit Walls/ wingwalls/ headwalls
- (f) Concrete pit tops
- (g) Connection to existing system
- (h) Tailout works
- (i) Final Inspection

(iv) Construction of Road Pavement

- (a) Boxing out
- (b) Sub-grade roller test
- (c) Subsoil drainage
- (d) Sandstone roller test layer 1
- (e) Sandstone roller test layer 2
- (f) Kerb pre-laying
- (g) Kerb during laying including provision of roof-water outlets
- (h) Sandstone depth
- (i) Pavement profiles
- (j) DGB depths and roller tests
- (k) Wearing Course
- (l) Kerb final
- (m) Concrete tests
- (n) Formwork concrete pavements
- (o) Final inspection

(vi) Footpath Works

- (a) Footpath Trimming and/or turfing (to ensure 4% fall)

These conditions are imposed for the following reasons:

- (a) To ensure compliance with the terms of the relevant Environmental Planning Instruments and/or the Building Code of Australia and/or Council's codes, policies and specifications.
- (b) To ensure that no injury is caused to the amenity of the area, to other persons or to private and public property.
- (c) It is in the public interest that they be imposed.

Kerry Robinson
GENERAL MANAGER

Per _____
Blacktown City Council

- (b) Pathway construction (cycle/ link pathways)
- (c) Path-paving construction
- (d) Service Adjustments
- (e) Final Inspection

(vii) Construction of on-site detention system

- (a) Steel and Formwork for tank/ HED control pit
- (b) Completion of HED control pit
- (c) Pit formwork
- (d) Pipes upstream/ downstream of HED control pit before backfilling
- (e) Completion of OSD system

(ix) Traffic Control

- (a) Implementation of traffic control
- (b) Maintenance of traffic control during works

(x) CCTV Inspection of Drainage Structures (pipelines and pits)

(a) All road drainage

(xi) Final overall Inspections

- (a) Preliminary overall final inspection
- (b) Overall final inspection

ALTERNATIVELY, one comprehensive Inspection Certificate or Compliance certificate may be issued to include all of the above-mentioned stages of construction.

Where Council is appointed as the Principal Certifying Authority for the development (e.g. all Torrens Title subdivisions), only Compliance Certificates issued by accredited certifiers will be accepted at the completion of the above-mentioned stages. Any Compliance Certificate must certify that the relevant work has been completed in accordance with the pertinent Notice of Determination / Development Consent and Construction certificate.

- 10.7.2 Inspection of the works required pursuant to the engineering approval issued under the Roads Act 1993 must be made by Council's Development Overseers who can be contacted on 9839 6586 between 7am - 8am and 12.30pm - 1.30pm. A site inspection is required prior to commencement of work. A minimum twenty-four (24) hours notice must be given prior to any required inspection. A schedule of mandatory inspections is listed in Council's Works Specification – Civil (current version).

10.8 Public Safety

These conditions are imposed for the following reasons:

- (a) To ensure compliance with the terms of the relevant Environmental Planning Instruments and/or the Building Code of Australia and/or Council's codes, policies and specifications.
- (b) To ensure that no injury is caused to the amenity of the area, to other persons or to private and public property.
- (c) It is in the public interest that they be imposed.

Kerry Robinson
GENERAL MANAGER

Per _____
Blacktown City Council

- 10.8.1 The applicant is advised that all works undertaken in a public place are to be maintained in a safe condition at all times. Council may at any time and without prior notification make safe any such works Council considers to be unsafe and recover all reasonable costs incurred from the applicant.

10.9 Site Security

- 10.9.1 Chain wire gates and security fencing must be provided around the site in order to prevent unauthorised access and dumping of rubbish.

11 PRIOR TO OCCUPATION CERTIFICATE

11.1 Road Damage

- 11.1.1 The cost of repairing any damage caused to Council's assets in the vicinity of the land as a result of the development works shall be met in full by the applicant/developer.

Note: Should the cost of damage repair work not exceed the road maintenance bond Council will automatically call up the bond to recover its costs. Should the repair costs exceed the bond amount a separate invoice will be issued.

11.2 Compliance with Conditions

- 11.2.1 An Occupation Certificate shall not be issued until such time as all conditions of this consent, other than "Operational" conditions, have been satisfied. The use or occupation of the development prior to compliance with all conditions of consent, other than "Operational" conditions, may render the applicant/developer liable to legal proceedings.
- 11.2.2 Prior to occupation/use of a new building, it is necessary to obtain an Occupation Certificate from the Principal Certifying Authority in accordance with the provisions of Section 109H of the Environmental Planning & Assessment Act 1979.

11.3 Temporary Facilities Removal

- 11.3.1 Any hoarding or similar barrier erected to protect a public place shall be removed from the land and/or public place.
- 11.3.2 Any temporary toilet facilities provided during construction works shall be appropriately dismantled, disconnected and removed from the land.
- 11.3.3 Any temporary soil erosion control measure installed during development works shall be removed and other permanent measures required by Council's Soil Erosion Control Policy shall be provided.
- 11.3.4 Any temporary builder's sign or other site information sign shall be removed from the land.

These conditions are imposed for the following reasons:

- (a) To ensure compliance with the terms of the relevant Environmental Planning Instruments and/or the Building Code of Australia and/or Council's codes, policies and specifications.
- (b) To ensure that no injury is caused to the amenity of the area, to other persons or to private and public property.
- (c) It is in the public interest that they be imposed.

Kerry Robinson
GENERAL MANAGER

Per _____
Blacktown City Council

- 11.3.5 Any temporary site access provided for the purpose of development works shall be removed and the kerb and gutter and/or previous roadworks reinstated in a manner satisfactory to Council. Should the reinstatement involve the provision of a new vehicular crossing, layback, kerb and gutter or road shoulder works the separate approval of Council's Maintenance Section shall be obtained (and any appropriate fees paid) prior to such works commencing.

11.4 Service Authorities

- 11.4.1 A final written clearance shall be obtained from Sydney Water Corporation, Endeavour Energy and Telstra (or any other recognised communication carrier) if such clearance (in the form of a Section 73 Certificate, Notification of Arrangement, etc) has not previously been issued.

- 11.4.2 The following documentary evidence shall accompany any Occupation Certificate:

- (a) A Section 73 Compliance Certificate under the Sydney Water Act 1994 must be obtained. Applications must be made through an authorised Water Servicing Coordinator. Please refer to the "Building Plumbing and Developing" Section of the website www.sydneywater.com.au, then follow the "Developing Your Land" link or telephone 13 20 92 for assistance. Following application a "Notice of Requirements" will advise of water and sewer extensions to be built and charges to be paid. Please make early contact with the Coordinator since building of water/sewer extensions can be time consuming and may impact on other services and building, driveway or landscape design. The Section 73 Certificate must be submitted to the Principal Certifying Authority prior to the occupation of the development.

11.5 Fire Safety Certificate

- 11.5.1 An interim or final fire safety certificate complying with Clause 153 of the Environmental Planning and Assessment Regulation 2000 shall be issued prior to the use or change of use of the building, except in the case of any Class 1a and Class 10 building(s).

- 11.5.2 A final fire safety certificate complying with Clause 153 of the Environmental Planning and Assessment Regulation 2000 shall be issued prior to the use or change of use of the building, except in the case of any Class 1a and Class 10 building(s).

11.6 Fee Payment

- 11.6.1 Any fee payable to Council as part of a Construction, Compliance or Occupation Certificate or inspection associated with the development (including the registration of privately issued certificates) shall be paid in full.

11.7 Engineering Matters

These conditions are imposed for the following reasons:

- (a) To ensure compliance with the terms of the relevant Environmental Planning Instruments and/or the Building Code of Australia and/or Council's codes, policies and specifications.
(b) To ensure that no injury is caused to the amenity of the area, to other persons or to private and public property.
(c) It is in the public interest that they be imposed.

Kerry Robinson
GENERAL MANAGER

Per _____
Blacktown City Council

11.7.1 Surveys/Certificates/Works As Executed plans

- 11.7.1.1 A Work-As-Executed plan (to a standard suitable for scanning) signed by a Chartered Professional Engineer or a Registered Surveyor must be lodged with Blacktown City Council when the engineering works are completed. Council requires the Work-As-Executed plans to be submitted in both hardcopy and electronically on a CD (in PDF and DWG format). All engineering Work-As-Executed plans MUST be prepared on a copy of the original, stamped Construction Certificate plans for engineering works. The works as executed plan must confirm that the On Site Detention system identification plate has been installed in accordance with the Upper Parramatta River Catchment Trust Guidelines. The On Site Detention system identification plate can be purchased from Upper Parramatta River Catchment Trust or Council.
- 11.7.1.2 A certificate from a Chartered Professional Engineer/Registered Surveyor must be obtained and submitted to Council verifying that the on-site detention system as constructed will function hydraulically in accordance with the approved design plans.
- 11.7.1.3 Special attention is drawn to the following requirements of Council's Works Specification - Civil (Current Version):
- (a) Submission of compaction certificates for fill within road reserves.
 - (b) Submission of compaction certificates for road sub-grade.
 - (c) Submission of compaction certificates for road pavement materials (sub base and base courses).
 - (d) Compliance Certificates from road material suppliers.
- 11.7.1.4 The submission to Council of all Inspection/Compliance Certificates required by the "During Construction (Engineering)" Section of this consent.

11.7.2 Easements/Restrictions/Positive Covenants

- 11.7.2.1 Restrictions and positive covenants must be registered with Land and Property Information over the on-site detention storage areas and outlet works.
- 11.7.2.2 Restrictions and/ or positive covenant must be registered with Land and Property Information over the overland flow-path.
- 11.7.2.3 All Section 88B restrictions and covenants created, as part of this consent shall contain a provision that they cannot be extinguished or altered except with the consent of Blacktown City Council.

11.8 Security

These conditions are imposed for the following reasons:

- (a) To ensure compliance with the terms of the relevant Environmental Planning Instruments and/or the Building Code of Australia and/or Council's codes, policies and specifications.
- (b) To ensure that no injury is caused to the amenity of the area, to other persons or to private and public property.
- (c) It is in the public interest that they be imposed.

Kerry Robinson
GENERAL MANAGER

Per _____
Blacktown City Council