Carr - Catherine

From: Dataworks

Subject: FW: Filter Backwash

From: Chris Acevski [mailto:Chris.Acevski@qhd.com]

Sent: Monday, 9 May 2016 10:24 AM

To: Silver-Mike

Subject: FW: Filter Backwash

Hi Mike,

Hope this clarifies the back wash requirements

Cheers chris

From: Daniel Bestmann Subject: Filter Backwash

Chris,

As discussed over the phone. Please let me know if you require any additional information.

Operating Assumptions

- Based on one backwash cycle per week for each filtration system
 - o NOTE: During high demand periods (summer) that the filtration system may require up to 2 backwash cycles per week

Backwash Loads

50m Pool Backwash Volume Allowance – 75 kL Kids Wet Play Area Backwash Volume Allowance – 15 kL 25 Indoor Pool (Stage 2) Backwash Volume Allowance – 45 kL

Sewer Load from Filter Backwashing

- Approx. 90 kL per week in Stage 1
- Approx. 135 kL per week in Stage 2

Backwash Discharge to Sewer

Whilst the are no standards on discharging backwash water to sewer, normal practice would be to lease the water to sewer at 1-2 L/s.

For the design, allow to discharge backwash water to sewer at 2 L/s. This would allow the backwash tank to drain within 24 hours to allow another backwash cycle to occur the next day.

Regards

Daniel Bestmann

Civil Engineer

GHD

T: 61 7 4720 0482 | V: 420 482 | E: daniel.bestmann@ghd.com
Level 1 42 Sturt St Townsville Qld 4810 Australia | www.ghd.com
WATER | ENERGY & RESOURCES | ENVIRONMENT | PROPERTY & BUILDINGS | TRANSPORTATION

Please consider our environment before printing this email

CONFIDENTIALITY NOTICE: This email, including any attachments, is confidential and may be privileged. If you are not the intended recipient please notify the sender immediately, and please delete it; you should not copy it or use it for any purpose or disclose its contents to any other person. GHD and its affiliates reserve the right to monitor and modify all email communications through their networks.

Click here to report this email as spam.