



TELEPHONE: (02) 93946627
EMAIL: development@ausgrid.com.au
REFERENCE: TRIM 2017/10/50

ATTN: Alice Pettini
Assessment Officer
PO Box 8
Bankstown NSW 1885

570 George Street
Sydney NSW 2000
All mail to GPO Box 4009
Sydney NSW 2001
T +61 2 131 525
F +61 2 9269 2830
www.ausgrid.com.au

Re: DA-462/2016 - 918-935 Canterbury Road & 2 Dreadnought Street, Roselands - Demolition of existing structures and construction of a mixed use development consisting of 98 residential units.

I refer to Canterbury-Bankstown City Council development application DA-462/2016.

This letter is Ausgrid's response under clause 45(2) of the State Environmental planning Policy (Infrastructure) 2007.

The assessment and evaluation of environmental impacts for a new development consent (or where a development consent is modified) is undertaken in accordance with requirements of Section 79C of the Environmental Planning and Assessment Act 1979. One of the obligations upon consent authorities, such as local councils, is to consider the suitability of the site for the development which can include a consideration of whether the proposal is compatible with the surrounding land uses and the existing environment.

In this regard, Ausgrid requires that due consideration be given to the compatibility of proposed development with existing Ausgrid infrastructure, particularly in relation to risks of electrocution, fire risks, Electric & Magnetic Fields (EMFs), noise, visual amenity and other matters that may impact on Ausgrid or the development.

With Regard to: Demolition of existing structures and construction of a mixed use development consisting of 98 residential units. at 918-935 Canterbury Road & 2 Dreadnought Street, Roselands

- Notification Plans

Ausgrid consents to the above mentioned development subject to the following conditions:-

Method of Electricity Connection

The method of connection will be in line with Ausgrid's Electrical Standard (ES)1 – 'Premise Connection Requirements.

Supply of Electricity

It is recommended for the nominated electrical consultant/contractor to provide a preliminary enquiry to Ausgrid to obtain advice for the connection of the proposed development to the adjacent electricity network infrastructure. An assessment will be carried out based on the enquiry which may include whether or not:

- The existing network can support the expected electrical load of the development
- A substation may be required on-site, either a pad mount kiosk or chamber style and;
- site conditions or other issues that may impact on the method of supply.

Please direct the developer to Ausgrid's website, www.ausgrid.com.au about how to connect to Ausgrid's network.

Conduit Installation

The need for additional electricity conduits in the footway adjacent to the development will be assessed and documented in Ausgrid's Design Information, used to prepare the connection project design.

Streetlighting

The developer is to consider the impact that existing streetlighting and any future replacement streetlighting and maintenance may have on the development. Should the developer determine that any existing streetlighting may impact the development, the developer should either review the development design, particular the placement of windows, or discuss with Ausgrid the options for relocating the streetlighting. The relocating of any streetlighting will generally be at the developers cost. In many cases is not possible to relocate streetlighting due to its strategic positioning.

Proximity to Existing Network Assets

Overhead Powerlines

There are existing overhead electricity network assets in Canterbury Rd, Remly St and Dreadnought St. Safework NSW Document – Work Near Overhead Powerlines: Code of Practice, outlines the minimum safety separation requirements between these mains/poles to structures within the development throughout the construction process. It is a statutory requirement that these distances be maintained throughout construction. Special consideration should be given to the positioning and operating of cranes and the location of any scaffolding.

The “as constructed” minimum clearances to the mains should also be considered. These distances are outlined in the Ausgrid Network Standard, NS220 Overhead Design Manual. This document can be sourced from Ausgrid’s website, www.ausgrid.com.au

Should the existing overhead mains require relocating due to the minimum safety clearances being compromised in either of the above scenarios, this relocation work is generally at the developers cost.

It is also the responsibility of the developer to ensure that the existing overhead mains have sufficient clearance from all types of vehicles that are expected be entering and leaving the site.

Underground Cables

There are existing underground electricity network assets in Canterbury Rd and Remly St.

Special care should also be taken to ensure that driveways and any other construction activities within the footpath area do not interfere with the existing cables in the footpath. Ausgrid cannot guarantee the depth of cables due to possible changes in ground levels from previous activities after the cables were installed. Hence it is recommended that the developer locate and record the depth of all known underground services prior to any excavation in the area.

Should ground anchors be required in the vicinity of the underground cables, the anchors must not be installed within 300mm of any cable, and the anchors must not pass over the top of any cable.

Safework Australia – Excavation Code of Practice, and Ausgrid’s Network Standard NS156 outlines the minimum requirements for working around Ausgrid’s underground cables.

Please do not hesitate to contact Adam Bradford on Ph: (02) 93946627 (please quote our ref: Trim 2017/10/50) should you require any further information.

Regards, Adam

Adam Bradford
Portfolio Manager - Asset Protection
Ausgrid - Field Services
Ph: (02) 93946627