

11 April 2016

The General Manager  
Bankstown City Council  
PO Box 8  
Bankstown NSW 1885

**ATTENTION: Natasha Alford**

Dear Sir/Madam,

**STATE ENVIRONMENTAL PLANNING POLICY (INFRASTRUCTURE) 2007  
DEVELOPMENT APPLICATION – DA-687/2015  
137 Campbell Hill Road, Chester Hill**

I refer to Council's letter requesting RailCorp's concurrence for the above development application in accordance with clause 86(1) of the above SEPP.

As of 1 July 2014 the property functions of RailCorp have been transferred to Sydney Trains. Whilst RailCorp still exists as the legal land owner of the rail corridor, its concurrence function under the above SEPP has been delegated to Sydney Trains.

As such, Sydney Trains now advises that the proposed development is being assessed in accordance with the requirements of Clause 86(4) being:

- a) the potential effects of the development (whether alone or cumulatively with other development or proposed development) on:
  - (i) the safety or structural integrity of existing or proposed rail infrastructure facilities in the rail corridor, and
  - (ii) the safe and effective operation of existing or proposed rail infrastructure facilities in the rail corridor, and
- b) what measures are proposed, or could reasonably be taken, to avoid or minimise those potential effects.

In this regard, Sydney Trains has taken the above matters into consideration and has decided to grant its concurrence to the development proposed in development application DA-687/2015 subject to Council imposing the deferred commencement condition provided in Attachment A and operational conditions listed in Attachment B that will need to be complied with upon satisfaction of the Deferred Commencement Condition.

Should Council choose not to impose the deferred commencement condition in Attachment A and the operational conditions provided in Attachment B (as written), then concurrence from Sydney Trains has not been granted to the proposed development.

In the event that this development proposal is the subject of a Land and Environment Court appeal, Council's attention is drawn to Section 97A of the Environmental Planning and Assessment Act 1979 which requires Council to give notice of that appeal to a concurrence authority. Sydney Trains therefore requests that Council comply with this requirements should such an event occur.

Please contact Mr Jim Tsirimiagos on 8575 0780 should you wish to discuss this matter. Finally, Sydney Trains requests that a copy of the Notice of Determination and conditions of consent be forwarded to Sydney Trains.

Yours sincerely,

  
**Kevin Sykes**  
**General Manager Property**



**Attachment A****Deferred Commencement Condition**

*This consent is not to operate until the Applicant satisfies the Council, within 12 months of the date of this consent, that it has obtained approval/certification from Sydney Trains as to the following matters and the approval/certification has been forwarded to the Council:*

**A1**

*The Applicant shall prepare and provide to Sydney Trains for approval/certification the following items:*

- 1. Geotechnical and Structural report/drawings that meet Sydney Trains requirements. The Geotechnical Report must be based on actual borehole testing conducting on the site closest to the rail corridor.*
- 2. Construction methodology with construction details pertaining to structural support during excavation. The Applicant is to be aware that Sydney Trains will not permit any rock anchors/bolts (whether temporary or permanent) within its land or easements.*
- 3. Cross sectional drawings showing the rail corridor, sub soil profile, proposed basement excavation and structural design of sub ground support adjacent to the rail corridor. All measurements are to be verified by a Registered Surveyor.*
- 4. Detailed Survey Plan showing the relationship of the proposed developed with respect to Sydney Trains rail corridor.*
- 5. If required by Sydney Trains, an FE analysis which assesses the different stages of loading-unloading of the site and its effect on the rock mass surrounding the rail corridor.*

*Any conditions issued as part of Sydney Trains approval/certification of the above documents will also form part of the consent conditions that the Applicant is required to comply with.*



**Attachment B**

- *If required by Sydney Trains, prior to the commencement of works and prior to the issue of the Occupation Certificate, a joint inspection of the rail infrastructure and property in the vicinity of the project is to be carried out by representatives from Sydney Trains and the Applicant. These dilapidation surveys will establish the extent of any existing damage and enable any deterioration during construction to be observed. The submission of a detailed dilapidation report will be required unless otherwise notified by Sydney Trains.*
- *An acoustic assessment is to be submitted to Council prior to the issue of a construction certificate demonstrating how the proposed development will comply with the Department of Planning's document titled "Development Near Rail Corridors and Busy Roads- Interim Guidelines".*
- *Prior to the issue of a Construction Certificate the Applicant is to engage an Electrolysis Expert to prepare a report on the Electrolysis Risk to the development from stray currents. The Applicant must incorporate in the development all the measures recommended in the report to control that risk. A copy of the report is to be provided to the Principal Certifying Authority with the application for a Construction Certificate.*
- *The design, installation and use of lights, signs and reflective materials, whether permanent or temporary, which are (or from which reflected light might be) visible from the rail corridor must limit glare and reflectivity to the satisfaction of Sydney Trains. The Principal Certifying Authority is not to issue the Construction Certificate until written confirmation has been received from Sydney Trains confirming that this condition has been satisfied.*
- *If required by Sydney Trains, prior to the issue of a Construction Certificate a Risk Assessment/Management Plan and detailed Safe Work Method Statements (SWMS) for the proposed works are to be submitted to Sydney Trains for review and comment on the impacts on rail corridor. The Principal Certifying Authority is not to issue the Construction Certificate until written confirmation has been received from Sydney Trains confirming that this condition has been satisfied.*
- *Prior to the issuing of a Construction Certificate the Applicant is to submit to Sydney Trains a plan showing all craneage and other aerial operations for the development and must comply with all Sydney Trains requirements. The Principal Certifying Authority is not to issue the Construction Certificate until written confirmation has been received from the Sydney Trains confirming that this condition has been satisfied.*
- *The Sydney Trains rail corridor access gate located at the end of Campbell Hill Road that is adjacent to the development site shall remain unobstructed at all times. Should Sydney Trains advise that access to the gate is not possible then these shall be removed within the time specified by Sydney Trains.*

- *If required by Sydney Trains, a track monitoring plan (including instrumentation and the monitoring regime during excavation and construction phases) is to be submitted to Sydney Trains for review and endorsement prior to the issuing of a Construction Certificate. The Principal Certifying Authority is not to issue a Construction Certificate until written confirmation has been received from Sydney Trains advising of the need to undertake the track monitoring plan, and if required, that it has been endorsed.*

--o0o--