

Jasmine Beverley

From: Dean Cecil <Dean.Cecil@hunterwater.com.au>
Sent: Wednesday, 8 March 2017 4:03 PM
To: Brian Gibson
Cc: Wesley Jones; Malcolm Withers
Subject: RE: DA referral for Mixed Use Development at Brooks Parade, Belmont (HWC Ref. 2016-1632/1.007)
Attachments: Letter - Signed Notice Letter.pdf; Letter - Notice from Council regarding development.pdf

Good afternoon Brian,

We had received the previous Council letter (attached) however we had previously responded to the Development Application and as such, had advised of our concerns directly to the developer.

Hunter Water's concerns with the development are in regard to potential odour issues due to the proximity to the wastewater pump station.

I have attached a copy for your information of Hunter Water's Notice Of Formal Requirements which states in Condition 3 that an odour control report is required and that may include possible mitigation to avoid future issues. Any internal Hunter Water assets (sewer mains) can be removed and relocated as per the notice letter and similarly, all external assets have been identified and Hunter Water has advised of the precautions required when developing.


If you have any issues, please contact either Malcolm Withers, Wesley Jones or myself.

Regards,

Dean Cecil

Developer Services Technical Officer | Hunter Water Corporation
36 Honeysuckle Drive Newcastle NSW 2300 | PO BOX 5171 HRMC NSW 2310
T 02 4979 9726 | F 02 4979 9711 | Twitter: [@hunterwater](https://twitter.com/hunterwater)
Dean.Cecil@hunterwater.com.au | hunterwater.com.au
Please consider the environment before printing this email





Water Wise Rules are in place
Saving one billion litres of water each year
Water before 10am or after 4pm
No hosing hard surfaces, use a broom instead
All hoses must have a trigger nozzle



Lifeline
Out of the Shadows
World Suicide Prevention Day
Friday 8 September 2017

Hunter Water's charity partner Lifeline Hunter Central Coast provides life-saving suicide and crisis prevention services which will assist more than 25,000 locals this year. If you are in distress you can call 13 11 14. A compassionate person is there to listen 24 hours a day, seven days a week.
Make a donation or volunteer at www.lifelinehunter.org.au

From: Brian Gibson [<mailto:BrianGibson@lakemac.nsw.gov.au>]
Sent: Wednesday, 8 March 2017 2:34 PM
To: Dean Cecil <Dean.Cecil@hunterwater.com.au>
Subject: DA referral for Mixed Use Development at Brooks Parade, Belmont (HWC Ref. 2016-1632/1.007)

Dean

Council is assessing a large development over 13 Lots at Brooks Parade/Sharp Street/Edgar Street, Belmont. The development incorporates a large basement structure and multi storey towers, being in the vicinity of Hunter Water Infrastructure at 28 Brooks Parade, Belmont.

Whilst the DA has been lodged with HWC stamps, I am seeking comment specifically on any concerns HWC may have in terms of construction impacts and the like on the infrastructure at 28 Brooks Parade. Council previously referred a letter but has not received a response, hence following up with this enquiry.

Should you have any queries regarding the above please do not hesitate to contact me.

Regards,

Brian Gibson | Senior Development Planner
LAKE MACQUARIE CITY COUNCIL
126-138 Main Road Speers Point NSW 2284 | Box 1906 HRMC 2310
P: 02 4921 0388 | F: 02 49587257
briangibson@lakemac.nsw.gov.au | www.lakemac.nsw.gov.au
Please consider the environment before printing this email.

This information is intended for the addressee only. The use, copying or distribution of this message or any information it contains, by anyone other than the addressee is prohibited by the sender.

Any views expressed in this communication are those of the individual sender, except where the sender specifically states them to be the views of Council.

Information provided to Council in correspondence, submissions or requests (verbal, electronic or written), including personal information such as your name and address, may be made publicly available, including via Council website, in accordance with the Government Information (Public Access) Act (GIPA Act) 2009.

This transmission is confidential and intended for the addressee only.
If you have received it in error, please delete it and notify the sender.
Unless explicitly attributed, the opinions expressed in this e-mail are those of the author only and do not represent the official view of Hunter Water Corporation.
Hunter Water Corporation checks all inbound/outbound e-mail for viruses. However, we advise that this e-mail and any attached files should be re-scanned to detect viruses. Hunter Water Corporation accepts no liability for the loss or damage (whether caused by negligence or not) resulting from the use of this or any attached files.



6 January 2017

Hunter Water Corporation
ABN 46 228 513 446

PO Box 5171
HRMC NSW 2310
36 Honeysuckle Drive
NEWCASTLE NSW 2300
1300 657 657 (T)
(02) 4979 9625 (F)
enquiries@hunterwater.com.au
hunterwater.com.au

Ref: 2016-1632 / 1.007

KML Joint Venture
C/- Monteath & Powys Pty Ltd
P O Box 2270
Dangar NSW 2309

Attention: Konrad Grinlaubs

Dear Konrad,

RE NOTICE OF FORMAL REQUIREMENTS FOR PROPOSED DEVELOPMENT

Hunter Water's requirements for the provision of water and sewerage facilities to the development of 130 Units (20 x 1b, 88 x 2b, 22 x 3b) & Commercial (506m²) over 14 (various) lots, at 30–40 Brooks Parade, 5–11 Edgar & 2–10 Sharp Streets, Belmont are as follows:

You Are Required To:

- 1 Submit the Development Consent Conditions determined by Council for this specific development. Hunter Water will confirm that the final development description is consistent with the details supplied by you for this application. If there are any subsequent amendments to this development consent, Hunter Water will require you to submit a revision application.
- 2 Should the existing fourteen (14) lots be consolidated into one (1) single lot, provide one copy of the final plan of subdivision and a DXF file of the subdivision showing only lot numbers and boundaries directly on the MGA grid to plan.check@hunterwater.com.au. The lot boundaries should be produced directly from your calculation software, with all edges matched and unbroken, and also match as near as possible the final deposited plan of the subdivision.

Network Infrastructure and Delivery

- 3 Hunter Water is concerned with the proximity of the proposed dwellings to the existing Belmont 1 Waste Water Pumping Station (WWPS), and the potential for odour impacts on these dwellings. Hunter Water will require that a developer-funded odour assessment and control report be prepared to assess the impact of odours and any necessary mitigation measures that may be required. Hunter Water may provide a copy of this odour assessment and control report to Council to assist in its assessment of the development application.
- 4 Design and construct major works to connect the development to the existing water and sewer system(s) in accordance with the **Specific Connection Details** and **Asset Protection Requirements** for this development as detailed below.

The design must be submitted to Hunter Water for assessment. Please note, Hunter Water's fees changed on 1 July 2016. Hunter Water no longer charge a Major Works Assessment fee.

It is the responsibility of the Accredited Designer to lodge approved designs at plan.check@hunterwater.com.au. Hunter Water will not issue the Instrument of Agreement until the Accredited Designer has lodged the approved designs.

All contractors engaged by the developer must have insurances in place in accordance with the Agreement.

Specific Connection Details

5 Water Supply

The property requires a frontage to a 150mm watermain as it is more than four (4) stories in height. There is an existing 150mm Cast Iron Cement Lined (CICL) watermain along Maude Street to the west and the developer is required to extend a watermain from Maude Street either along Edgar Street or Brooks Parade to provide the development with a 150mm watermain frontage. The location of the possible connection points is shown in **Figure 1**.

Any unused water service(s) on the existing 14 lots is to be disconnected from the Hunter Water network in accordance with the specified Hunter Water disconnection process guidelines, this includes the submission of a disconnection application form and return of the meter with all work to be performed by a licensed plumber. The full set of guidelines for disconnection can be found at www.hunterwater.com.au.

You will be required to undertake a Hydraulic Design Assessment to confirm pressures available within this water main and any additional requirements for provision of adequate pressures to serve the proposed development. Further advice on making an application is provided at Condition 11.

6 Wastewater Transportation

There are multiple sewer connection point options to service the development. Maintenance Structures 227C and 248B are located adjacent to the property boundaries and it appears that flows from the development may gravitate to these points.

The developer is required to confirm the designated connection point and is to cap and abandon the existing sewer connection points that currently serve the existing 14 lots over which the development is situated. The location of the possible connection points is shown in **Figure 2**.

Buildings "A" & "D" of the development will be situated over an existing 150mm Vitrified Clay (VC) sewermain that traverses the development lots. The Developer is to cap and remove the above mentioned sewermain as it will no longer be utilised. The location of the effected sewermain is shown in **Figure 3**.

Trade Waste Permits may be required for the proposed commercial units within the development. Further advice on making an application is provided at Condition 12.

7 Submit a Review of Environmental Factors (REF) (refer Appendix HW 1 of Water Supply Code of Australia – Hunter Water Edition) to Hunter Water for the construction works. The REF will need to be approved prior to Hunter Water providing final approval of designs. A REF considers the likely impacts a development may have on the environment. At all times, methods for preventing or reducing adverse environmental impacts should be considered and where appropriate, incorporated into the project design.

Hunter Water will make a determination in accordance with the EP& A Act 1979. An environmental report assessment fee of \$1,182 should be paid when the REF is submitted.

Please note that a **Controlled Activity Approval will be required from the NSW Office of Water** due to the proximity to a watercourse.

In addition, please refer to the Hunter Water Review of Environmental Factors Guidance Notes, located in the Building & Development section of the Hunter Water website. The Guidance Notes provide the minimum requirements and an example template for the preparation of a REF.

- 8 The proposed works may require entry to another property. You will need to arrange for entry and have evidence of consent by way of a signed Entry Permit with the affected landowner. The Permit is to be submitted prior to release of the signed contract.

Asset Protection Requirements

- 9 Comply with Hunter Water's Building Over Sewer Assets Policy. The above development will impact the 150mm Vitrified Clay (VC) sewermain located within the development lot(s). As such Hunter Water requires:
 - a All buildings, structures, landscaping and improvements to the land which are located over or adjacent to the sewermain must not impose any loading on the sewermain nor interfere with or obstruct the sewer in conveying flows;
 - b Compliance with Hunter Water's Act with respect to the design and construction of all building, structures, landscaping and improvements (refer to the Building Over Sewer Assets Policy attached to this Notice of Requirements);
 - c The removal of the existing 150mm VC sewermain shown in **Figure 3**.
- 10 Ensure that all due care is taken by all contractors in the course of construction activities including construction of the driveway and accessing the construction site as there are watermain and sewermain located in the footpath adjacent to the proposed development site.

Access over the footpath must be via a bridging structure to eliminate any loads on the mains.

The developer should confirm the depth of the watermain by site survey prior to construction to ensure Hunter Water's minimum cover requirements will be complied with in relation to the driveways. If this minimum cover requirement cannot be met, please contact Hunter Water to discuss options for protection of the watermain. An option may be lowering the watermain under a Major Works contract with Hunter Water.

Please note that it is Hunter Water's practice to seek the full costs of repairs should any damage occur to Hunter Water assets.

Other Services Required


- 11 You will be required to submit an application for a hydraulic design assessment of internal water and sewerage services for this development, including rainwater tanks, any alternative water supply systems and service size & meter configuration. Please contact Hunter Water's Hydraulic Consultant on (02) 4979 9467 to confirm if a hydraulic assessment is required. (Refer to the attached fact sheet).
- 12 Contact Hunter Water's Hydraulic Consultant on (02) 4979 9467 to make the necessary application for a Trade Waste Permit and pay the prescribed fees as your proposed development has been identified as having the potential to discharge trade waste into Hunter Water's sewerage system. The discharge of trade waste to the sewer will not be permitted without a permit authorising that discharge.

Please note, the information shown on the plan provided with this letter may not be up to date and Hunter Water accepts no responsibility for its accuracy. Any contractor(s) or consultant(s) engaged by the developer should confirm all levels by field survey.

These requirements are valid for 12 months from the date of this letter and are specific to this development. All fees and charges are subject to adjustment using the Consumer Price Index (CPI) adjustment on 1 July each year.

Please refer to the attached Development and Design Assessment fact sheet, which details the conditions under which water and sewer facilities are available to new customers. Hunter Water reserves the right to amend its requirements if we find an error has been made.

Yours faithfully,




MALCOLM WITHERS
Senior Developer Services Engineer

Enquiries:	Dean Cecil
Tel:	1300 657 657
Email:	Dean.Cecil@hunterwater.com.au
Your Ref:	13-0524

Figure 1 – Water Connection Points



Figure 3 – Sewermain to be capped and removed





BUILDING OVER SEWER ASSETS

PURPOSE

Hunter Water maintains a network of sewer mains within its area of operation. Under its Operating Licence Hunter Water is required to meet specified levels of performance with respect to the operation of this sewerage system. The sewerage network requires regular maintenance to ensure its continued operation. Access to underground pipelines is a key factor in providing prompt and cost effective maintenance. The presence of a building or structure over a sewer main restricts or may preclude Hunter Water from accessing the asset for repairs.

SCOPE

This policy applies to all developments proposing to build over or adjacent to Hunter Water's sewer network assets.

POLICY STATEMENT

The policy of Hunter Water is to ensure compliance with the legislation (Hunter Water Act, 1991, as amended) and requires all sewer network assets to be diverted clear of proposed buildings, structures, landscaping and improvements so as to ensure ongoing access to operate and maintain the asset.

Where Hunter Water agrees that there may be a suitably low residual risk, Hunter Water may require that the asset be replaced in-situ with flexible and more durable plastic pipe prior to building works commencing. This work is at the landowner's expense and can usually be carried out by an accredited contractor. Where existing sewer mains are located on the development lot, the landowner is required to undertake work so that the sewer mains comply with the latest Hunter Water Edition, WSAA Design Manual guidelines.

APPLICATION OF POLICY

This policy applies to any development, subdivision, building (residential, commercial or industrial), or any structure proposed to be placed over or adjacent to a sewer asset of Hunter Water.

Where subdivision is proposed and the future building alignments are not known, Hunter Water requires the existing sewer mains to be relocated adjacent to boundaries in accordance with the latest Hunter Water Edition WSAA Design Manual

All footings crossing or adjacent to a sewer main should be strengthened or underpinned to prevent loading upon the sewer and to protect the stability of the structure in the event of subsidence of the sewer trench, collapse of the sewer, or excavation by Hunter Water to repair or maintain the sewer. In this regard, it may be necessary to consult a competent designer or structural engineer.

Special consideration to footing design should extend to land within the Zone of Influence. This is a nominal strip of land (usually about twice as wide as the sewer is deep) within which the sewer main is centrally located. Ground conditions are an important consideration in determining the likely zone of influence and it may be necessary for you to engage a qualified Geotechnical Engineer to determine the appropriate design parameters influencing the structural performance of proposed foundations, footings or piers. Hunter Water requires a minimum working clearance of 1.5 metres from the centre of any access chamber to a building wall.

The location of the sewer main can be determined from the plan attached to the Section 50 Notice of Requirements. A surveyor or building contractor engaged by the developer will confirm this location. Hunter Water Corporation will not accept responsibility for future maintenance on the shaft and/or branch contained in or under the structure. Conversion of the structure to a habitable area, with or without plumbing fixtures, is not compliant with Plumbing Code of Australia and Australian/New Zealand Standard 3500 (AS/NZS 3500:1).

Enquiries on Hunter Water Corporation's Building Over Sewer Assets Policy should be directed to Hunter Water's 1300 657 657 number.

POLICY ADMINISTRATION

Effective from	29 August 2014
Approved by	Chief Customer Service Officer
Policy Owner	Manager Developer Services
Policy Administrator	Manager Developer Services
Application	All Policies and Schedules of Hunter Water Corporation
Last review date	29 August 2014
Next review date	29 August 2017
Version	2.0
File reference	HW2007-2963/1.003
Published externally	Yes
Approval Signature	Managing Director/ Company Secretary

RELATED DOCUMENTS

[Building Over Easement or Property](#)

ASSOCIATED REGULATIONS AND STANDARDS

The Hunter Water Corporation Act (1991) requires that no building or structure is to impose any loading on a sewer nor interfere with or obstruct the sewer in conveying flows. Hunter Water's powers allow it to take legal action where there is a breach or threatened breach of the requirements and to recover associated costs from the landowner. Hunter Water may in any case where there is a threatened breach of these conditions; obtain an injunction to prevent any damage to, or interference with, its sewerage system or other works.

DEFINITIONS, ACRONYMS AND ABBREVIATIONS

Term	Definition
Name	Details

PERMIT TO ENTER

File Number: 2016-1632

I/We

of.....

being the Owner(s)/occupier(s)* of the land described in Schedule A (the land), grant permission to the Hunter Water Corporation, its Contractors, Agents, Servants and Workers with or without plant, vehicles, equipment, machinery and materials, to enter at any time upon the land and to carry out the work described in Schedule B. This consent shall be without prejudice to any compensation to which I may be entitled for under Section 22 Hunter Water Act 1991. A copy is below for your information.

I/We acknowledge that if the works described in Schedule B provides a direct point of connection to sewer and/or direct access to a watermain and I/We apply to connect to Hunter Water's system then we will be required to:-

Pay to the developer (or other developers where applicable) a reimbursement towards the costs of the works constructed by developers which will be utilised on connection. For lots with existing dwellings which are provided direct access to services by the developer then the reimbursement may not be payable. If you are in this situation you should discuss with Hunter Water to clarify.

Dated atthisday of20
(Place)

..... (Signature)

..... (Signature)

(if more than one owner or occupier)

SCHEDULE A (The Land)

LOT.....DP.....HOUSE NO.....

STREET.....SUBURB.....

SCHEDULE B (Particulars of Work)

SECTION 22 of the Hunter Water Act 1991.

- 1 The Corporation, in exercising its function under this Division, is to do as little damage as practicable and is, subject to this Division, to compensate all persons who suffer damages by exercise of the function.
- 2 Compensation may be made by reinstatement, repair, construction of works or payment.

If the Corporation installs a sewer on land in exercise of powers under this Division, the Corporation is required to pay compensation only if the sewer damages, or interferes with, a building or other structure on the land or if a manhole or main ventilator is constructed on the land.



HUNTER WATER CORPORATION

A.B.N. 46 228 513 446




TRIM NUMBER: 2016-1632

PROPERTY ADDRESS:

LOT/SECTION/DP: \$210.LotSectionDPNumber

\$210.DisplayAddress



SEWER POSITION APPROXIMATE ONLY. SUBJECT PROPERTY BOLDED.
ALL MEASUREMENTS ARE METRIC.

IF A SEWERMAIN IS LAID WITHIN THE BOUNDARIES OF THE LOT, SPECIAL REQUIREMENTS FOR THE PROTECTION OF THE SEWERMAIN APPLY IF DEVELOPMENT IS UNDERTAKEN. IN THESE CASES, IT IS RECOMMENDED THAT YOU SEEK ADVICE ON THE SPECIAL REQUIREMENTS PRIOR TO CONSTRUCTION. PHONE 1300 657 657, FOR MORE INFORMATION.

IMPORTANT:

ANY INFORMATION ON THIS PLAN MAY NOT BE UP TO DATE
AND THE CORPORATION ACCEPTS NO RESPONSIBILITY FOR ITS
ACCURACY.

Date: 16/12/2016 User: tynanme

Scale: at A4 1:1,000

CADASTRAL DATA © LPI OF NSW
CONTOUR DATA © AAMHatch
© Department of Planning

SEWER/WATER/RECYCLED WATER
UTILITY DATA
© HUNTER WATER CORPORATION



23 January 2017

HUNTER WATER CORPORATION
PO Box 5171
HUNTER REGION MAIL CENTRE NSW 2310

Dear Sir/Madam

In accordance with Section 79 of the Environmental Planning and Assessment Act 1979 (the Act) and Section 87 to 89 of the Environmental Planning and Assessment Regulation 2000, notice is hereby given that a Development Application has been received seeking development consent for the following Advertised development under the provisions of the Water Management Act 2000, specified in Section 91(1) of the Act:

Application Number: DA/11/2017

Property: Lot 10 Sec B DP 585, Lot 11 Sec B DP 585, Lot A DP 400644, Lot B DP 400644, Lot 6 DP 12898, Lot 5 DP 12898, Lot 4 DP 12898, Lot 1 DP 353066, Lot 2 DP 353066, Lot 4 Sec B DP 585, Lot A DP 339105, Lot B DP 339105, Lot 8 DP 12898, Lot 3 Sec B DP 585
5 Edgar Street, BELMONT NSW 2280, 7 Edgar Street, BELMONT NSW 2280, 9 Edgar Street, BELMONT NSW 2280, 11 Edgar Street, BELMONT NSW 2280, 2 Sharp Street, BELMONT NSW 2280, 4 Sharp Street, BELMONT NSW 2280, 6 Sharp Street, BELMONT NSW 2280, 8 Sharp Street, BELMONT NSW 2280, 10 Sharp Street, BELMONT NSW 2280, 36 Brooks Parade, BELMONT NSW 2280, 38 Brooks Parade, BELMONT NSW 2280, 40 Brooks Parade, BELMONT NSW 2280, 42 Brooks Parade, BELMONT NSW 2280, 32 Brooks Parade, BELMONT NSW 2280

Applicant's Name: MONTEATH AND POWYS PTY LTD

Proposed Development: Mixed Use Development and Demolition of Existing Structures

Consent Authority: Hunter & Central Coast Joint Regional Planning Panel

Integrated Approval Bodies: Department of Primary Industries – NSW Office of Water

Notification End Date: Monday 27 February 2017

Exhibition: Until the notification end date from 8:00am to 5:00pm weekdays at:

Lake Macquarie City Council, Administration Centre,
126-138 Main Road
SPEERS POINT NSW 2284

And office hours of:

Department of Planning,
Price Waterhouse Coopers Centre
Level 2, 26 Honeysuckle Drive
NEWCASTLE NSW 2300

Alternatively the notification plans can be viewed using Council's Application Tracking System by logging on to the City's Website www.lakemac.com.au and following the prompts.

The development proposal is Integrated Development as defined under Section 91 the Act as the applicant has sought on the application the General Terms of Approval under: Section 91 of the Water Management Act 2000.

Any person may inspect the application and make written submissions to Council about the proposed development. Submissions must be in writing and received during the notification period. If you object to the proposed development, the reasons for your objection must be included in your submission. Council will consider all submissions made within the specified period prior to the determination of the application.

If you have made a reportable political donation or gift in the last 2 years your submission will need to be accompanied by a "Disclosure Statement of Political Donations and Gifts - Submitters" Form. For more information on reportable political donations or gifts or to download a copy of this form please contact Council's Customer Service Centre or go to www.lakemac.com.au and search for "Political Donations Submitters". Please note failure to complete a statement if such a Political Donation/Gift has been made is an offence under the Environmental Planning and Assessment Act 1979.

Please note any submission received by Council, will be publicly available on the City's website. Third parties may also access any submission under the Government Information (Public Access) Act 2009. Council may reproduce submissions in Council reports or in Court proceedings.

Please note it is the responsibility of the Owners Corporation to display this notice in a prominent position on strata subdivided properties to ensure that all occupiers are aware of this proposal.

If you require any further information in relation to this application, or do not have access to the web to view the Notification Plans, please contact Council on 4921 0333.

Yours faithfully

Advertising Officer
Development Assessment & Compliance Department