

SEPP65 COMPLIANCE CHECKLIST																
ADG OBJECTIVE	4A-1.1	4A-1.3	4B-3.1	4C-1.1	4D-1.1	4D-1.2	4D-2.1	4D-2.2	4D-3.1	4D-3.2	4D-3.3	4E-1.1	4G-1.1	4G-1.1	4Q-1	4Q-2
	SOLAR ACCESS (2 HRS)	NO SOLAR ACCESS	CROSS VENTILATION	CEILING HEIGHTS	APARTMENT MINIMUM SIZES	WINDOW TO HABITABLE ROOMS	DEPTH OF HABITABLE ROOM	HABITABLE ROOM DEPTH	BEDROOM MINIMUM AREA	BEDROOM MINIMUM DIMENSION	LIVING ROOM MINIMUM WIDTH	BALCONY SIZES	STORAGE (50%)	STORAGE	LIVABLE HOUSING SILVER LEVEL	ADAPTABLE UNITS
UNIT NO.	9AM-3PM	9AM-3PM	<9 STOREYS										INTERNAL	TOTAL		
2.01			●	●	●	●	●	●	●	●	●	●	●	●		
2.02	●		●	●	●	●	●	●	●	●	●	●	●	●		
2.03	●		●	●	●	●	●	●	●	●	●	●	●	●		
2.04			●	●	●	●	●	●	●	●	●	●	●	●	●	●
2.05	●		●	●	●	●	●	●	●	●	●	●	●	●	●	●
2.06	●		●	●	●	●	●	●	●	●	●	●	●	●		
2.07		●	●	●	●	●	●	●	●	●	●	●	●	●	●	●
2.08		●	●	●	●	●	●	●	●	●	●	●	●	●	●	●
3.01			●	●	●	●	●	●	●	●	●	●	●	●		
3.02	●		●	●	●	●	●	●	●	●	●	●	●	●		
3.03	●		●	●	●	●	●	●	●	●	●	●	●	●		
3.04			●	●	●	●	●	●	●	●	●	●	●	●	●	●
3.05	●		●	●	●	●	●	●	●	●	●	●	●	●	●	●
3.06	●		●	●	●	●	●	●	●	●	●	●	●	●		
3.07		●	●	●	●	●	●	●	●	●	●	●	●	●	●	●
3.08		●	●	●	●	●	●	●	●	●	●	●	●	●	●	●
4.01	●		●	●	●	●	●	●	●	●	●	●	●	●		
4.02	●		●	●	●	●	●	●	●	●	●	●	●	●		
4.03			●	●	●	●	●	●	●	●	●	●	●	●		
4.04			●	●	●	●	●	●	●	●	●	●	●	●	●	●
4.05	●		●	●	●	●	●	●	●	●	●	●	●	●	●	●
4.06	●		●	●	●	●	●	●	●	●	●	●	●	●		
4.07		●	●	●	●	●	●	●	●	●	●	●	●	●	●	●
4.08		●	●	●	●	●	●	●	●	●	●	●	●	●	●	●
5.01	●		●	●	●	●	●	●	●	●	●	●	●	●		
5.02	●		●	●	●	●	●	●	●	●	●	●	●	●		
5.03			●	●	●	●	●	●	●	●	●	●	●	●		
5.04			●	●	●	●	●	●	●	●	●	●	●	●	●	●
5.05	●		●	●	●	●	●	●	●	●	●	●	●	●	●	●
5.06	●		●	●	●	●	●	●	●	●	●	●	●	●		
5.07		●	●	●	●	●	●	●	●	●	●	●	●	●	●	●
5.08		●	●	●	●	●	●	●	●	●	●	●	●	●	●	●
6.01			●	●	●	●	●	●	●	●	●	●	●	●		
6.02	●		●	●	●	●	●	●	●	●	●	●	●	●		
6.03	●		●	●	●	●	●	●	●	●	●	●	●	●		
6.05	●		●	●	●	●	●	●	●	●	●	●	●	●		
7.01			●	●	●	●	●	●	●	●	●	●	●	●		
7.02	●		●	●	●	●	●	●	●	●	●	●	●	●		
7.03	●		●	●	●	●	●	●	●	●	●	●	●	●		
7.04	●		●	●	●	●	●	●	●	●	●	●	●	●		
7.05	●		●	●	●	●	●	●	●	●	●	●	●	●		
8.01			●	●	●	●	●	●	●	●	●	●	●	●		
8.02	●		●	●	●	●	●	●	●	●	●	●	●	●		
8.03	●		●	●	●	●	●	●	●	●	●	●	●	●		
8.04	●		●	●	●	●	●	●	●	●	●	●	●	●		
8.05	●		●	●	●	●	●	●	●	●	●	●	●	●		
9.01			●	●	●	●	●	●	●	●	●	●	●	●		
9.02	●		●	●	●	●	●	●	●	●	●	●	●	●		
9.03	●		●	●	●	●	●	●	●	●	●	●	●	●		
9.04	●		●	●	●	●	●	●	●	●	●	●	●	●		
9.05	●		●	●	●	●	●	●	●	●	●	●	●	●		
10.01			●	●	●	●	●	●	●	●	●	●	●	●		
10.02	●		●	●	●	●	●	●	●	●	●	●	●	●		
10.03	●		●	●	●	●	●	●	●	●	●	●	●	●		
10.04	●		●	●	●	●	●	●	●	●	●	●	●	●		
10.05	●		●	●	●	●	●	●	●	●	●	●	●	●		
11.01			●	●	●	●	●	●	●	●	●	●	●	●		
11.02	●		●	●	●	●	●	●	●	●	●	●	●	●		
11.03	●		●	●	●	●	●	●	●	●	●	●	●	●		
11.04	●		●	●	●	●	●	●	●	●	●	●	●	●		
11.05	●		●	●	●	●	●	●	●	●	●	●	●	●		
12.01	●		●	●	●	●	●	●	●	●	●	●	●	●		
12.02	●		●	●	●	●	●	●	●	●	●	●	●	●		
12.03	●		●	●	●	●	●	●	●	●	●	●	●	●		
12.04	●		●	●	●	●	●	●	●	●	●	●	●	●		
13.01	●		●	●	●	●	●	●	●	●	●	●	●	●		
13.02	●		●	●	●	●	●	●	●	●	●	●	●	●		
13.03	●		●	●	●	●	●	●	●	●	●	●	●	●		
13.04	●		●	●	●	●	●	●	●	●	●	●	●	●		
14.01	●		●	●	●	●	●	●	●	●	●	●	●	●		
14.02	●		●	●	●	●	●	●	●	●	●	●	●	●		
14.03	●		●	●	●	●	●	●	●	●	●	●	●	●		
14.04	●		●	●	●	●	●	●	●	●	●	●	●	●		
15.01	●		●	●	●	●	●	●	●	●	●	●	●	●		
15.02	●		●	●	●	●	●	●	●	●	●	●	●	●		
15.03	●		●	●	●	●	●	●	●	●	●	●	●	●		
15.04	●		●	●	●	●	●	●	●	●	●	●	●	●		
16.01	●		●	●	●	●	●	●	●	●	●	●	●	●		
16.02	●		●	●	●	●	●	●	●	●	●	●	●	●		
16.03	●		●	●	●	●	●	●	●	●	●	●	●	●		
16.04	●		●	●	●	●	●	●	●	●	●	●	●	●		
17.01	●		●	●	●	●	●	●	●	●	●	●	●	●	●	●
17.02	●		●	●	●	●	●	●	●	●	●	●	●	●	●	●
TOTAL	61 of 83	8 of 83	34 of 46	83 of 83	83 of 83	83 of 83	83 of 83	83 of 83	83 of 83	83 of 83	83 of 83	79 of 83	83 of 83	83 of 83	18 of 83	8 of 83
REQUIREMENT	>70%	<15%	>60%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	20.4%	9.6%
NOTE										where walls are not parallel, average length/width taken from centre of walls		where non-compliant, Juliet balconies have been proposed				