

# APARTMENT DESIGN GUIDE CHECKLIST **(Revised 14.12.17)**

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE
				✓ X N/A
<b>3B ORIENTATION</b>				
3B-1 - Building types and layouts respond to the streetscape and site while optimising solar access within the development.	Buildings along the street frontage define the street, by facing it and incorporating direct access from the street (see figure 3B.1)			✓
		Where the street frontage is to the north or south, overshadowing to the south should be minimised and buildings behind the street frontage should be orientated to the east and west (see figure 3B.2)		✓
3B-2 - Overshadowing of neighbouring properties is minimised during mid winter.	Living areas, private open space and communal open space should receive solar access in accordance with sections 3D Communal and public open space and 4A Solar and daylight access			✓
		Solar access to living rooms, balconies and private open spaces of neighbours should be considered	Building mass is sculpted to capture available sun.	✓
		Where an adjoining property does not currently receive the required hours of solar access, the proposed building ensures solar access to neighbouring properties is not reduced by more than 20%		✓
		If the proposal will significantly reduce the solar access of neighbours, building separation should be increased beyond minimums contained in section 3F Visual privacy		✓
		Overshadowing should be minimised to the south or down hill by increased upper level setbacks		✓
		It is optimal to orientate buildings at 90 degrees to the boundary with neighbouring properties to minimise overshadowing and privacy impacts, particularly where minimum setbacks are used and where buildings are higher than the adjoining development	Proposal is almost 90 degrees to boundary	✓
		A minimum of 4 hours of solar access should be retained to solar collectors on neighbouring buildings		N/A
<b>3C PUBLIC DOMAIN INTERFACE</b>				

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE
3C-1 - Transition between private and public domain is achieved without compromising safety and security.		Terraces, balconies and courtyard apartments should have direct street entry, where appropriate		N/A
		Upper level balconies and windows should overlook the public domain		✓
		Front fences and walls along street frontages should use visually permeable materials and treatments. The height of solid fences or walls should be limited to 1m	Street fronts are highly transparent, no solid fences proposed in proposal.	✓
		Length of solid walls should be limited along street frontages		✓
		Opportunities should be provided for casual interaction between residents and the public domain. Design solutions may include seating at building entries, near letter boxes and in private courtyards adjacent to streets	Building entry is highly transparent	✓
		In developments with multiple buildings and/or entries, pedestrian entries and spaces associated with individual buildings/entries should be differentiated to improve legibility for residents, using a number of the following design solutions: <ul style="list-style-type: none"> <li>• architectural detailing</li> <li>• changes in materials</li> <li>• plant species</li> <li>• colours</li> </ul>		N/A
		Opportunities for people to be concealed should be minimised		✓
3C-2 - Amenity of the public domain is retained and enhanced.		Planting softens the edges of any raised terraces to the street, for example above sub-basement car parking		N/A
		Mail boxes should be located in lobbies, perpendicular to the street alignment or integrated into front fences where individual street entries are provided		✓
		The visual prominence of underground car park vents should be minimised and located at a low level where possible		✓
		Substations, pump rooms, garbage storage areas and other service requirements should be located in basement car parks or out of view		✓
		Ramping for accessibility should be minimised by building entry location and setting ground floor levels in relation to footpath levels		✓
		Durable, graffiti resistant and easily cleanable materials should be used		✓

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE
		<p>Where development adjoins public parks, open space or bushland, the design positively addresses this interface and uses a number of the following design solutions:</p> <ul style="list-style-type: none"> <li>• street access, pedestrian paths and building entries which are clearly defined</li> <li>• paths, low fences and planting that clearly delineate between communal/private open space and the adjoining public open space</li> <li>• minimal use of blank walls, fences and ground level parking</li> </ul> <p>On sloping sites protrusion of car parking above ground level should be minimised by using split levels to step underground car parking</p>	<p>Site faces 2 streets and a lane way, proposal provides increased pedestrian footpaths, a clearly identifiable entry and minimises use of blank walls</p>	✓
<b>3D COMMUNAL AND PUBLIC OPEN SPACE</b>				
<p>3D-1 - An adequate area of communal open space is provided to enhance residential amenity and to provide opportunities for landscaping.</p>	<p>Communal open space has a minimum area equal to 25% of the site.</p> <p>Developments achieve a minimum of 50% direct sunlight to the principal usable part of the communal open space for a minimum of 2 hours between 9 am and 3 pm on 21 June (mid winter)</p>	<p>Communal open space should be consolidated into a well designed, easily identified and usable area</p> <p>Communal open space should have a minimum dimension of 3m, and larger developments should consider greater dimensions</p> <p>Communal open space should be co-located with deep soil areas</p> <p>Direct, equitable access should be provided to communal open space areas from common circulation areas, entries and lobbies</p> <p>Where communal open space cannot be provided at ground level, it should be provided on a podium or roof</p>	<p>Proposal provides 282 sqm of communal open space on level 6, equals to 25% of site.</p> <p>Proposal achieves over 50% of direct sunlight to principle usable part of communal space - refer to drawings DA 0901 and 0902</p> <p>Communal open space provided on podium level</p>	<p>✓</p> <p>✓</p> <p>✓</p> <p>✓</p> <p>N/A</p> <p>✓</p> <p>✓</p>

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE
		<p>Where developments are unable to achieve the design criteria, such as on small lots, sites within business zones, or in a dense urban area, they should:</p> <ul style="list-style-type: none"> <li>• provide communal spaces elsewhere such as a landscaped roof top terrace or a common room</li> <li>• provide larger balconies or increased private open space for apartments</li> <li>• demonstrate good proximity to public open space and facilities and/ or provide contributions to public open space</li> </ul>		N/A
<p>3D-2 - Communal open space is designed to allow for a range of activities, respond to site conditions and be attractive and inviting.</p>		<p>Facilities are provided within communal open spaces and common spaces for a range of age groups (see also 4F Common circulation and spaces), incorporating some of the following elements:</p> <ul style="list-style-type: none"> <li>• seating for individuals or groups</li> <li>• barbecue areas</li> <li>• play equipment or play areas</li> <li>• swimming pools, gyms, tennis courts or common rooms</li> </ul>	<p>Facilities provided include seating for individuals and groups and a barbeque area.</p>	✓
		<p>The location of facilities responds to micro-climate and site conditions with access to sun in winter, shade in summer and shelter from strong winds and down drafts</p>	<p>Location of facilities located on top of podium to maximise sun in winter and to correspond to neighbouring building.</p>	✓
		<p>Visual impacts of services should be minimised, including location of ventilation duct outlets from basement car parks, electrical substations and detention tanks.</p>	<p>Services are located to face the rear lane or on rooftops concealed with louvres.</p>	✓
<p>3D-3 - Communal open space is designed for maximum safety.</p>		<p>Communal open space and the public domain should be readily visible from habitable rooms and private open space areas while maintaining visual privacy. Design solutions may include:</p> <ul style="list-style-type: none"> <li>• bay windows</li> <li>• corner windows</li> <li>• balconies</li> </ul>	<p>Communal open space directly visible from private balconies above</p>	✓
		<p>Communal open space should be well lit</p>		✓
		<p>Where communal open space/facilities are provided for children and young people they are safe and contained</p>		✓
<p>3D-4 - Public open space, where provided, is responsive to the existing pattern and uses of the neighbourhood.</p>		<p>The public open space should be well connected with public streets along at least one edge</p>	<p>No public open space</p>	N/A

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE
		<p>Where developments are unable to achieve the design criteria, such as on small lots, sites within business zones, or in a dense urban area, they should:</p> <ul style="list-style-type: none"> <li>• provide communal spaces elsewhere such as a landscaped roof top terrace or a common room</li> <li>• provide larger balconies or increased private open space for apartments</li> <li>• demonstrate good proximity to public open space and facilities and/ or provide contributions to public open space</li> </ul>		N/A
<p>3D-2 - Communal open space is designed to allow for a range of activities, respond to site conditions and be attractive and inviting.</p>		<p>Facilities are provided within communal open spaces and common spaces for a range of age groups (see also 4F Common circulation and spaces), incorporating some of the following elements:</p> <ul style="list-style-type: none"> <li>• seating for individuals or groups</li> <li>• barbecue areas</li> <li>• play equipment or play areas</li> <li>• swimming pools, gyms, tennis courts or common rooms</li> </ul>	<p>Facilities provided include seating for individuals and groups and a barbeque area.</p>	✓
		<p>The location of facilities responds to micro-climate and site conditions with access to sun in winter, shade in summer and shelter from strong winds and down drafts</p>	<p>Location of facilities located on top of podium to maximise sun in winter and to correspond to neighbouring building.</p>	✓
		<p>Visual impacts of services should be minimised, including location of ventilation duct outlets from basement car parks, electrical substations and detention tanks.</p>	<p>Services are located to face the rear lane or on rooftops concealed with louvres.</p>	✓
<p>3D-3 - Communal open space is designed for maximum safety.</p>		<p>Communal open space and the public domain should be readily visible from habitable rooms and private open space areas while maintaining visual privacy. Design solutions may include:</p> <ul style="list-style-type: none"> <li>• bay windows</li> <li>• corner windows</li> <li>• balconies</li> </ul>	<p>Communal open space directly visible from private balconies above</p>	✓
		<p>Communal open space should be well lit</p>		✓
		<p>Where communal open space/facilities are provided for children and young people they are safe and contained</p>		✓
<p>3D-4 - Public open space, where provided, is responsive to the existing pattern and uses of the neighbourhood.</p>		<p>The public open space should be well connected with public streets along at least one edge</p>	<p>No public open space</p>	N/A

## ADG OBJECTIVE

## DESIGN CRITERIA

## DESIGN GUIDANCE

## COMMENTS

## COMPLIANCE

The public open space should be connected with nearby parks and other landscape elements

Public open space should be linked through view lines, pedestrian desire paths, termination points and the wider street grid

Solar access should be provided year round along with protection from strong winds

Opportunities for a range of recreational activities should be provided for people of all ages

A positive address and active frontages should be provided adjacent to public open space

Boundaries should be clearly defined between public open space and private areas

---

### 3E DEEP SOIL ZONES

---

3E-1 - Deep soil zones provide areas on the site that allow for and support healthy plant and tree growth. They improve residential amenity and promote management of water and air quality.

Deep soil zones are to meet the following minimum requirements:  
Minimum dimension: 6m  
Percentage of site area: 7%

On some sites it may be possible to provide larger deep soil zones, depending on the site area and context:

- 10% of the site as deep soil on sites with an area of 650m<sup>2</sup> - 1,500m<sup>2</sup>
- 15% of the site as deep soil on sites greater than 1,500m<sup>2</sup>

Deep soil zones should be located to retain existing significant trees and to allow for the development of healthy root systems, providing anchorage and stability for mature trees. Design solutions may include:

- basement and sub basement car park design that is consolidated beneath building footprints
- use of increased front and side setbacks
- adequate clearance around trees to ensure long term health
- co-location with other deep soil areas on adjacent sites to create larger contiguous areas of deep soil

No opportunity for deep soil on city centre site

N/A

## ADG OBJECTIVE

## DESIGN CRITERIA

## DESIGN GUIDANCE

## COMMENTS

## COMPLIANCE

Achieving the design criteria may not be possible on some sites including where:

- the location and building typology have limited or no space for deep soil at ground level (e.g. central business district, constrained sites, high density areas, or in centres)
- there is 100% site coverage or non-residential uses at ground floor level.

Where a proposal does not achieve deep soil requirements, acceptable stormwater management should be achieved and alternative forms of planting provided such as on structure

---

### 3F VISUAL PRIVACY

---

3F-1 - Adequate building separation distances are shared between neighbouring sites, to achieve reasonable levels of external and internal visual privacy.

Separation between windows and balconies is provided to ensure visual privacy is achieved. Minimum required separation distances from buildings to the side and rear boundaries are as follows:

- 4 storeys: 6m for habitable rooms and balconies; 3m for non-habitable rooms.
- 5-8 storeys: 9m for habitable rooms and balconies; 4.5m for non-habitable rooms.
- 9+storeys: 12m for habitable rooms and balconies; 6m for non-habitable rooms.

Generally one step in the built form as the height increases due to building separations is desirable. Additional steps should be careful not to cause a 'ziggurat' appearance.

For residential buildings next to commercial buildings, separation distances should be measured as follows:

- for retail, office spaces and commercial balconies use the habitable room distances
- for service and plant areas use the non-habitable room distances

New development should be located and oriented to maximise visual privacy between buildings on site and for neighbouring buildings.

Design solutions include:

- site layout and building orientation to minimise privacy impacts (see also section 3B Orientation)
- on sloping sites, apartments on different levels have appropriate visual separation distances (see figure 3F.4)

The site is located in a highly dense city centre location with taller towers to both the northern and eastern side. Proposal is under 12m to north and east boundaries and under 24m from habitable rooms of neighbouring buildings. The proposal is carefully arranged to avoid direct overlooking. In additional privacy screens are proposed where the separation is under 24m between habitable rooms.

X

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE
		<p>Apartment buildings should have an increased separation distance of 3m (in addition to the requirements set out in design criteria 1) when adjacent to a different zone that permits lower density residential development to provide for a transition in scale and increased landscaping (figure 3F.5)</p> <p>Direct lines of sight should be avoided for windows and balconies across corners</p> <p>No separation is required between blank walls</p>		
<p>3F-2 - Site and building design elements increase privacy without compromising access to light and air and balance outlook and views from habitable rooms and private open space.</p>		<p>Communal open space, common areas and access paths should be separated from private open space and windows to apartments, particularly habitable room windows. Design solutions may include:</p> <ul style="list-style-type: none"> <li>• setbacks</li> <li>• solid or partially solid balustrades to balconies at lower levels</li> <li>• fencing and/or trees and vegetation to separate spaces</li> <li>• screening devices</li> <li>• bay windows or pop out windows to provide privacy in one direction and outlook in another</li> <li>• raising apartments/private open space above the public domain or communal open space</li> <li>• planter boxes incorporated into walls and balustrades to increase visual separation</li> <li>• pergolas or shading devices to limit overlooking of lower apartments or private open space</li> <li>• on constrained sites where it can be demonstrated that building layout opportunities are limited, fixed louvres or screen panels to windows and/or balconies</li> </ul> <p>Bedrooms, living spaces and other habitable rooms should be separated from gallery access and other open circulation space by the apartment's service areas</p> <p>Balconies and private terraces should be located in front of living rooms to increase internal privacy.</p> <p>Windows should be offset from the windows of adjacent buildings</p> <p>Recessed balconies and/or vertical fins should be used between adjacent balconies</p>	<p>No direct overlooking between habitable rooms. Privacy screens - vertical angled fins, that direct viewlines away from neighbours are proposed.</p>	<p>✓</p> <p>✓</p> <p>✗</p> <p>✓</p> <p>✓</p>
<p><b>3G PEDESTRIAN ACCESS AND ENTRIES</b></p>				

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE
3G-1 - Building entries and pedestrian access connects to and addresses the public domain.		Multiple entries (including communal building entries and individual ground floor entries) should be provided to activate the street edge		✓
		Entry locations relate to the street and subdivision pattern and the existing pedestrian network		✓
		Building entries should be clearly identifiable and communal entries should be clearly distinguishable from private entries.		✓
		Where street frontage is limited and multiple buildings are located on the site, a primary street address should be provided with clear sight lines and pathways to secondary building entries.		N/A
3G-2 - Access, entries and pathways are accessible and easy to identify.		Building access areas including lift lobbies, stairwells and hallways should be clearly visible from the public domain and communal spaces		✓
		The design of ground floors and underground car parks minimise level changes along pathways and entries.		✓
		Steps and ramps should be integrated into the overall building and landscape design.		✓
		For large developments 'way finding' maps should be provided to assist visitors and residents (see figure 4T.3)	Proposal has only one residential entry and one lift lobby.	N/A
		For large developments electronic access and audio/video intercom should be provided to manage access.		✓
3G-3 - Large sites provide pedestrian links for access to streets and connection to destinations		Pedestrian links through sites facilitate direct connections to open space, main streets, centres and public transport	A pedestrian link was proposed at concept stage but was deemed unnecessary by both council and the design review panel.	N/A
		Pedestrian links should be direct, have clear sight lines, be overlooked by habitable rooms or private open spaces of dwellings, be well lit and contain active uses, where appropriate		N/A

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE
<b>3H PEDESTRIAN ACCESS AND ENTRIES</b>				
3H-1 - Vehicle access points are designed and located to achieve safety, minimise conflicts between pedestrians and vehicles and create high quality streetscapes.	<p>Car park access should be integrated with the building's overall facade. Design solutions may include:</p> <ul style="list-style-type: none"> <li>• the materials and colour palette to minimise visibility from the street</li> <li>• security doors or gates at entries that minimise voids in the facade</li> <li>• where doors are not provided, the visible interior reflects the facade design and the building services, pipes and ducts are concealed</li> </ul>	Carpark entry is recessed from the facade line and secured by a metal roller shutter powdercoated to match mechanical louvres along the same facade facing Grafton Lane.	✓	
	Car park entries should be located behind the building line			✓
	Vehicle entries should be located at the lowest point of the site minimising ramp lengths, excavation and impacts on the building form and layout	✓		
	Car park entry and access should be located on secondary streets or lanes where available	Carpark entry is located at the rear lane of the site.	✓	
	Vehicle standing areas that increase driveway width and encroach into setbacks should be avoided		✓	
	Access point locations should avoid headlight glare to habitable rooms	✓		
	Adequate separation distances should be provided between vehicle entries and street intersections	✓		
	The width and number of vehicle access points should be limited to the minimum	✓		
	Visual impact of long driveways should be minimised through changing alignments and screen planting	No long driveway is proposed	✓	
	The need for large vehicles to enter or turn around within the site should be avoided		The need for large vehicles to enter or turn around within the site is restricted to the loading bay accessed from the rear lane.	✓
	Garbage collection, loading and servicing areas are screened	✓		
	Clear sight lines should be provided at pedestrian and vehicle crossings	✓		
	Traffic calming devices such as changes in paving material or textures should be used where appropriate	N/A		

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE
		<p>Pedestrian and vehicle access should be separated and distinguishable. Design solutions may include:</p> <ul style="list-style-type: none"> <li>• changes in surface materials</li> <li>• level changes</li> <li>• the use of landscaping for separation</li> </ul>	Pedestrian and vehicle access are separated	✓
<b>3J BICYCLE AND CAR PARKING</b>				
3J-1 - Car parking is provided based on proximity to public transport in metropolitan Sydney and centres in regional areas.	<p>For development in the following locations:</p> <ul style="list-style-type: none"> <li>• on sites that are within 800 metres of a railway station or light rail stop in the Sydney Metropolitan Area; or</li> <li>• on land zoned, and sites within 400 metres of land zoned, B3 Commercial Core, B4 Mixed Use or equivalent in a nominated regional centre the minimum car parking requirement for residents and visitors is set out in the Guide to Traffic Generating Developments, or the car parking requirement prescribed by the relevant council, whichever is less The car parking needs for a development must be provided off street</li> </ul>	Where a car share scheme operates locally, provide car share parking spaces within the development. Car share spaces, when provided, should be on site	The site is within 800 metres to the Bondi Junction Train station and bus interchange. Car parking is provided in accordance to the Waverley council DCP and is less than the maximum number permissible.	✓
		Where less car parking is provided in a development, council should not provide on street resident parking permits		N/A
		Conveniently located and sufficient numbers of parking spaces should be provided for motorbikes and scooters		✓
		Secure undercover bicycle parking should be provided that is easily accessible from both the public domain and common areas		✓
		Conveniently located charging stations are provided for electric vehicles, where desirable		N/A
3J-3 - Car park and design and access is safe and secure		Supporting facilities within car parks, including garbage, plant and switch rooms, storage areas and car wash bays can be accessed without crossing car parking spaces.		✓

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE
		Direct, clearly visible and well lit access should be provided into common circulation areas.		✓
		A clearly defined and visible lobby or waiting area should be provided to lifts and stairs.		✓
		For larger car parks, safe pedestrian access should be clearly defined and circulation areas have good lighting, colour, line marking and/or bollards.	Small carpark footprint proposed	N/A
3J-4 - Visual and environmental impacts of underground car parking are minimised		Excavation should be minimised through efficient car park layouts and ramp design		✓
		Car parking layout should be well organised, using a logical, efficient structural grid and double loaded aisles.	Carparking layout is restricted by the small site area but is well organised and efficient.	✓
		Protrusion of car parks should not exceed 1m above ground level. Design solutions may include stepping car park levels or using split levels on sloping sites.		✓
		Natural ventilation should be provided to basement and subbasement car parking areas.	Mechanical ventilation is provided.	N/A
		Ventilation grills or screening devices for car parking openings should be integrated into the facade and landscape design.		✓
<b>4A SOLAR AND DAYLIGHT ACCESS</b>				
4A-1 - To optimise the number of apartments receiving sunlight to habitable rooms, primary windows and private open space.	Living rooms and private open spaces of at least 70% of apartments in a building receive a minimum of 2 hours direct sunlight between 9 am and 3 pm at mid winter in the Sydney Metropolitan Area and in the Newcastle and Wollongong local government areas.		73.5% of living rooms receives a minimum of 2 hours direct sunlight between 9 am and 3 pm at mid winter	✓
	In all other areas, living rooms and private open spaces of at least 70% of apartments in a building receive a minimum of 3 hours direct sunlight between 9 am and 3 pm at mid winter.			N/A

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE
	A maximum of 15% of apartments in a building receive no direct sunlight between 9 am and 3 pm at mid winter.	The design maximises north aspect and the number of single aspect south facing apartments is minimised.	9.6% of apartments in a building receive no direct sunlight between 9 am and 3 pm at mid winter.	✓
		Single aspect, single storey apartments should have a northerly or easterly aspect.	The main street of the site is on the out, the number of south facing units have been controlled carefully with achieve a balanced urban design outcome. It is not possible to face all units away from a main street.	✗
		Living areas are best located to the north and service areas to the south and west of apartments.	Achieved where possible and where other aspects do not provide better amenities like significant views or solar access. Note that the proposed is largely overshadowed by a tall building to its north.	✓
		To optimise the direct sunlight to habitable rooms and balconies a number of the following design features are used: <ul style="list-style-type: none"> <li>• dual aspect apartments</li> <li>• shallow apartment layouts</li> <li>• two storey and mezzanine level apartments</li> <li>• bay windows</li> </ul>	A large proportion of units in the proposal are dual aspect apartments	✓
		To maximise the benefit to residents of direct sunlight within living rooms and private open spaces, a minimum of 1m2 of direct sunlight, measured at 1m above floor level, is achieved for at least 15 minutes.	The site is located in a highly congested area with tall buildings on 3 sides. The building has been tuned to capture any available sunlight coming in between neighbouring tower forms. Whilst the proposed achieves 73.5% to comply with the design criteria, it is not possible to improve this any further to all the units of the proposal. Refer to architectural design report for details	✗
		Achieving the design criteria may not be possible on some sites. This includes: <ul style="list-style-type: none"> <li>• where greater residential amenity can be achieved along a busy road or rail line by orientating the living rooms away from the noise source</li> <li>• on south facing sloping sites</li> <li>• where significant views are oriented away from the desired aspect for direct sunlight</li> </ul>		
		Design drawings need to demonstrate how site constraints and orientation preclude meeting the design criteria and how the development meets the objective		
4A-2 - Daylight access is maximised where sunlight is limited.		Courtyards, skylights and high level windows (with sills of 1,500mm or greater) are used only as a secondary light source in habitable rooms.		✓

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE
---------------	-----------------	-----------------	----------	------------

Where courtyards are used :

- use is restricted to kitchens, bathrooms and service areas
- building services are concealed with appropriate detailing and materials to visible walls
- courtyards are fully open to the sky
- access is provided to the light well from a communal area for cleaning and maintenance
- acoustic privacy, fire safety and minimum privacy separation distances (see section 3F Visual privacy) are achieved.

Opportunities for reflected light into apartments are optimised through:

- reflective exterior surfaces on buildings opposite south facing windows
- positioning windows to face other buildings or surfaces (on neighbouring sites or within the site) that will reflect light
- integrating light shelves into the design
- light coloured internal finishes

N/A

4A-3 - Design incorporates shading and glare control, particularly for warmer months.

A number of the following design features are used:

- balconies or sun shading that extend far enough to shade summer sun, but allow winter sun to penetrate living areas
- shading devices such as eaves, awnings, balconies, pergolas, external louvres and planting
- horizontal shading to north facing windows
- vertical shading to east and particularly west facing windows
- operable shading to allow adjustment and choice
- high performance glass that minimises external glare off windows, with consideration given to reduced tint glass or glass with a reflectance level below 20% (reflective films are avoided).

Vertical sunshading fins are proposed where appropriate to provide sunshading

✓

### 4B NATURAL VENTILATION

4B-1 - All habitable rooms are naturally ventilated.

The building's orientation maximises capture and use of prevailing breezes for natural ventilation in habitable rooms.

✓

Depths of habitable rooms support natural ventilation.

✓

The area of unobstructed window openings should be equal to at least 5% of the floor area served.

✓

Light wells are not the primary air source for habitable rooms.

✓

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE
		<p>Doors and openable windows maximise natural ventilation opportunities by using the following design solutions:</p> <ul style="list-style-type: none"> <li>• adjustable windows with large effective openable areas</li> <li>• a variety of window types that provide safety and flexibility such as awnings and louvres</li> <li>• windows which the occupants can reconfigure to funnel breezes into the apartment such as vertical louvres, casement windows and externally opening doors.</li> </ul>		✓
<p>4B-2 - The layout and design of the single aspect apartments maximises natural ventilation.</p>		<p>Apartment depths are limited to maximise ventilation and airflow (see also figure 4D.3).</p> <p>Natural ventilation to single aspect apartments is achieved with the following design solutions:</p> <ul style="list-style-type: none"> <li>• primary windows are augmented with plenums and light wells (generally not suitable for cross ventilation)</li> <li>• stack effect ventilation / solar chimneys or similar to naturally ventilate internal building areas or rooms such as bathrooms and laundries</li> <li>• courtyards or building indentations have a width to depth ratio of 2:1 or 3:1 to ensure effective air circulation and avoid trapped smells.</li> </ul>		✓
<p>4B-3 - The number of apartments with natural cross ventilation is maximised to create a comfortable indoor environment for residents.</p>	<p>At least 60% of apartments are naturally cross ventilated in the first nine storeys of the building. Apartments at ten storeys or greater are deemed to be cross ventilated only if any enclosure of the balconies at these levels allows adequate natural ventilation and cannot be fully enclosed.</p> <p>Overall depth of a cross-over or cross-through apartment does not exceed 18m, measured glass line to glass line.</p>	<p>The building should include dual aspect apartments, cross through apartments and corner apartments and limit apartment depths.</p> <p>In cross-through apartments external window and door opening sizes/ areas on one side of an apartment (inlet side) are approximately equal to the external window and door opening sizes/areas on the other side of the apartment (outlet side) (see figure 4B.3).</p>	<p>73.9% of apartments are naturally cross ventilated in the first nine storeys of the building.</p> <p>No cross over apartments proposed</p> <p>Proposal has a high percentage of dual aspect and corner apartments</p> <p>No cross over apartments proposed</p>	<p>✓</p> <p>N/A</p> <p>✓</p> <p>N/A</p>

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE
		Apartments are designed to minimise the number of corners, doors and rooms that might obstruct airflow		✓
		Apartment depths, combined with appropriate ceiling heights, maximise cross ventilation and airflow		✓
<b>4C CEILING HEIGHT</b>				
4C-1 - Ceiling height achieves sufficient natural ventilation and daylight access.	Minimum ceiling heights are: Habitable rooms: 2.7m Non-Habitable: 2.4m 2 Storey apartments: 2.7m for min living room floor, 2.4m for second floor (where its areas does not exceed 50% of the apartment area) Attic spaces: 1.8m at the edge of the room with 30 degree minimum ceiling slope If located in mixed use areas: 3.3m for ground and first floors.			✓
		Ceiling height can accommodate use of ceiling fans for cooling and heat distribution.		✓
4C-2 - Ceiling height increases the sense of space in apartments and provides for well proportioned rooms.		A number of the following design solutions can be used: <ul style="list-style-type: none"> <li>• the hierarchy of rooms in an apartment is defined using changes in ceiling heights and alternatives such as raked or curved ceilings, or double height spaces</li> <li>• well proportioned rooms are provided, for example, smaller rooms feel larger and more spacious with higher ceilings</li> <li>• ceiling heights are maximised in habitable rooms by ensuring that bulkheads do not intrude. The stacking of service rooms from floor to floor and coordination of bulkhead location above non-habitable areas, such as robes or storage, can assist.</li> </ul>		✓
4C-3 - Ceiling heights contribute to the flexibility of building use over the life of the building.		Ceiling heights of lower level apartments in centres should be greater than the minimum required by the design criteria allowing flexibility and conversion to non-residential uses (see figure 4C.1).	Ceiling heights of lower level apartments are restricted to the minimum by the overall urban design intent to match the podium level of the neighbouring building.	✗
<b>4D APARTMENT SIZE AND LAYOUT</b>				

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE
<p>4D-1 - The layout of rooms within an apartment is functional, well organised and provides a high standard of amenity.</p>	<p>Apartments are required to have the following minimum internal areas:</p>	Studio: 35m <sup>2</sup>	<p>All 2 bedroom aaprtmenst are over 75 sqm as 2 bathrooms have been provided</p>	✓
		1 Bedroom: 50m <sup>2</sup>		✓
		2 Bedroom: 70m <sup>2</sup>		✓
		3 Bedroom: 90m <sup>2</sup>		✓
		<p>The minimum internal areas include only one bathroom. Additional bathrooms increase the minimum internal area by 5m<sup>2</sup> each. A fourth bedroom and further additional bedrooms increase the minimum internal area by 12m<sup>2</sup> each.</p>		N/A
<p>Every habitable room must have a window in an external wall with a total minimum glass area of not less than 10% of the floor area of the room. Daylight and air may not be borrowed from other rooms.</p>	<p>Kitchens should not be located as part of the main circulation space in larger apartments (such as hallway or entry space).</p>	<p>A window should be visible from any point in a habitable room.</p>	<p>Where minimum areas or room dimensions are not met apartments need to demonstrate that they are well designed and demonstrate the usability and functionality of the space with realistically scaled furniture layouts and circulation areas.</p>	<p>These circumstances would be assessed on their merits.</p>
<p>4D-2 - Environmental performance of the apartment is maximised</p>	<p>Habitable room depths are limited to a maximum of 2.5 x the ceiling height.</p>	<p>In open plan layouts (where the living, dining and kitchen are combined) the maximum habitable room depth is 8m from a window.</p>		✓
	<p>Greater than minimum ceiling heights can allow for proportional increases in room depth up to the permitted maximum depths.</p>	✓		
	<p>All living areas and bedrooms should be located on the external face of the building.</p>	✓		
	✓			

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE	
		Where possible: <ul style="list-style-type: none"> <li>• bathrooms and laundries should have an external openable window</li> <li>• main living spaces should be oriented toward the primary outlook and aspect and away from noise sources</li> </ul>	A high number of bathrooms, especially on the tower levels have an open-able window	✓	
4D-3 - Apartment layouts are designed to accommodate a variety of household activities and needs	Master bedrooms have a minimum area of 10m <sup>2</sup> and other bedrooms 9m <sup>2</sup> (excluding wardrobe space).			✓	
	Bedrooms have a minimum dimension of 3m (excluding wardrobe space)			✓	
	Living rooms or combined living/dining rooms have a minimum width of: <ul style="list-style-type: none"> <li>• 3.6m for studio and 1 bedroom apartments</li> <li>• 4m for 2 and 3 bedroom apartments</li> </ul>			✓	
	The width of cross-over or cross-through apartments are at least 4m internally to avoid deep narrow apartment layouts.			No cross over apartments proposed	N/A
			Access to bedrooms, bathrooms and laundries is separated from living areas minimising direct openings between living and service areas.	Where possible.	✓
		All bedrooms allow a minimum length of 1.5m for robes.		✓	
		The main bedroom of an apartment or a studio apartment should be provided with a wardrobe of a minimum 1.8m long, 0.6m deep and 2.1m high.		✓	

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE
---------------	-----------------	-----------------	----------	------------

Apartment layouts allow flexibility over time, design solutions may include:

- dimensions that facilitate a variety of furniture arrangements and removal
- spaces for a range of activities and privacy levels between different spaces within the apartment
- dual master apartments
- dual key apartments

Note: dual key apartments which are separate but on the same title are regarded as two sole occupancy units for the purposes of the Building Code of Australia and for calculating the mix of apartments

- room sizes and proportions or open plans (rectangular spaces (2:3) are more easily furnished than square spaces (1:1))
- efficient planning of circulation by stairs, corridors and through rooms to maximise the amount of usable floor space in rooms.



### 4E PRIVATE OPEN SPACE AND BALCONIES

4E-1 - Apartments provide appropriately sized private open space and balconies to enhance residential amenity.

All apartments are required to have primary balconies as follows:  
 Studio: 4m<sup>2</sup>  
 1 Bedroom: 8m<sup>2</sup>, 2m minimum depth  
 2 Bedroom: 10m<sup>2</sup>, 2m minimum depth  
 3 Bedroom: 12m<sup>2</sup>, 2.4m minimum depth

The minimum balcony depth to be counted as contributing to the balcony area is 1m

For apartments at ground level or on a podium or similar structure, a private open space is provided instead of a balcony. It must have a minimum area of 15m<sup>2</sup> and a minimum depth of 3m.

For apartments at ground level or on a podium or similar structure, a private open space is provided instead of a balcony. It must have a minimum area of 15m<sup>2</sup> and a minimum depth of 3m.

Storage areas on balconies is additional to the minimum balcony size.

95.2% of apartments have primary balconies as required. A small handful of apartments located in the podium levels that faces the main street have juliet balconies in lieu of full 2m deep balconies. Use of balconies facing noisy main roads can be limited.



N/A

N/A

N/A

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE	
		<p>Balcony use may be limited in some proposals by:</p> <ul style="list-style-type: none"> <li>consistently high wind speeds at 10 storeys and above</li> <li>close proximity to road, rail or other noise sources</li> <li>exposure to significant levels of aircraft noise</li> <li>heritage and adaptive reuse of existing buildings</li> </ul>	Wind breaks in the form of vertical angled fins are proposed on balconies on high levels	✓	
		<p>In these situations, juliet balconies, operable walls, enclosed wintergardens or bay windows may be appropriate, and other amenity benefits for occupants should also be provided in the apartments or in the development or both. Natural ventilation also needs to be demonstrated.</p>			
4E-2 - Primary private open space and balconies are appropriately located to enhance livability for residents.		Primary open space and balconies should be located adjacent to the living room, dining room or kitchen to extend the living space.		✓	
		Private open spaces and balconies predominantly face north, east or west.	✓		
		Primary open space and balconies should be orientated with the longer side facing outwards or be open to the sky to optimise daylight access into adjacent rooms.	✓		
4E-3 - Private open space and balcony design is integrated into and contributes to the overall architectural form and detail of the building.		Solid, partially solid or transparent fences and balustrades are selected to respond to the location. They are designed to allow views and passive surveillance of the street while maintaining visual privacy and allowing for a range of uses on the balcony. Solid and partially solid balustrades are preferred.	Glass balustrades are proposed to maximise significant views in all directions from the proposed site.	X	
		Full width full height glass balustrades alone are generally not desirable.	The site has significant city and water views out.	X	
		Projecting balconies should be integrated into the building design and the design of soffits considered.			N/A
		Operable screens, shutters, hoods and pergolas are used to control sunlight and wind.		Fixed screens are integrated to control sunlight and wind.	✓
		Balustrades are set back from the building or balcony edge where overlooking or safety is an issue			N/A
		Downpipes and balcony drainage are integrated with the overall facade and building design.			✓

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE
		Air-conditioning units should be located on roofs, in basements, or fully integrated into the building design.		✓
		Where clothes drying, storage or air conditioning units are located on balconies, they should be screened and integrated in the building design.		N/A
		Ceilings of apartments below terraces should be insulated to avoid heat loss.		✓
		Water and gas outlets should be provided for primary balconies and private open space.		✓
4E-4 - Private open space and balcony design maximises safety		Changes in ground levels or landscaping are minimised.		✓
		Design and detailing of balconies avoids opportunities for climbing and falls.		✓
<b>4E PRIVATE OPEN SPACE AND BALCONIES</b>				
4F-1 - Common circulation spaces achieve good amenity and properly service the number of apartments	The maximum number of apartments off a circulation core on a single level is eight.			✓
	For buildings of 10 storeys and over, the maximum number of apartments sharing a single lift is 40.		High performance lifts will be installed to service the building. A study has been conducted by a lift engineer to substantiate adequate performance of the lifts.	X
		Greater than minimum requirements for corridor widths and/ or ceiling heights allow comfortable movement and access particularly in entry lobbies, outside lifts and at apartment entry doors.	Where possible	✓
		Daylight and natural ventilation should be provided to all common circulation spaces that are above ground.		✓
		Windows should be provided in common circulation spaces and should be adjacent to the stair or lift core or at the ends of corridors.		✓
		Longer corridors greater than 12m in length from the lift core should be articulated. Design solutions may include: <ul style="list-style-type: none"> <li>• a series of foyer areas with windows and spaces for seating</li> <li>• wider areas at apartment entry doors and varied ceiling heights</li> </ul>		N/A

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE
		Design common circulation spaces to maximise opportunities for dual aspect apartments, including multiple core apartment buildings and cross over apartments.		✓
		Achieving the design criteria for the number of apartments off a circulation core may not be possible. Where a development is unable to achieve the design criteria, a high level of amenity for common lobbies, corridors and apartments should be demonstrated, including: <ul style="list-style-type: none"> <li>• sunlight and natural cross ventilation in apartments</li> <li>• access to ample daylight and natural ventilation in common circulation spaces</li> <li>• common areas for seating and gathering</li> <li>• generous corridors with greater than minimum ceiling heights</li> <li>• other innovative design solutions that provide high levels of amenity</li> </ul>		N/A
		Where design criteria 1 is not achieved, no more than 12 apartments should be provided off a circulation core on a single level		N/A
		Primary living room or bedroom windows should not open directly onto common circulation spaces, whether open or enclosed. Visual and acoustic privacy from common circulation spaces to any other rooms should be carefully controlled.		✓
4F-2 - Common circulation spaces promote safety and provide for social interaction between residents		Direct and legible access should be provided between vertical circulation points and apartment entries by minimising corridor or gallery length to give short, straight, clear sight lines.		✓
		Tight corners and spaces are avoided.	✓	
		Circulation spaces should be well lit at night.	✓	
		Legible signage should be provided for apartment numbers, common areas and general wayfinding.	✓	
		Incidental spaces, for example space for seating in a corridor, at a stair landing, or near a window are provided.	✓	
		In larger developments, community rooms for activities such as owners corporation meetings or resident use should be provided and are ideally co-located with communal open space.	N/A	

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE
		Where external galleries are provided, they are more open than closed above the balustrade along their length.		N/A
<b>4G STORAGE</b>				
4G-1 - Adequate, well designed storage is provided in each apartment	In addition to storage in kitchens, bathrooms and bedrooms, the following storage is provided: Studio: 4m3 1 Bedroom: 6m3 2 Bedroom: 8m3 3 Bedroom: 10m3 At least 50% of the required storage is to be located within the apartment.		All apartments meet or exceed the requirements for storage.	✓
		Storage is accessible from either circulation or living areas.		✓
		Storage provided on balconies (in addition to the minimum balcony size) is integrated into the balcony design, weather proof and screened from view from the street.		N/A
		Left over space such as under stairs is used for storage.		N/A
4G-2 - Additional storage is conveniently located, accessible and nominated for individual apartments		Storage not located in apartments is secure and clearly allocated to specific apartments.	All storage cages are located in basements and are individually allocated to each unit.	✓
		Storage is provided for larger and less frequently accessed items.		✓
		Storage space in internal or basement car parks is provided at the rear or side of car spaces or in cages so that allocated car parking remains accessible.		✓
		If communal storage rooms are provided they should be accessible from common circulation areas of the building.		✓
		Storage not located in an apartment is integrated into the overall building design and is not visible from the public domain.		✓

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE
<b>4H ACOUSTIC PRIVACY</b>				
4H-1 - Noise transfer is minimised through the siting of buildings and building layout		Adequate building separation is provided within the development and from neighbouring buildings/adjacent uses (see also section 2F Building separation and section 3F Visual privacy).		✓
		Window and door openings are generally orientated away from noise sources.	Generally complies with the exception of podium level units that addresses the main street.	✓
		Noisy areas within buildings including building entries and corridors should be located next to or above each other and quieter areas next to or above quieter areas		✓
		Storage, circulation areas and non-habitable rooms should be located to buffer noise from external sources.		✓
		The number of party walls (walls shared with other apartments) are limited and are appropriately insulated.		✓
		Noise sources such as garage doors, driveways, service areas, plant rooms, building services, mechanical equipment, active communal open spaces and circulation areas should be located at least 3m away from bedrooms.		✓
4H-2 - Noise impacts are mitigated within apartments through layout and acoustic treatments		Internal apartment layout separates noisy spaces from quiet spaces, using a number of the following design solutions: <ul style="list-style-type: none"> <li>• rooms with similar noise requirements are grouped together</li> <li>• doors separate different use zones</li> <li>• wardrobes in bedrooms are co-located to act as sound buffers</li> </ul>		✓
		Where physical separation cannot be achieved noise conflicts are resolved using the following design solutions: <ul style="list-style-type: none"> <li>• double or acoustic glazing</li> <li>• acoustic seals</li> <li>• use of materials with low noise penetration properties</li> <li>• continuous walls to ground level courtyards where they do not conflict with streetscape or other amenity requirements</li> </ul>		✓

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE
---------------	-----------------	-----------------	----------	------------

**4J NOISE AND POLLUTION**

4J-1 - In noisy or hostile environments the impacts of external noise and pollution are minimised through the careful siting and layouts of buildings.

- To minimise impacts the following design solutions may be used:
- physical separation between buildings and the noise or pollution source.
  - residential uses are located perpendicular to the noise source and where possible buffered by other uses.
  - non-residential buildings are sited to be parallel with the noise source to provide a continuous building that shields residential uses and communal open spaces.
  - non-residential uses are located at lower levels vertically separating the residential component from the noise or pollution source. Setbacks to the underside of residential floor levels should increase relative to traffic volumes and other noise sources.
  - buildings should respond to both solar access and noise. Where solar access is away from the noise source, nonhabitable rooms can provide a buffer
  - where solar access is in the same direction as the noise source, dual aspect apartments with shallow building depths are preferable (see figure 4J.4)
  - landscape design reduces the perception of noise and acts as a filter for air pollution generated by traffic and industry

The site faces the main street and cannot avoid having units address the street. The facade proposed has a higher than normal (1/3) solid to void ratio to maximise the privacy and noise impact to the balconies that front the street.



- Achieving the design criteria in this Apartment Design Guide may not be possible in some situations due to noise and pollution. Where developments are unable to achieve the design criteria, alternatives may be considered in the following areas:
- solar and daylight access
  - private open space and balconies
  - natural cross ventilation



4J-2 - Appropriate noise shielding or attenuation techniques for the building design, construction and choice of materials are used to mitigate noise transmission.

- Design solutions to mitigate noise include:
- limiting the number and size of openings facing noise sources
  - providing seals to prevent noise transfer through gaps
  - using double or acoustic glazing, acoustic louvres or enclosed balconies (wintergardens)
  - using materials with mass and/or sound insulation or absorption properties e.g. solid balcony balustrades, external screens and soffits.



ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE
---------------	-----------------	-----------------	----------	------------

**4K APARTMENT MIX**

4K-1 - A range of apartment types and sizes is provided to cater for different household types now and into the future.

A variety of apartment types is provided.

✓

The apartment mix is appropriate, taking into consideration:

- the distance to public transport, employment and education centres
- the current market demands and projected future demographic trends
- the demand for social and affordable housing
- different cultural and socioeconomic groups.

✓

Flexible apartment configurations are provided to support diverse household types and stages of life including single person households, families, multi-generational families and group households.

✓

4K-1 - A range of apartment types and sizes is provided to cater for different household types now and into the future.

Different apartment types are located to achieve successful facade composition and to optimise solar access (see figure 4K.3).

✓

Larger apartment types are located on the ground or roof level where there is potential for more open space and on corners where more building frontage is available.

No ground floor apartments

N/A

**4L GROUND FLOOR APARTMENTS**

4L-1 - Street frontage activity is maximised where ground floor apartments are located

Direct street access should be provided to ground floor apartments.

No ground floor apartments

N/A

Activity is achieved through front gardens, terraces and the facade of the building. Design solutions may include:

- both street, foyer and other common internal circulation entrances to ground floor apartments
- private open space is next to the street
- doors and windows face the street.

Retail or home office spaces should be located along street frontages.

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE
---------------	-----------------	-----------------	----------	------------

Ground floor apartment layouts support small office home office (SOHO) use to provide future opportunities for conversion into commercial or retail areas. In these cases provide higher floor to ceiling heights and ground floor amenities for easy conversion.

N/A

4L-2 - Design of ground floor apartments delivers amenity and safety for residents.

Privacy and safety should be provided without obstructing casual surveillance. Design solutions may include:

- elevation of private gardens and terraces above the street level by 1-1.5m (see figure 4L.4)
- landscaping and private courtyards
- window sill heights that minimise sight lines into apartments
- integrating balustrades, safety bars or screens with the exterior design

Solar access should be maximised through:

- high ceilings and tall windows
- trees and shrubs that allow solar access in winter and shade in summer.

No ground floor apartments

N/A

### 4M FACADES

4M-1 - Design of ground floor apartments delivers amenity and safety for residents.

Design solutions for front building facades may include:

- a composition of varied building elements
- a defined base, middle and top of buildings
- revealing and concealing certain elements
- changes in texture, material, detail and colour to modify the prominence of elements.

Building services should be integrated within the overall façade.

Building facades should be well resolved with an appropriate scale and proportion to the streetscape and human scale. Design solutions may include:

- well composed horizontal and vertical elements
- variation in floor heights to enhance the human scale
- elements that are proportional and arranged in patterns
- public artwork or treatments to exterior blank walls
- grouping of floors or elements such as balconies and windows on taller buildings.

Building facades relate to key datum lines of adjacent buildings through upper level setbacks, parapets, cornices, awnings or colonnade heights.

The building is clearly defined with a tower top, a middle podium, and a 2 storey retail bottom that front Adelaide Street

✓

The facade consists of a balanced composition of vertical metal fins and ceramic cladding to present a high quality facade to the street and beyond.

✓

✓

✓

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE
		Shadow is created on the facade throughout the day with building articulation, balconies and deeper window reveals.		✓
4M-2 - Building functions are expressed by the facade		Building entries should be clearly defined.		✓
		Important corners are given visual prominence through a change in articulation, materials or colour, roof expression or changes in height.	The corners of the tower are defined by a series of vertical bronze/champagne metal fins	✓
		The apartment layout should be expressed externally through facade features such as party walls and floor slabs.		✓
<b>4N ROOF DESIGN</b>				
4N-1 - Roof treatments are integrated into the building design and positively respond to the street		<p>Roof design relates to the street. Design solutions may include:</p> <ul style="list-style-type: none"> <li>• special roof features and strong corners</li> <li>• use of skillion or very low pitch hipped roofs</li> <li>• breaking down the massing of the roof by using smaller elements to avoid bulk</li> <li>• using materials or a pitched form complementary to adjacent buildings.</li> </ul> <p>Roof treatments should be integrated with the building design. Design solutions may include:</p> <ul style="list-style-type: none"> <li>• roof design proportionate to the overall building size, scale and form</li> <li>• roof materials compliment the building</li> <li>• service elements are integrated.</li> </ul>	The proposal is for a tower building and its relevance from the street level is minimal. A strong feature roof is not appropriate to the proposal and an integrated subtle roof element that sits behind the building fronts is proposed.	N/A
				✓
4N-2 - Opportunities to use roof space for residential accommodation and open space are maximised		<p>Habitable roof space should be provided with good levels of amenity. Design solutions may include:</p> <ul style="list-style-type: none"> <li>• penthouse apartments</li> <li>• dormer or clerestory windows</li> <li>• openable skylights.</li> </ul>		✓
		Open space is provided on roof tops subject to acceptable visual and acoustic privacy, comfort levels, safety and security considerations.		✓

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE
4N-3 - Roof design incorporates sustainability features	<p>Roof design maximises solar access to apartments during winter and provides shade during summer. Design solutions may include:</p> <ul style="list-style-type: none"> <li>• the roof lifts to the north</li> <li>• eaves and overhangs shade walls and windows from summer sun.</li> </ul>	<p>Skylights and ventilation systems should be integrated into the roof design.</p>		✓
				N/A
<b>40 LANDSCAPE DESIGN</b>				
40-1 - Landscape design is viable and sustainable	<p>Landscape design should be environmentally sustainable and can enhance environmental performance by incorporating:</p> <ul style="list-style-type: none"> <li>• diverse and appropriate planting</li> <li>• bio-filtration gardens</li> <li>• appropriately planted shading trees</li> <li>• areas for residents to plant vegetables and herbs</li> <li>• composting</li> <li>• green roofs or walls.</li> </ul>	<p>Ongoing maintenance plans should be prepared.</p>	<p>To be provided at later stages</p>	✓
	<p>Microclimate is enhanced by:</p> <ul style="list-style-type: none"> <li>• appropriately scaled trees near the eastern and western elevations for shade</li> <li>• a balance of evergreen and deciduous trees to provide shading in summer and sunlight access in winter</li> <li>• shade structures such as pergolas for balconies and courtyards.</li> </ul>	<p>Tree and shrub selection considers size at maturity and the potential for roots to compete (see Table 4).</p>		N/A
				✓
40-2 - Landscape design contributes to the streetscape and amenity	<p>Landscape design responds to the existing site conditions including:</p> <ul style="list-style-type: none"> <li>• changes of levels</li> <li>• views</li> <li>• significant landscape features including trees and rock outcrops.</li> </ul>	<p>Significant landscape features should be protected by:</p> <ul style="list-style-type: none"> <li>• tree protection zones (see figure 40.5)</li> <li>• appropriate signage and fencing during construction.</li> </ul>	<p>Plants selected should be endemic to the region and reflect the local ecology.</p>	✓
				✓

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE
<b>4P PLANTING ON STRUCTURES</b>				
4P-1 - Appropriate soil profiles are provided		Structures are reinforced for additional saturated soil weight.		✓
		Soil volume is appropriate for plant growth, considerations include: <ul style="list-style-type: none"> <li>• modifying depths and widths according to the planting mix and irrigation frequency</li> <li>• free draining and long soil life span</li> <li>• tree anchorage.</li> </ul>		✓
		Minimum soil standards for plant sizes should be provided in accordance with Table 5.		✓
4P-2 - Appropriate soil profiles are provided		Plants are suited to site conditions, considerations include: <ul style="list-style-type: none"> <li>• drought and wind tolerance</li> <li>• seasonal changes in solar access</li> <li>• modified substrate depths for a diverse range of plants</li> <li>• plant longevity.</li> </ul>		✓
		A landscape maintenance plan is prepared.	To be provided at later stages	N/A
		Irrigation and drainage systems respond to: <ul style="list-style-type: none"> <li>• changing site conditions</li> <li>• soil profile and the planting regime</li> <li>• whether rainwater, stormwater or recycled grey water is used.</li> </ul>	To be provided at later stages	N/A
4P-3 - Planting on structures contributes to the quality and amenity of communal and public open spaces.		Building design incorporates opportunities for planting on structures. Design solutions may include: <ul style="list-style-type: none"> <li>• green walls with specialised lighting for indoor green walls</li> <li>• wall design that incorporates planting</li> <li>• green roofs, particularly where roofs are visible from the public domain</li> <li>• planter boxes</li> </ul>		✓
		Note: structures designed to accommodate green walls should be integrated into the building facade and consider the ability of the facade to change over time.		
<b>4Q UNIVERSAL DESIGN</b>				

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE
4Q-1 - Universal design features are included in apartment design to promote flexible housing for all community members		Developments achieve a benchmark of 20% of the total apartments incorporating the Livable Housing Guideline's silver level universal design features.		✓
4Q-2 - A variety of apartments with adaptable designs are provided		Adaptable housing should be provided in accordance with the relevant council policy.		✓
		<p>Design solutions for adaptable apartments include:</p> <ul style="list-style-type: none"> <li>• convenient access to communal and public areas</li> <li>• high level of solar access</li> <li>• minimal structural change and residential amenity loss when adapted</li> <li>• larger car parking spaces for accessibility</li> <li>• parking titled separately from apartments or shared car parking arrangements.</li> </ul>		✓
4Q-3 - Apartment layouts are flexible and accommodate a range of lifestyle needs		<p>Apartment design incorporates flexible design solutions which may include:</p> <ul style="list-style-type: none"> <li>• rooms with multiple functions</li> <li>• dual master bedroom apartments with separate bathrooms</li> <li>• larger apartments with various living space options</li> <li>• open plan 'loft' style apartments with only a fixed kitchen, laundry and bathroom.</li> </ul>		✓
<b>4R ADAPTIVE REUSE</b>				
4R-1 - New additions to existing buildings are contemporary and enhance an area's identity and sense of place		<p>Design solutions may include:</p> <ul style="list-style-type: none"> <li>• new elements to align with the existing building</li> <li>• additions that complement the existing character, siting, scale, proportion, pattern, form and detailing</li> <li>• use of contemporary and complementary materials, finishes, textures and colours.</li> </ul> <p>Additions to heritage items should be clearly identifiable from the original building.</p> <p>New additions allow for the interpretation and future evolution of the building</p>		N/A

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE
---------------	-----------------	-----------------	----------	------------

4R-2 - Adapted buildings provide residential amenity while not precluding future adaptive reuse

Design features should be incorporated sensitively into adapted buildings to make up for any physical limitations, to ensure residential amenity is achieved. Design solutions may include:

- generously sized voids in deeper buildings
- alternative apartment types when orientation is poor
- using additions to expand the existing building envelope.

Some proposals that adapt existing buildings may not be able to achieve all of the design criteria in this Apartment Design Guide. Where developments are unable to achieve the design criteria, alternatives could be considered in the following areas:

- where there are existing higher ceilings, depths of habitable rooms could increase subject to demonstrating access to natural ventilation, cross ventilation (when applicable) and solar and daylight access (see also sections 4A Solar and daylight access and 4B Natural ventilation)
- alternatives to providing deep soil where less than the minimum requirement is currently available on the site
- building and visual separation – subject to demonstrating alternative design approaches to achieving privacy
- common circulation
- car parking
- alternative approaches to private open space and balconies.

N/A

### 4S MIXED USE

4S-1 - Mixed use developments are provided in appropriate locations and provide active street frontages that encourage pedestrian movement

Mixed use development should be concentrated around public transport and centres.

✓

Mixed use developments positively contribute to the public domain. Design solutions may include:

- development addresses the street
- active frontages are provided
- diverse activities and uses
- avoiding blank walls at the ground level
- live/work apartments on the ground floor level, rather than commercial.

✓

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE
4S-2 - Residential levels of the building are integrated within the development, and safety and amenity is maximised for residents		<p>Residential circulation areas should be clearly defined. Design solutions may include:</p> <ul style="list-style-type: none"> <li>• residential entries are separated from commercial entries and directly accessible from the street</li> <li>• commercial service areas are separated from residential components</li> <li>• residential car parking and communal facilities are separated or secured</li> <li>• security at entries and safe pedestrian routes are provided</li> <li>• concealment opportunities are avoided</li> </ul> <p>Landscaped communal open space should be provided at podium or roof levels.</p>		✓
<b>4T AWNINGS AND SIGNAGE</b>				
4T-1 - Awnings are well located and complement and integrate with the building design		Awnings should be located along streets with high pedestrian activity and active frontages.		✓
		<p>A number of the following design solutions are used:</p> <ul style="list-style-type: none"> <li>• continuous awnings are maintained and provided in areas with an existing pattern</li> <li>• height, depth, material and form complements the existing street character</li> <li>• protection from the sun and rain is provided</li> <li>• awnings are wrapped around the secondary frontages of corner sites</li> <li>• awnings are retractable in areas without an established pattern.</li> </ul>		✓
		Awnings should be located over building entries for building address and public domain amenity.		✓
		Awnings relate to residential windows, balconies, street tree planting, power poles and street infrastructure.		✓
		Gutters and down pipes should be integrated and concealed.		✓
		Lighting under awnings should be provided for pedestrian safety.		✓
4T-2 - Signage responds to the context and desired streetscape character		Signage should be integrated into the building design and respond to the scale, proportion and detailing of the development.		✓

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE
		Legible and discrete way finding should be provided for larger developments.		✓
		Signage is limited to being on and below awnings and a single facade sign on the primary street frontage.		✓
<b>4U ENERGY EFFICIENCY</b>				
4U-1 - Development incorporates passive environmental design		Adequate natural light is provided to habitable rooms (see 4A Solar and daylight access).		✓
		Well located, screened outdoor areas should be provided for clothes drying.	A Clothesdryer is provided for every unit	N/A
4U-2 - Development incorporates passive solar design to optimise heat storage in winter and reduce heat transfer in summer		<p>A number of the following design solutions are used:</p> <ul style="list-style-type: none"> <li>• the use of smart glass or other technologies on north and west elevations</li> <li>• thermal mass in the floors and walls of north facing rooms is maximised</li> <li>• polished concrete floors, tiles or timber rather than carpet</li> <li>• insulated roofs, walls and floors and seals on window and door openings</li> <li>• overhangs and shading devices such as awnings, blinds and screens</li> </ul>		✓
		Provision of consolidated heating and cooling infrastructure should be located in a centralised location (e.g. the basement)		
4U-3 - Adequate natural ventilation minimises the need for mechanical ventilation		<p>A number of the following design solutions are used:</p> <ul style="list-style-type: none"> <li>• rooms with similar usage are grouped together</li> <li>• natural cross ventilation for apartments is optimised</li> <li>• natural ventilation is provided to all habitable rooms and as many non-habitable rooms, common areas and circulation spaces as possible.</li> </ul>		✓
<b>4V WATER MANAGEMENT AND CONSERVATION</b>				
4V-1 - Potable water use is minimised		Water efficient fittings, appliances and wastewater reuse should be incorporated.		✓
		Apartments should be individually metered.		✓

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE
		Rainwater should be collected, stored and reused on site.		✓
		Drought tolerant, low water use plants should be used within landscaped areas.		✓
4V-2 - Urban stormwater is treated before being discharged to receiving waters		Water sensitive urban design systems are designed by a suitably qualified professional.		✓
		A number of the following design solutions are used: <ul style="list-style-type: none"> <li>• runoff is collected from roofs and balconies in water tanks and plumbed into toilets, laundry and irrigation</li> <li>• porous and open paving materials is maximised</li> <li>• on site stormwater and infiltration, including bio-retention systems such as rain gardens or street tree pits.</li> </ul>		✓
4V-3 - Flood management systems are integrated into site design		Detention tanks should be located under paved areas, driveways or in basement car parks.		✓
		On large sites parks or open spaces are designed to provide temporary on site detention basins.		N/A
<b>4W WASTE MANAGEMENT</b>				
4W-1 - Waste storage facilities are designed to minimise impacts on the streetscape, building entry and amenity of residents.		Adequately sized storage areas for rubbish bins should be located discreetly away from the front of the development or in the basement car park.		✓
		Waste and recycling storage areas should be well ventilated.		✓
		Circulation design allows bins to be easily manoeuvred between storage and collection points.		✓
		Temporary storage should be provided for large bulk items such as mattresses.		✓
		A waste management plan should be prepared.		✓

ADG OBJECTIVE	DESIGN CRITERIA	DESIGN GUIDANCE	COMMENTS	COMPLIANCE
4W-2 - Domestic waste is minimised by providing safe and convenient source separation and recycling		All dwellings should have a waste and recycling cupboard or temporary storage area of sufficient size to hold two days worth of waste and recycling.		✓
		Communal waste and recycling rooms are in convenient and accessible locations related to each vertical core.		✓
		For mixed use developments, residential waste and recycling storage areas and access should be separate and secure from other uses. Alternative waste disposal methods such as composting should be provided.		✓
<b>4X BUILDING MAINTENANCE</b>				
4X-1 - Building design detail provides protection from weathering		A number of the following design solutions are used: <ul style="list-style-type: none"> <li>• roof overhangs to protect walls</li> <li>• hoods over windows and doors to protect openings</li> <li>• detailing horizontal edges with drip lines to avoid staining of surfaces</li> <li>• methods to eliminate or reduce planter box leaching</li> <li>• appropriate design and material selection for hostile locations</li> </ul>		✓
	4X-2 - Systems and access enable ease of maintenance	<p>Window design enables cleaning from the inside of the building.</p> <p>Building maintenance systems should be incorporated and integrated into the design of the building form, roof and façade.</p> <p>Design solutions do not require external scaffolding for maintenance access.</p> <p>Manually operated systems such as blinds, sunshades and curtains are used in preference to mechanical systems.</p> <p>Centralised maintenance, services and storage should be provided for communal open space areas within the building.</p>	Building maintenance systems are incorporated and integrated into the design of the building form, roof and façade.	✓

**ADG OBJECTIVE****DESIGN CRITERIA****DESIGN GUIDANCE****COMMENTS****COMPLIANCE**

---

4X-3 - Material selection reduces ongoing maintenance costs

A number of the following design solutions are used:

- sensors to control artificial lighting in common circulation and spaces
- natural materials that weather well and improve with time such as face brickwork
- easily cleaned surfaces that are graffiti resistant
- robust and durable materials and finishes are used in locations which receive heavy wear and tear, such as common circulation areas and lift interiors

