



CUMBERLAND  
COUNCIL

Our Reference:  
Contact:  
Phone:

2017/203/1  
Mr P Anzellotti  
02 8745 9771

**ENVIRONMENTAL PLANNING & ASSESSMENT ACT 1979  
NOTICE OF DETERMINATION OF APPLICATION**

**To Be Advised**

Amelie Housing C/- Hawes & Swan Planning  
Attention: Melissa Stilloni  
Suite 4, Level 4, 35 Buckingham Street  
SURRY HILLS NSW 2010

Dear Madam

Pursuant to Section 81 of the Act, Council has granted conditional approval to your Development Application described as follows:

**PROPERTY:** Lots 1 & 2, DP 597975 and Lot: 19-24, Sec 3, DP 2020

**STREET ADDRESS:** 11-19 Centenary Road, Merrylands

**DEVELOPMENT CONSENT NO:** 2017/203/1

**DECISION:** Sydney West Central Planning Panel

**DATE OF EXPIRY OF CONSENT:** To Be Advised

**PROPOSED DEVELOPMENT:** Demolition of existing structures, consolidation of 8 lots into 1 lot, construction of a 4 storey residential flat building comprising 78 units under Affordable Rental Housing SEPP 2009 above basement parking accommodating 68 car parking spaces

This Development Application is APPROVED in accordance with the Environmental Planning & Assessment Act 1979 and is subject to compliance with the requirements of Cumberland Council, the Building Code of Australia, the Local Government Act 1993, and the following conditions as set out hereunder and/or endorsed upon the attached plans.

16 Memorial Avenue, PO Box 42, Merrylands NSW 2160  
T 02 8757 9000 F 02 9840 9734 E [council@cumberland.nsw.gov.au](mailto:council@cumberland.nsw.gov.au) W [cumberland.nsw.gov.au](http://cumberland.nsw.gov.au)  
ABN 22 798 563 329

*Welcome Belong Succeed*

## Important

English

This letter contains important information. If you do not understand it please ask a relative or friend to translate it or come to Council and discuss this letter with Council's staff using the Telephone Interpreter Service.

هام

Arabic

تحتوي هذه الرسالة على معلومات هامة. إذا لم تكن تفهمها يرجى طلب ترجمتها من قريب أو صديق أو احضر إلى المجلس وناقش هذه الرسالة مع موظفي المجلس عن طريق الاستعانة بخدمة الترجمة الهاتفية.

## 重要資訊

Cantonese

本函包含重要的資訊。如果您無法理解相關內容，可請您的親屬或朋友翻譯成中文，或者前往市政府並通過電話傳譯服務與市政府的工作人員討論本函內容。

هههه

Dari

این نامه حاوی معلومات مهم است. اگر شما آن را نمی فهمید، از دوستان یا فامیل تان بخواهید که برایتان ترجمه کند و یا به شورا آمده و در مورد این نامه با کارمندان شورا با استفاده از خدمات ترجمه تلفونی بحث کنید.

## Σημαντικό

Greek

Αυτή η επιστολή περιέχει σημαντικές πληροφορίες. Εάν δεν την καταλαβαίνετε, ζητήστε από ένα συγγενή ή φίλο να σας την μεταφράσει, ή ελάτε στο Συμβούλιο και συζητήστε για την επιστολή με το προσωπικό του Συμβουλίου χρησιμοποιώντας την Τηλεφωνική Υπηρεσία Διερμηνέων.

## महत्वपूर्ण

Hindi

इस पत्र में महत्वपूर्ण जानकारी दी गई है। यदि आप इसे नहीं समझ पाते हैं तो कृपया अपने रिश्तेदार या दोस्त से कहें कि वे इसे अनुवाद कर बताएँ या परिषद में आएँ और टेलीफोन दुभाषिया सेवा का इस्तेमाल करते हुए परिषद के स्टाफ के साथ इस पत्र पर चर्चा करें।

## IMPORTANTE

Italian

Questa lettera contiene informazioni importanti. Se non la comprende chiedi ad un parente od amico di tradurgliela, o venga al Municipio a discuterla col personale del Comune con l'aiuto del Servizio Telefonico Interpreti.

## 중요

Korean

이 서신에는 중요한 정보가 포함되어 있습니다. 잘 이해되지 않으면, 친척이나 친구에게 번역을 부탁하거나 또는 위원회를 방문하여 전화 통역 서비스로 위원회 직원과 이 서신에 대해 논의하십시오.

## Importanti

Maltese

Din l-ittra fiha taghrif importanti. Jekk ma tifimhiex, jekk joghgbok staqsi lil qarib jew habib biex jittraducihielek jew ejja sal-Kunsill u ddiskuti din l-ittra ma' l-istaff tal-Kunsill billi tuza s-Servizz Telefoniku tal-Interpreti.

## 重要信息

Mandarin

本函包含重要的信息。如果您无法理解相关内容，可请您的亲属或朋友翻译成中文，或者前往市政府并通过电话传译服务与市政府的工作人员讨论本函内容。

## Mahalaga

Tagalog

Ang sulat na ito ay naglalaman ng mahalagang impormasyon. Kung hindi mo ito nauunawaan, mangyaring hilingin ang isang kamag-anak o kaibigan na isalin ito o lumapit sa isang Council at talakayin ang sulat na ito sa kawani ng Council gamit ang Serbisyo ng Interpreter sa Telepono.

## முக்கிய குறிப்பு:

Tamil

இந்த கடிதத்தில் முக்கிய தகவல் அடங்கியுள்ளது. உங்களுக்கு இது புரியவில்லையென்றால், உங்கள் உறவினர் அல்லது நண்பரை மொழிபெயர்க்க சொல்லி கேட்கவும் அல்லது அமைச்சகத்திற்கு வருகை அளித்து, அமைச்சக அலுவலருடன் தொலைபேசி மொழிபெயர்ப்பு சேவை உதவியுடன் இந்த கடிதத்தைப் பற்றி விவாதிக்கவும்.

## Önemli

Turkish

Bu mektup önemli bilgiler içermektedir. Bu bilgileri anlamıyorsanız lütfen bir akrabanızdan veya arkadaşınızdan onu çevirmesini isteyin ya da Konseye gelin ve Telefonla Sözlü Çeviri Hizmeti'ni kullanarak bu mektup hakkında Konsey personeli ile görüşün.

## TIN QUAN TRỌNG

Vietnamese

Tin tức trong thư này rất quan trọng. Nếu quý vị không hiểu rõ, xin hỏi những người thân hoặc bạn bè phiên dịch cho quý vị hoặc đến hỏi nhân viên Tòa Hành Chánh, tại đây có phương tiện Thông Ngôn Qua Điện Thoại

**PRELIMINARY**

1. This consent shall lapse if the above development is not physically commenced by the date of expiry shown on the front page of this Consent.
2. Development shall take place in accordance with the following plans and information, except where amended by the conditions of this consent:

**Architectural Plans (all Job No. SVP00117)**

Drawing	Title	Issue	Date	Prepared by
DA.000	Cover Page	F	08/05/2017	Nordan Jago
DA.030	Construction Management Plan	F	08/05/2017	Nordan Jago
DA.040	Lot Consolidation & Demolition Plan	F	08/05/2017	Nordan Jago
DA.100	Basement Carpark	G	21/07/2017	Nordan Jago
DA.101	Level 1 + 1a	G	12/09/2017	Nordan Jago
DA.102	Level 2 + 2a	F	08/05/2017	Nordan Jago
DA.103	Level 3 + 3a	F	08/05/2017	Nordan Jago
DA.104	Level 4 + 4a	F	08/05/2017	Nordan Jago
DA.190	Roof Plan	F	08/05/2017	Nordan Jago
DA.200	Sections	F	08/05/2017	Nordan Jago
DA.300	Elevations	F	08/05/2017	Nordan Jago

**Engineering Plans (all Job No. 170318)**

Drawing	Title	Issue	Date	Prepared by
C01	Notes & Legends	3	11/09/17	Greenview Consulting
C02	Basement 1 Drainage Plan	3	11/09/17	Greenview Consulting
C03	Ground Floor Drainage Plan	3	11/09/17	Greenview Consulting
C04	Site Stormwater Details – Sheet 1	1	11/09/17	Greenview Consulting

Council's OSD No. 2017-178

**Landscape Plans (all Job No. 20170314)**

Drawing	Title	Issue	Date	Prepared by
LDA-000	Cover Sheet & Design Statement	A	11/05/2017	Groundink
LDA-101	Overall Landscape Plan	A	11/05/2017	Groundink
LDA-102	Detailed Landscape Plan – Page 1	A	11/05/2017	Groundink
LDA-103	Detailed Landscape Plan – Page 2	A	11/05/2017	Groundink
LDA-104	Detailed Landscape Plan – Page 3	A	11/05/2017	Groundink
LDA-105	Detailed Landscape Plan – Page 4	A	11/05/2017	Groundink
LDA-201	Landscape Specification & Details	A	11/05/2017	Groundink
LDA-301	Landscape Finishes & Plant Schedule	A	11/05/2017	Groundink

**Documentation**

- Remediation Action Plan (RAP) prepared by Douglas Partners, Project No. 71184.06, Revision 2, dated 25 August 2017;
- Arboricultural Impact Assessment prepared by Bluegum Tree Care & Consultancy, dated April 2017;

- Acoustic Report prepared by Acoustic Logic, Project No. 20170554.1, Reference No. 20170554.1/1007A/R1/MF, Revision 1, dated 10 July 2017;
  - Basix Certificate No. 819937MM dated 19 May 2017;
  - Waste Management Plan prepared by Dickens Solutions, dated 19 May 2017 and Addendum report prepared by Dickens Solutions, dated 17 August 2017;
  - Correspondence prepared by Endeavour Energy, dated 27 June 2017 and all conditions contained therein;
  - Correspondence prepared by Roads & Maritime Services, Ref SYD17/00823, dated 26 June 2017 and all conditions contained therein; and
  - Correspondence prepared by NSW Police, Holroyd LAC, Reference No. D/2017/519605, dated 11 July 2016 and all conditions contained therein.
- a) As amended in red by Council. The above amendments are to be incorporated in the Construction Certificate plans.
3. All building work shall be carried out in accordance with the requirements of the Building Code of Australia. Fully detailed plans including fire safety details shall be submitted with the Construction Certificate application. No work is to commence until such time as a Construction Certificate is obtained for the work/building permitted by this Consent.

**Appointment of Council or a Private Certifier as the Principal Certifying Authority (PCA)**

4. Either Council or a Private Certifier is to be appointed as the Principal Certifying Authority (PCA) for the development in accordance with Section 109E of the Act.

Accordingly, wherever reference is made to the Principal Certifying Authority in this Consent, it refers to Council or the Private Certifier as chosen by you.

**Note:** Once you have chosen either Council or a Private Certifier as the PCA, you cannot change from one to the other, or from one Private Certifier or another, without the approval of Department of Planning & Infrastructure.

5. The applicant shall consult with, as required:
- (a) Sydney Water Corporation Limited
  - (b) Endeavour Energy
  - (c) Natural Gas Company
  - (d) A local telecommunications carrier
- regarding their requirements for the provision of services to the development and the location of existing services that may be affected by proposed works, either on site or on the adjacent public road(s).

6. Building materials, builders sheds, waste bins, site fencing, gates or any material of any description shall not be left or placed on any footway, road or nature strip. Footways and nature strips shall be maintained, including the cutting of vegetation, so as not to become unsightly or a hazard for pedestrians. Offenders will be prosecuted.

### Demolition

7. In the event that demolition is to occur prior to the issue/release of a Construction Certificate, all relevant fees and bonds such as the demolition inspection fee, kerb & gutter and tree protection bonds shall be paid in full to Council prior to demolition commencing (as per the relevant conditions elsewhere in this Development Consent). Furthermore, the applicant/developer is to ensure that all relevant conditions in this Development Consent relating to the protection of the site, adjoining lands and trees are adhered to in full prior to commencement of any demolition works.
8. Permission is granted for the demolition of existing structures on the property, subject to strict compliance with the following:-
  - a) Demolition is to be carried out in accordance with the applicable provisions of Australian Standard AS2601-2001 - *Demolition of Structures*. **Note:** Developers are reminded that WorkCover requires that all plant and equipment used in demolition work must comply with the relevant Australian Standards and manufacturer specifications. The developer is to notify owners and occupiers of premises on either side, opposite and at the rear of the development site 5 working days prior to demolition. Such notification is to be a clearly written on A4 size paper giving the date demolition will commence and is to be placed in the letterbox of every premises (including every residential flat or unit, if any) either side, immediately at the rear of, and directly opposite the demolition site. The demolition must not commence prior to the date stated in the notification.
  - b) 5 working days (i.e., Monday to Friday with the exclusion of Public Holidays) notice in writing is to be given to Council for inspection of the site prior to the commencement of works. Such written notice is to include the date when demolition will commence and details of the name, address, business hours, contact telephone number and licence number of the demolisher. Works are not to commence prior to Council's inspection and works must also not commence prior to the commencement date nominated in the written notice.
  - c) On the first day of demolition, work is not to commence until Council has inspected the site. Should the building to be demolished be found to be wholly or partly clad with asbestos cement, approval to commence demolition will not be given until Council is satisfied that all measures are in place so as to comply with WorkCover's document "Your Guide to Working with Asbestos", a copy of which accompanies this Development Consent and demolition works must at all times comply with its requirements.
  - d) On demolition sites where buildings to be demolished contain asbestos cement, a standard commercially manufactured sign containing the words "DANGER ASBESTOS REMOVAL IN PROGRESS" measuring not less than 400mm x 300mm is to be erected in a prominent visible position on the site to the satisfaction of Council's officers. Advice on the availability of these signs can be obtained by telephoning Council's Customer Service Centre during business hours on 9840 9840. The sign is to be erected prior to demolition work commencing and is to

remain in place until such time as all asbestos cement has been removed from the site to an approved waste facility. This condition is imposed for the purpose of worker and public safety and to ensure compliance with Clause 259(2)(c) of the Occupational Health and Safety Regulation 2001.

- e) Demolition shall not commence until all trees required to be retained/transplanted are protected in accordance with those conditions stipulated under "Prior to Works Commencing" in this Consent.
- f) All previously connected services are to be appropriately disconnected as part of the demolition works. The applicant is obliged to consult with the various service authorities regarding their requirements for the disconnection of services.
- g) Demolition works involving the removal and disposal of asbestos cement must only be undertaken by contractors who hold a current WorkCover "Demolition Licence" **and** a current WorkCover "Class 2 (Restricted) Asbestos Licence".
- h) Demolition is to be completed within 5 days of commencement.
- i) Demolition works are restricted to Monday to Friday between the hours of 7.00am to 6.00pm. No demolition works are to be undertaken on Saturdays, Sundays or Public Holidays.
- j) Protective fencing is to be installed to prevent public access to the site.
- k) All asbestos laden waste, including asbestos cement flat and corrugated sheets must be disposed of at a tipping facility licensed by the Environment Protection Authority (EPA).
- l) Before demolition operations begin, the property shall be connected to the sewer of Sydney Water to which a pedestal pan shall be temporarily connected for the use as the employees' toilet service during demolition operations.
- m) After completion, the applicant shall notify Council within 7 days to assess the site and ensure compliance with AS2601-2001 – *Demolition of Structures*.

**NOTE:** The person responsible for disposing of the above asbestos waste is to telephone the OEH on (02) 9995 5000 or Council's Waste Officer on (02) 9840 9715 to determine the location of a tip licensed to receive asbestos. Within fourteen (14) days of the completion of demolition works, the applicant must lodge with Council, all original weighbridge receipts issued by the receiving tip as evidence of proper disposal.

- n) Within 14 days of completion of demolition, the applicant shall submit to Council:
  - i) An asbestos clearance certificate carried out by a licensed asbestos assessor (normally a NATA accredited occupational hygienist), or a person who has the knowledge and skills to be a licensed assessor, regardless of whether or not they are licensed; and
  - ii) A signed statement verifying that demolition work and the recycling of materials was undertaken in accordance with the Waste Management Plan approved with this consent under Holroyd DCP 2013, Part A, Section 11. **In reviewing such documentation Council will require the provision of original weighbridge receipts for the recycling/disposal of all materials; and**

**Note:** To find a list of NATA accredited facilities visit the NATA website at [www.nata.asn.au](http://www.nata.asn.au) and under 'Facilities and Labs' click on 'Facilities List by

Field', then click on 'Chemical Testing', then click on 'Asbestos' and finally click on 'identification'. A list of laboratories will be produced which you can contact for the purpose of having a clearance certificate issued.

9. Payment of **\$459.20** fee for inspection by Council of the demolition site prior to commencement of any demolition works.

#### **BASIX (Building Sustainability Index)**

10. Under Clause 136D of the Environmental Planning & Assessment Regulation 2000, it is a condition of this Development Consent that all the commitments listed as per Condition 2 in relation to BASIX are fulfilled.

#### **Substations and Fire Hydrant Boosters**

11. No approval is granted or implied for the installation of substations and fire hydrant booster pumps and construction of associated encasing structures i.e. blast walls and radiant heat shields. Separate Development Consent is required.

#### **Cranes on Building Sites**

12. No approval is granted or implied for the installation of any crane on the premises that has the potential to swing beyond the boundaries of the subject site. Separate necessary approvals, including but not limited to Section 138 of the Roads Act and/or Section 68 of the Local Government Act, must be obtained from Council prior to installation of any such cranes.

**NOTE: FEES, BONDS & CONTRIBUTIONS INDICATED IN CONDITIONS OF THIS CONSENT MAY VARY IN ACCORDANCE WITH THOSE ADOPTED BY COUNCIL AT SUBSEQUENT ANNUAL REVIEWS OF ITS "FEES AND CHARGES" AND SUBSEQUENT CHANGES TO THE BUILDING PRICE INDEX. FEES CHARGED WILL BE THOSE CURRENT AT THE TIME OF PAYMENT.**

## **PRIOR TO ISSUE/RELEASE OF CONSTRUCTION CERTIFICATE/PRELIMINARY CONDITIONS FOR DEMOLITION**

**The following conditions must be complied with prior to the issue of a Construction Certificate, or where relevant prior to demolition occurring. In many cases the conditions require certain details to be included with or incorporated in the detailed plans and specifications which accompany the Construction Certificate:-**

### **Amended plans**

13. Amended plans addressing the below requirements shall be submitted to and approved by Council's Manager Engineering and Traffic prior to the issue of a Construction Certificate.

#### On-site Stormwater Detention

- a) Four (4) copies of the amended hydraulic drawings and calculations along with the completed design checklist, signed by an authorised designer shall be submitted to Council for assessing.
- b) The applicant's engineer shall complete Council's 'On Site Detention drawing submission checklist' as an attachment with the revised stormwater plans. Council may refuse the application should details that have been ticked not be provided/addressed on the amended drawing to be submitted. Please note that this is clearly highlighted in Council's OSD checklist. Council's OSD Drawing Submission checklist is available from Council's customer service or the Engineering Services Department.
- c) The Applicants designer is advised that the maximum area permitted to bypass the On-Site Detention system in accordance with the current version of the policy is 15%.
- d) The size of the orifice in the Discharge Control Pit (DCP) is incorrect as the incorrect OSD Catchment Area has been used. The correct area is Upper Parramatta Catchment Trust, with SSR of 470m<sup>3</sup>/Ha and PSD of 80L/sec/Ha.
- e) The On-Site Detention policy requires an aboveground system to be utilised for On-Site Detention storage. In this regard, an aboveground system is now shown within the front setback area of Centenary Road. The 'Tree Protection Plan' submitted by Bluegum Pty Ltd as part of the DA documents shows no existing trees along this front boundary, except for tree #15. The aboveground OSD shall be extended further into the Centenary Road setback area. This procedure will also assist with increasing the area draining into storage. However, the newly shown aboveground OSD infringes on the splay area on the corner of Centenary Road and Alderney Street, referred to in point #2, under "Roadworks and Street Access", below. This must be rectified in the re-submitted plans.
- f) Areas draining to the basement pump-out system to be shown hatched and calculations that determine the pump-out pit & above-floor storage volumes to Councils OSD Policy, Section 7.9, to be provided.
- g) Provide pump calculations, including Head-Discharge charts for the specified pumps; and Pump/System versus head/discharge rating curves, including riser main



specifications including diameter, material & class (Section 7.9 of OSD Policy), and provide in a cross-section diagram the details of float switches & alarm set levels.

- h) Dimensions & levels of the proposed DCP shall be indicated on the Plans so that Council may check the design for conformance with the current OSD Stormwater Policy. Initial calculations by Council indicate only approximately 62% of the required site storage has been provided, because the incorrect Catchment area & parameters have been used, as noted in (4), above. The designer is to refer to Councils On-site detention policy handbook, Appendix B1.
- i) The orifice plate must be noted on the revised Plans to be epoxied to the wall of the Discharge Control Pit (DCP), in addition to bolting.

**NB.** The Applicant is required to attend to these above matters so that the '*Works-as-Executed*' plans (at Audit stage of the OSD system) prove to the PCA that these matters have been corrected.

Amended plans addressing the above requirements shall be submitted to and approved by Council's Manager Engineering and Traffic prior to the issue of a Construction Certificate.

#### Water Sensitive Urban Design (WSUD)

- 14. The development has been identified as requiring water sensitive urban design (WSUD) as the Site has an area greater than 2500m<sup>2</sup>. Therefore, in order to satisfy the drainage requirements for the building, any construction certificate for the building shall include the construction of the WSUD system. In this regard, design and construction details of the WSUD system demonstrating compliance with DCP 2013, Part A, Section 7.5 shall be submitted.

Amended plans addressing the above requirements shall be submitted to and approved by Council's Manager Engineering and Traffic prior to the issue of a Construction Certificate.

#### Roadworks and Street Access

- 15. The Applicant shall show details on the plans of the proposed single driveway in Wyreema Street, ensure it has a maximum width of 6.0m and indicate on the Plans that that "*The proposed crossing shall be in accordance with Council's standard design and specification*".

Amended plans addressing the above requirements shall be submitted to and approved by Council's Manager Engineering and Traffic prior to the issue of a Construction Certificate.

- 16. The Applicant shall arrange a 3.0m x 3.0m splay corner at the intersection of the Centenary Road/Alderney Street and Centenary Road/Wyreema Street boundaries, wherein no structures encroach, either at ground level, above-ground level, or below-ground level. In this regard, the submitted Architectural Plans indicate there is a proposed electrical substation and easement encroaching on the Centenary Road/Alderney Street splay. Additionally, the 'Revision 3' Stormwater Plans, dated 11 September 2017, show part of the above-ground OSD system also occupies this splay corner.

Amended plans addressing the above requirements shall be submitted to and approved by Council's Manager Engineering and Traffic prior to the issue of a Construction Certificate.

17. Amended architectural plans are required prior to the issue of the Construction certificate to the satisfaction of the Principal Certifying Authority indicating the following:
  - a) The provision of 1.8m high privacy walls for the private open spaces that adjoin bedrooms in dwellings 27 and 28, and dwellings 47 and 48.
  - b) The provision of 1.5m high privacy screens (i.e. horizontal timber screens) for the ground level private courtyards that adjoin the ground level common open space area.
  - c) The provision of a an accessible path of travel to all amenities within the ground level common open space area.

#### **Payment of Bonds, Fees and Long Service Levy**

18. The Principal Certifying Authority is to ensure and obtain written proof that all bonds, fees and contributions as required by this consent have been paid to the applicable authority. This includes all Long Service Levy payments to be made to the Long Service Payments Corporation.

#### **Damage Deposit**

19. A cash bond/bank guarantee of **\$5,872.10** must be paid/lodged with Council to cover making good any damage caused to the property of Council, during the course of construction associated with the development. This will be held for 'six (6) months after the completion of works' or six (6) months after the issue of 'Final Occupation Certificate' (whichever occurs last) to remedy any defects that may arise within this time.

**Note:-** The applicant/owner shall be held responsible for and may be required to pay the full reinstatement costs for damage caused to Council's property, unless the applicant/owner notifies Council in writing and provides photographic proof of any existing damage to Council's property. Such notification shall occur prior to works/demolition commencing. However, if in the opinion of Council, during the course of construction existing damage has worsened, Council may require full reinstatement. If damage does occur during the course of construction, prior to reinstating any damage to Council's property, the applicant/owner shall obtain design specifications of all proposed restoration works. Restoration/construction works within the road reserve shall be carried out by a licensed construction contractor at the applicant/owners expense and shall be inspected by Council prior to placement of concrete and/or asphalt.

#### **Consistency with Endorsed Development Consent Plans**

20. The Principal Certifying Authority must ensure that any certified plans forming part of the Construction Certificate, are in accordance with the Development Consent plans.

#### **Landscape Inspection Fee**

21. Payment of a **\$704** fee for the inspection by Council of landscape works and/or trees to be retained at the key stages, where Council is the Principal Certifying Authority.

### **Engineering Fees and Bonds**

22. Payment of a **\$337.90** fee for the design, specifications and inspection by Council of the vehicular crossing/s prior to placement of concrete.
23. Payment of a **\$2,377.80** fee for the design, specifications and inspection by Council of the footpath paving prior to placement of concrete.
24. Payment of a **\$1,115** fee for the inspection by Council of the stormwater drainage, Onsite Stormwater Detention System and Pollution Control Device/s at the key stages, where Council is the Principal Certifying Authority.
25. Payment of a **\$669** fee for the inspection by Council of the stormwater drainage construction in the road reserve at the key stages.
26. The applicant shall lodge with Council a **\$4,500** cash bond or bank guarantee to cover the removal of redundant vehicular crossings and laybacks along the full road frontage and replacement with kerb and gutter. This bond will be held for 'Six (6) months after the completion of works' or issue of a 'Final Occupation Certificate' (whichever occurs last) to remedy and defects that may arise within this time.
27. The applicant shall lodge with Council a **\$17,640** cash bond or bank guarantee for the satisfactory completion of the construction and/or reconstruction of the concrete footpath paving adjacent to the site. This bond will be held for 'Six (6) months after the completion of works' or issue of a 'Final Occupation Certificate' (whichever occurs last) to remedy and defects that may arise within this time.
28. The applicant shall lodge with Council a **\$6,000** cash bond to cover the registration of a Positive Covenant and Restriction as to User over the Onsite Stormwater Detention System and Pollution Control Device/s. This bond is refundable upon the submission of proof of registration of the Restriction on Use and Positive Covenant with the Land and Property Information NSW.

### **Road Works**

29. A Traffic Management Plan shall be lodged with Council for any road and drainage works to be carried out within public road reserves, or where construction activity impacts on traffic flow or pedestrian access, in strict compliance with the requirements of Australian Standard 1742.3 (Traffic Control Devices for Works on Roads). In this regard, the applicant shall pay Council a **\$511.20** fee for the assessment of the Traffic Management Plan by Council, prior to commencing works within the road reserves. A copy of the approved Traffic Management Plan shall be kept on site during the course of construction for reference and compliance.
30. The applicant shall also provide a Construction and Traffic Management Plan, prepared by a suitably qualified consultant and submitted to Council for approval. The following matters must be specifically addressed in the Plan:

- (a) A plan view (min 1:100 scale) of the entire site and frontage roadways indicating:
- Dedicated construction site entrances and exits, controlled by a certified traffic controller, to safely manage pedestrians and construction related vehicles in the frontage roadways;
  - Signage type and location to manage pedestrians in the vicinity;
  - The locations of any proposed Work Zones in the frontage roadways – note: Work Zone fees apply in accordance with Council's Fees and Charges;
  - Locations and type of any hoardings proposed along all street frontages;
  - Area of site sheds and the like;
  - Location of any proposed crane standing areas;
  - A dedicated unloading and loading point within the site for all construction vehicles, plant and deliveries;
  - Material, plant and spoil bin storage areas within the site, where all materials are to be dropped off and collected;
  - The provision of an on-site parking area for employees, tradesperson and construction vehicles as far as possible; and
- (b) A Traffic Control Plan for the site must be prepared for approval by Council incorporating the following: -
- (i) Traffic control devices proposed in the road reserve must in accordance with the RMS publication "Traffic Control Worksite Manual" and designed by a person licensed to do so (minimum RMS 'red card' qualification). The main stages of the development requiring specific construction management measures are to be identified and specific traffic control measures identified for each.
  - (ii) A detailed description and route map of the proposed route for vehicles involved in spoil removal, material delivery and machine floatage must be provided detailing:-
    - a. Light traffic roads and those subject to a load or height limit must be avoided at all times; and
    - b. A copy of this route is to be made available to all contractors, and shall be clearly depicted at a location within the site.
  - (iii) Evidence of RMS concurrence where construction access is provided directly or within 20m of an Arterial Road.
  - (iv) A schedule of site inductions to be held on regular occasions and as determined necessary to ensure all new employees are aware of the construction management obligations. These must specify that construction-related vehicles to comply with the approved requirements;
  - (v) For those construction personnel that drive to the site, the Applicant shall provide on-site parking so that their personnel's vehicles do not impact on the area.

- (c) Council's adopted fee for certification of compliance with this condition shall be payable on lodgement, or in any event, prior to the issue of the relevant approval.
- (d) Any use of Council property shall require appropriate approvals and demonstration of liability insurances prior to such work commencing.
- (e) Failure to provide complete and detailed information may result in delays. It is recommended that your Construction and Traffic Management Plan be lodged with Council as early as possible.
- (f) Dependent on the circumstances of the site, Council may request additional information to that detailed above.
- (g) Subject to an application for the occupation of public roadway or footway (Section 138, Local Govt. Act 1993), and Covered by a \$20M public liability insurance policy, with the policy noting Council as an interested party.

#### **On-site Stormwater Detention**

- 31. The development has been identified as requiring an On-site Stormwater Detention (OSD) system which has formed part of the development consent. Therefore, in order to satisfy the drainage requirements for the building, any construction certificate for the building shall include the construction of the OSD system. In this regard, design and construction details of the OSD system demonstrating compliance with the development consent, OSD plan number 2017-178 and Council's On-site Detention (OSD) policy shall be submitted to the Certifying Authority prior to the issue of a Construction Certificate.

#### **OSD Outlet**

- 32. The Sites stormwater drainage connection into the existing Council side entry pit in Centenary Road shall be in accordance with Councils Works Specification and standard Drawings.

#### **Sight Distance**

- 33. To maintain sight distance to pedestrians, all fencing and landscaping within 2.0m of a driveway shall have a maximum height of 1m and 50% transparent above a height of 0.5m. All solid posts higher than 0.5m (but lower than 1m) shall have a maximum width 350mm and a minimum spacing of 1.2m. Details shall be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

#### **Required Submissions to Certifying Authority**

- 34. A building plan approval must be obtained from Sydney Water Tap In™ to ensure the development will not affect any Sydney Water wastewater and water mains, stormwater drains and/or easement.  
A copy of the building plan approval receipt from Sydney Water Tap in™ must be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

Please refer to the website [www.sydneywater.com.au](http://www.sydneywater.com.au).

35. If the development is likely to disturb or impact upon telecommunications infrastructure, written confirmation from the service provider that they have agreed to the proposed works must be submitted to the Principal Certifying Authority prior to the issue of a Construction Certificate or any works commencing, whichever occurs first.
36. The arrangements and costs associated with any adjustment to telecommunications infrastructure shall be borne in full by the applicant/developer.
37. Retaining walls greater than 1.0m above finished ground level or other approved methods necessary to prevent the movement of excavated or filled ground, together with associated stormwater drainage measures, shall be designed by an appropriately qualified person. Details are to be included with any Construction Certificate application.
38. Structural engineer's details (in duplicate) prepared and certified by a practising qualified structural engineer of all reinforced concrete and structural members shall be submitted to the Principal Certifying Authority.
39. A Construction Management Plan (CMP) prepared by a suitably qualified consultant shall be prepared to address issues such as traffic control, noise, dust, etc. during construction. All measures / works / methods / procedures / control measures / recommendations made within the Construction Management Plan shall be implemented accordingly. Detail is to be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.
40. The development shall comply with the Access to Premises Standards. Detail is to be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.
41. Signs and line marking plans shall be prepared prior to the issue of Construction Certificate and to be in accordance with AS 2890.1-2004, AS 2890.6-2009, AS 2890.2-2002 and the endorsed plans. Detail is to be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.
42. Storage areas for each unit shall be provided at the following rates:-
  - 1 bedroom units - 6m<sup>3</sup>
  - 2 bedroom units - 8m<sup>3</sup>
  - 3 bedroom units - 10m<sup>3</sup>

A minimum of 50% of the storage area shall be provided within the unit.

Detail is to be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

43. A lighting plan shall be provided, detailing lighting along pedestrian access ways, common areas, communal open space areas, car parking entries and all entries. Detail is to be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

44. A screened area for clothes drying, 1.5 metres in height, shall be provided to each balcony within the development, which has an elevation to the public domain. Detail is to be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

#### **External Walls and Cladding Flammability**

45. The external walls of the building including attachments must comply with the relevant requirements of the National Construction Code (NCC). Prior to the issue of a Construction Certificate, the Certifying Authority and Principal Certifying Authority must:
  - (a) Be satisfied that suitable evidence is provided to demonstrate that the products and systems proposed for use or used in the construction of external walls including finishes and claddings such as synthetic or aluminium composite panels comply with the relevant requirements of the NCC; and
  - (b) Ensure that the documentation relied upon in the approval processes include an appropriate level of detail to demonstrate compliance with the NCC as proposed and as built.

#### **Fire Safety Upgrading & Essential Services**

46. The Construction Certificate is to include a schedule specifying all of the essential fire or other safety measures (both current and proposed) that are required for the building or premises to ensure the safety of persons in the building in the event of fire.

#### **Design Verification Statement**

47. In accordance with Environmental Planning and Assessment Regulation 2000 and State Environmental Planning Policy (SEPP) 65 "Design Quality of Residential Apartment Development", the subject development must be undertaken or directed by a "qualified designer" (i.e., a "registered architect" under the Architects Act). In this regard, a design verification statement shall be submitted to the Principal Certifying Authority (PCA). The PCA shall ensure that the statement prepared by the qualified designer provides the following:-
    - (i) A valid and current chartered architect's certificate number (as issued by the Board of Architects of NSW);
    - (ii) That the qualified designer has designed or directed the design of the subject development;
    - (iii) That the plans and specifications lodged with the Construction Certificate achieve or improve the design quality of the development for which the subject development consent was granted, having regard to the design principles set out in Part 2 SEPP 65.
- N.B.** The design verification statement must provide an explanation of the design in terms of the design quality principles set out in Part 2 of SEPP 65.

#### **Residential Flat Development Residential Waste Storage Area**

48. The waste storage area shall be roofed, screened from public view and provided with:-
- Openings, 5% of the floor area and recessed into the walls, positioned to provide cross floor ventilation OR mechanical ventilation to Council's satisfaction;
  - An adequate water supply provided by a hose cock and hose (hot water for commercial premises)
  - The floor shall be made of an impervious surface, drained to sewer in accordance with Sydney Water requirements and include a dry arrestor pit with a removable basket.

Plans and specifications for the storage room shall be submitted with the application for the Construction Certificate.

### **Car Wash Bay**

49. A vehicle wash bay shall be provided for residents of the development. Collection, reuse and ultimate disposal of water used in the vehicle wash bay shall be in accordance with Sydney Water's requirements. The car wash bay shall be designed so that the following requirements are met:-

Have an adequate parking and washing floor space.

Provide a water supply.

Minimise water use with appropriate devices (e.g., such as a gun-type nozzle which closes when released and a timer operative valve, collection and use of rainwater).

Have a water supply cut out system/fail-safe mechanisms provided to ensure that mechanical failure; drainage blockage or lack of maintenance cannot result in wastewater surcharge into the stormwater system.

Be designed to ensure that over spray, drift of water or detergent does not cause a nuisance to persons, vehicles, residences, other buildings, neighbouring properties or the environment.

Be located so that washing can occur with minimal disturbance to other residents,

details to be submitted to the Principal Certifying Authority

### **Salinity**

50. The site has been identified as having a potential salinity hazard. To prevent moisture/salinity from entering the built structure, appropriate construction methods are to be incorporated for all dwellings/buildings.

Details of proposed methods of construction are to be detailed in the engineering plans and submitted to the PCA.

**Note:** Further information for building in a saline environment is available in the following documents:

- "Building in Saline Environment" prepared by DIPNR 2003.
- Water Sensitive Urban Design in the Sydney Regions "Practice Note 12: Urban Salinity"
- Wagga Wagga City Council's "Urban Salinity Action" October 1999
- "Guide to Residential Slabs and Footings in Saline Environments" prepared by Cement Concrete and Aggregates Australia, May 2005

### **Acoustic Measures**



51. Plans and/or specifications indicating how compliance with the recommendations of the Acoustic Report prepared by Acoustic Logic, Project No. 20170554.1, Reference No. 20170554.1/1007A/R1/MF, Revision 1, dated 10 July 2017, will be achieved, are to be submitted to the Principal Certifying Authority.

#### **Remediation Works**

52. Prior to issue of the Construction Certificate, a quantitative human health risk assessment (HHRA) as referenced in the Remediation Action Plan (RAP) prepared by Douglas Partners, Project No. 71184.06, Revision 2, dated 25 August 2017, shall be undertaken to further inform the detailed design of vapour intrusion mitigation measures. Should the HHRA indicate that a vapour barrier is not required, then this modification to the current design, which assumes a barrier will be included, must be approved by the relevant consent authority (i.e. Cumberland Council) prior to construction.

## **PRIOR TO WORKS / DEMOLITION COMMENCING**

**The following conditions are to be complied with prior to any works / demolition commencing on the site:**

### **Appointment of Principal Certifying Authority and Notification of Commencement of Work**

53. The person having the benefit of the development consent, not the principal contractor (builder), must: -
- a) Appoint a Principal Certifying Authority in accordance with Section 81A(2)(b) of the Act.
  - b) Have the Principal Certifying Authority complete the 'Accredited Certifier Details' on the approved form provided by Council for this purpose, an original of which is attached to this Development Consent.
  - c) Notify Council of the appointment of the Principal Certifying Authority and of the intention to commence building work, such notification is to be given to Council at least two (2) working days prior to the proposed commencement date, and be on the approved form provided by Council for this purpose, an original of which is attached to this Development Consent.

*If nominated, Council can provide this service for you and act as the Principal Certifying Authority.*

**N.B.** The Principal Certifying Authority must also notify the person having the benefit of the Development Consent of any mandatory critical stage inspections and other inspections that are to be carried out in respect of the building work such notification must comply with Clause 103A of the Regulations.

### **Notification of Principal Contractor (Builder)/Owner-Builder**

54. The person having the benefit of the Development Consent must:-
- (a) Notify the Principal Certifying Authority that the person will carry out the work as an owner-builder, if that is the case;
- OR
- (b) Appoint a Principal Contractor for the building work (who must be the holder of a contractor licence if any residential building work is involved), and notify the Principal Contractor of any mandatory critical stage inspections and other inspections that are to be carried out in respect of the building work.
  - (c) Notify the Principal Certifying Authority of any such appointment.

Where Council is the Principal Certifying Authority, such notification is to be on the approved form provided by Council for this purpose, an original of which is attached to this Development Consent.

#### **Required Submissions to Council or the Principal Certifying Authority**

55. To facilitate a complete assessment and enable the Certifying Authority to check compliance on site, truss validation and design, details certified by a qualified practising structural engineer shall be submitted to Council or the Principal Certifying Authority for examination and approval. Details shall include:
- a) job address and builder's name
  - b) design wind velocity
  - c) terrain category
  - d) truss spacing
  - e) roof pitch
  - f) material of roof
  - g) roof batten/purlin spacing
  - h) material of ceiling
  - i) job number

#### **Photographic Record of Council Property – Damage Deposit**

56. The applicant shall submit to Council, for the purposes of the damage deposit bond lodged to cover making good any damage caused to the property of Council, a full and satisfactory photographic record of the condition of Council's property (i.e., road pavement, kerb and guttering, footway, stormwater drainage, etc.) adjacent to the subject site. The purpose of the photographic record is to establish any pre-existing damage to Council's property to ensure that you are not liable for any re-instatement works associated with that damage. However, if in the opinion of Council, the existing damage has worsened or any new damage is caused during the course of construction, the Council may require either part or full re-instatement.

**Note:** Failure to provide a full and satisfactory photographic record described above, is likely to render the applicant liable to rectify all damages unless satisfactory proof can be provided that the damage was pre-existing.

#### **Notification to Relevant Public Authority**

57. The applicant shall ensure that relevant public utility authorities are made aware of the salinity problems that have been identified, such that their services are designed to take into consideration the effects the saline soils may have on their installations.

#### **Fencing of Sites**

58. Fencing of sites is required to prevent public access when the site is unoccupied and building works are not in progress. In this regard the MINIMUM acceptable standard of fencing to the site is properly constructed chain wire fencing 1.8m high, clad internally with Hessian or Geotextile fabric.

All openings are to be provided with gates, such gates are not at any time to swing out from the site or obstruct the footpath or roadway.

### **Signs to be Erected on Sites**

59. A sign must be erected in a prominent position on any site on which building work, subdivision work or demolition work is being carried out:
- (a) showing the name, address and telephone number of the Principal Certifying Authority for the work, and
  - (b) showing the name of the principal contractor (if any) for any building work and a telephone number on which that person may be contacted **outside working hours and at any time for business purposes**, and
  - (c) stating that unauthorised entry to the work site is prohibited.

The sign must be rigid and durable and be read easily by anyone in any public road or other public place adjacent to the site.

Any such sign is to be maintained while the building work, subdivision work or demolition work is being carried out, but must be removed when the work has been completed.

This clause does not apply in relation to building work, subdivision work or demolition work that is carried out inside an existing building that does not affect the external walls of the building.

**Note:** Principal Certifying Authorities and Principal Contractors must also ensure that signs required by this clause are erected and maintained (clause 227A of the Regulations currently imposes a maximum penalty of \$1,100).

### **Prohibited Signage**

60. Advertising, Real Estate Agents, Architects, Designers, site suppliers and any other signage not mentioned in the conditions, is not to be placed or displayed on the site, such that the signage is visible from any public place. Offenders may be prosecuted.

### **Protection of Public Places**

61. A hoarding or fence must be erected between the work site and any public place, if the work involved in the erection or demolition of the building; is likely to cause pedestrian or vehicular traffic in a public place to be obstructed or rendered inconvenient, or involves the enclosure of a public place.

If necessary, an awning is to be erected, sufficient to prevent any substance from, or in connection with, the work falling into the public place.

The work site must be kept lit between sunset and sunrise if it is likely to be hazardous to persons in the public place.

### **Site Control Measures**

62. Suitable erosion and sediment control measures shall be provided at all vehicular entry/exit points and all other measures required with and/or shown on plans accompanying the Construction Certificate, to control soil erosion and sedimentation, are to be in place prior to the commencement of construction works. Such controls are to be provided in accordance with Council's "Erosion & Sediment Control Policy."

**Note:** On-the-spot fines may be issued by council where measures are absent or inadequate.

### **Tree Protection**

63. The tree/s identified on the endorsed plans as being retained/transplanted shall be protected prior to and throughout the demolition/construction process in accordance with the Arboricultural Impact Assessment prepared by Bluegum Tree Care & Consultancy, dated April 2017, the attached Guidelines for the Protection of Trees On and Adjacent To Demolition/Building sites, and relevant conditions of this Consent. All trees not authorised to be removed by this Consent must be retained. Prior to any work commencing, certification of the installation and inspection of the required tree protection works is to be provided to the Principal Certifying Authority by a suitably qualified person or the Arborist (as appropriate) engaged to ensure the proper protection and management of the tree/s required to be retained/transplanted. A copy of the Certificate is to be issued to Council within seven (7) days of the inspection and prior to any works commencing. Additionally, trees identified for removal are to be retained until immediately prior to works commencing, to assist with soil management and erosion control.

### **Footpaving, Kerbing and Guttering**

64. Protection must be provided for Council footpaving, kerbing and guttering. Wooden mats must also be provided at all entrances where the site fronts paved footpaths.
65. Where works involves the alteration to the road or street, the finished street levels shall not be assumed. The owner or builder must make application to Council's Engineering Services Department for street levels.

### **Support for Neighbouring Buildings**

66. If an excavation associated with the erection or demolition of a building extends below the level of the base of the footings of a building on an adjoining allotment of land (including a public road and any other public place), the person causing the excavation to be made:-
- a) must preserve and protect the building from damage, and
  - b) if necessary, must underpin and support the building in an approved manner, and
  - c) must, at least seven (7) days before excavating below the level of the base of the footings of a building on an adjoining allotment of land, give notice of intention to do so to the owner of the adjoining allotment of land and furnish particulars to the owner of the building being erected or demolished.

The owner of the adjoining allotment of land is not liable for any part of the cost of work carried out for the purposes of this clause, whether carried out on the allotment of land

being excavated or on the adjoining allotment of land. (In this clause, *allotment of land* includes a public road and any other public place).

67. A dilapidation report of adjoining properties/allotments and details of the proposed excavation works in excess of 2m or within the zone of influence of neighbouring building foundations and required underpinning and supportive measures shall be submitted to the Principal Certifying Authority. Any required underpinning and supportive measures shall be designed by a practising structural engineer and details shall be submitted to the Principal Certifying Authority for approval prior to construction works commencing.

### **Toilet Facilities**

68. Toilet facilities are to be provided, at or in the vicinity of the work site on which work involved in the erection or demolition of a building is being carried out, at the rate of one toilet for every 20 persons or part of 20 persons employed at the site.

Each toilet provided:

- a) Must be a standard flushing toilet, and
- b) Must be connected:
  - i) To a public sewer,
  - ii) If connection to a public sewer is not practicable, to an accredited sewage management facility approved by the Council, or
  - iii) If connection to a public sewer or an accredited sewage management facility is not practicable, to some other sewage management facility approved by the Council.
  - iv) The position of the toilet on the site shall be determined by Council's Building Surveyor and/or Sydney Water.

### **Residential Building Work - Insurance**

69. Residential building work within the meaning of the *Home Building Act 1989* must not be carried out unless the Principal Certifying Authority for the development to which the work relates (where not Council) has given Council written notice of the following information:-

- (a) in the case of work for which a Principal Contractor is required to be appointed:
  - (i) the name and licence number of the Principal Contractor, and
  - (ii) the name of the insurer by which the work is insured under Part 6 of that Act,
- (b) in the case of work to be done by an owner-builder:
  - (i) the name of the owner-builder, and
  - (ii) if the owner-builder is required to hold an owner-builder permit under that Act, the number of the owner-builder permit.

If arrangements for doing the residential building work are changed while the work is in progress so that the information notified under this condition becomes out of date, further work must not be carried out unless the Principal Certifying Authority for the development

to which the work relates (where not Council) has given Council written notice of the updated information.

The notification is to be on the approved form provided by Council for this purpose, an original of which is attached to this Development Consent.

### **Roadworks**

70. The applicant is to submit to Council an application for a road opening permit when the drainage connection into Council's system is within the road reserve. In this regard the applicant shall pay Council a **\$168.60** fee prior to the commencement of works. Additional road opening permits and fees may be necessary where there are connections to public utility services (e.g. telephone, electricity, sewer, water or gas) required within the road reserve.
71. The applicant to arrange with the relevant public utility authority the alteration or removal of any affected services in connection with the development. Any such work being carried out at the applicant's cost.
72. Any required adjustment to utility services, trees, signs and other street furniture requires approval of the appropriate authority and shall be undertaken by the applicant at no cost to Council.
73. Any works requiring closure of any road or footway closure will require submission of a Council's Temporary Road Closure application form and payment of fees.

### **Works Within Council's Reserve**

74. All works within the Council reserve shall be completed within three (3) weeks of the date of commencement. Council's Development Engineer shall be advised prior to the commencement of works.
75. Submission to Council of a Certificate of Currency of the contractor's Workers' Compensation Policy prior to the commencement of works.
76. All construction works shall be in accordance with the WorkCover safety requirements. Submission of insurance documentation demonstrating a minimum Public Liability cover of \$20,000,000 is to be submitted prior to commencement of works. Council shall be named on the Certificate of Currency as an interested party.

### **Property/Street Number**

77. Council is the authority responsible for the allocation of all official property addresses. For ease of identification of your new development, it is important that the allocated property numbers are used and displayed prominently. It is requested that you contact Council as soon as possible before construction is commenced to discuss proposed addressing for your development.

Please email your site plan to [hcc@cumberland.nsw.gov.au](mailto:hcc@cumberland.nsw.gov.au) or contact Council's Rates Section by Phone on 9840 9767.

Council's 'Allocation of Property Numbers' policy is available on Council's website [www.cumberland.nsw.gov.au](http://www.cumberland.nsw.gov.au).

DRAFT



## DURING DEMOLITION / CONSTRUCTION

The following conditions are applicable during demolition / construction:-

### Endorsed Plans & Specifications

78. A copy of the endorsed stamped plans and specifications, together with a copy of the Development Consent, Construction Certificate and approved Traffic Management Plan are to be retained on site at all times.

### Hours of Work & Display of Council Supplied Sign

79. For the purpose of preserving the amenity of neighbouring occupations building work including the delivery of materials to and from the site is to be restricted to the hours of 7.00am to 6.00pm Mondays to Fridays and 8.00am to 4.00pm Saturdays. Work on the site on Sundays and Public Holidays is prohibited. **Note: Demolition work is not permitted on weekends or Public Holidays - refer to specific demolition condition for approved hours.**

The yellow "Hours of Building Work" sign (supplied by Council with the approval), is to be displayed in a prominent position at the front of the site for the duration of the work.

### Site Control

80. All soil erosion measures required in accordance with the approved sediment and erosion control plan and any other relevant conditions of this Consent are to be put in place prior to commencement of construction works and are to be maintained during the entire construction period until disturbed areas are restored by turfing, paving or revegetation. This includes the provision of turf laid on the nature strip adjacent to the kerb.
81. Builder's refuse disposal and storage facilities are to be provided on the development site for the duration of construction works and all rubbish shall be removed from the site upon completion of the project.
82. Stockpiles of sand, soil and other material shall be stored clear of any drainage line or easement, tree protection zone, water bodies, footpath, kerb or road surface and shall have erosion and sediment control measures in place to prevent the movement of such materials onto the aforementioned areas and adjoining land.

### Asbestos Cement Sheeting

83.
  - i) All asbestos cement sheeting must be removed by contractors with an appropriate licence issued by WorkCover and who are familiar with asbestos removal prior to the commencement of:-
    - (a) Recladding or brick veneering of any building where the existing walls to be covered are currently clad with asbestos cement;

OR

- (b) Construction work where new work abuts existing asbestos cement sheeting and/or where parts of the existing building clad with asbestos cement sheeting are to be altered or demolished.

Removal must be carried out strictly in accordance with WorkCover's "Your Guide to Working with Asbestos" (copy attached).

- ii) All asbestos laden waste, including asbestos cement flat and corrugated sheets must be disposed of at a tipping facility licensed by the Environment Protection Authority (EPA).

**Note:** The person responsible for disposing of the above asbestos waste is to telephone the EPA on (02) 9995 5000 or Council's Waste Officer on (02) 9840 9715 to determine the location of a tip licensed to receive asbestos. **Upon completion of tipping operations the applicant shall lodge with the Council, all receipts issued by the receiving tip as evidence of proper disposal.**

- iii) Within fourteen (14) days of completion of renovation or recladding or brick veneering works where asbestos cement sheeting was removed, the applicant shall submit to Council an asbestos clearance certificate prepared by a NATA accredited occupational hygienist.

**Note:** To find a list of NATA accredited facilities visit the NATA website at [www.nata.asn.au](http://www.nata.asn.au) and under 'Find a Facility or Lab' type in 'asbestos identification' in 'keywords' then click on 'chemical testing' in NSW then click on the search button. A list of laboratories will be produced which you can contact for the purpose of having a clearance certificate issued.

#### **Waste Management Plan**

- 84. The approved Waste Management Plan must be implemented and complied with during all stages of works on site.
- 85. Within seven (7) days of completion of construction/building works, the applicant shall submit a signed statement to Council or the Principal Certifying Authority verifying that demolition work and recycling of materials was undertaken in compliance with the Waste Management Plan. The Principal Certifying Authority shall submit a copy of the statement to Council.

***In reviewing such documentation Council will require the provision of actual weighbridge receipts for the recycling/disposal of all materials.***

#### **Compliance with Critical Stage Inspections and other Inspections nominated by the Principal Certifying Authority**

- 86. Section 109E(3)(d) of the Act requires certain specific inspections (prescribed by clause 162A of the Regulations) and known as 'Critical Stage Inspections' to be carried out for building work. Prior to permitting commencement of the work your Principal Certifying

Authority is required to give notice of these inspections pursuant to clause 103A of the Regulations.

**N.B.** An Occupation Certificate cannot be issued and the building may not be able to be used or occupied where any mandatory critical stage inspections or other inspections required by the Principal Certifying Authority are not carried out.

Where Council is nominated as Principal Certifying Authority, notification of all inspections required is provided with the Construction Certificate approval.

### **Construction**

87. The building and external walls are not to proceed past ground floor formwork/reinforcing steel level until such time as the Principal Certifying Authority has been supplied with a check survey report prepared by a registered surveyor certifying that the floor levels and external wall locations to be constructed, comply with the approved plans, finished floor levels (FFL)s and setbacks to boundary/ies. **The slab shall not be poured, nor works continue, until the Principal Certifying Authority has advised the builder/developer that the floor level and external wall setback details shown on the submitted survey are satisfactory.**

In the event that Council is not the Principal Certifying Authority, a copy of the survey shall be provided to Council within three (3) working days.

On placement of the concrete, works again shall not continue until the Principal Certifying Authority has issued a Certificate stating that the Condition of approval has been complied with and that the slab has been poured at the approved levels.

### **Salinity**

88. The building and external walls are not to proceed past ground floor formwork/reinforcing steel level until such time as the Principal Certifying Authority has confirmed that all required construction measures addressing salinity, as required by this Consent and its accompanying Construction Certificate have been carried out.

### **Landscaping/Site Works**

89. All turfed areas shall be finished level with adjoining surfaces and also fall evenly to approved points of drainage discharge.
90. New 1.8m high lapped and capped timber paling or colorbond fences (colour to be sympathetic with the development) determined in consultation with adjoining property owner(s), shall be erected along and within all side and rear boundaries and between courtyards at full cost to the developer. In situations where the boundary fence is proposed on top of a retaining wall, the height of the fence shall not exceed a maximum of 2.4m as measured from the lower adjacent ground level. A Statutory Declaration or other documentary evidence of such consultation is to be submitted to the Principal Certifying Authority

91. The side fences within the front building line are to be the same design as the front fence.
92. A single master T.V. antenna is to be installed to service each building and provision made for connection to each dwelling within that building.

#### **Tree Protection**

93. The tree/s identified on the endorsed plans as being retained/transplanted shall be protected against damage throughout the demolition/construction process in accordance with the Arboricultural Impact Assessment prepared by Bluegum Tree Care & Consultancy, dated April 2017, the attached Guidelines for the Protection of Trees On and Adjacent to Demolition/Building Sites and relevant conditions of this Consent.
94. The applicant shall accept all responsibility for the accuracy of the information provided to Council for assessment. If any tree/s are not shown on the endorsed plan or are required to be retained/transplanted and protected but are threatened by demolition/construction work through unforeseen construction requirements or plan inaccuracy, all site and building works so affected are to cease until the matter is resolved to the satisfaction of Council. Council's Environmental and Planning Services Department is to be notified immediately upon such a problem being encountered.

#### **Works within Council's Reserve**

95. All works within the Council reserve shall be suitably fenced to prevent public access to the work site during construction of the stormwater drainage.

#### **Inspection of On Site Detention Works**

96. The stormwater drainage works are to be inspected during construction, by the Council or by a suitably qualified Civil Engineer. Documentary evidence of compliance with Council's specifications shall be obtained prior to proceeding to the subsequent stages of construction, encompassing not less than the following key stages:
  - (a) Initial inspection to discuss concept and site conditions/constraints prior to commencement of construction of the detention basin/tank.
  - (b) Prior to landscaping of detention basin or pouring of the roof of the detention tank.
  - (c) After completion of storage but prior to installation of fittings (e.g. orifice plates, screens, flap valves etc.)
  - (d) Final Inspection

Council's standard inspection fee will apply to each of the above set inspection key stages. Additional inspection fees will apply for additional inspections required to be undertaken by Council.

### **Inspection of Pollution Control Device/s**

97. The stormwater drainage and/or pollution control devices shall be inspected during construction, by the Council or by a suitably qualified Civil Engineer. Documentary evidence of compliance with Council's specifications shall be obtained prior to proceeding to the subsequent stages of construction, encompassing not less than the following key stages:

- (a) Initial inspection to discuss concept and site conditions/constraints prior to commencement of the construction of the pollution control device/s.
- (b) After completion of storage but prior to installation of fittings (eg. screens, etc.)
- (c) Final Inspection.

Council's standard inspection fee will apply to each of the above set inspection key stages. Additional inspection fees will apply for additional inspections required to be undertaken by Council.

### **Road Works and Footpaving**

98. Pedestrian access, including disabled and pram access, is to be maintained as per Australian Standard AS1742.3 "Part 3 – Traffic Control Devices for Works on Roads".
99. All advisory and regulatory sign posting (for example parking restriction signage, pedestrian crossing signs, warning signs) are to remain in place during construction.

### **Underground Cabling**

100. All communications cabling shall be installed underground as per relevant authority requirements (including broadband and Category 5).

### **Underground Power Connection**

101. Power connection to the site is to be underground. No intermediate power pole is permitted even where electricity reticulation cannot be obtained directly from the street.

### **Alarms**

102. The developer/builder shall not install any audible intruder alarms within the units. If the building is to be provided with a burglar alarm system, this shall incorporate back to base monitoring such that residents can connect thereto from each individual unit.
103. With regard to the basement level pump out system, a suitable audible alarm with flashing light system shall be positioned at the first floor level of each common property stairwell within the building and a flashing light only shall be positioned at each common property entrance to the car parking area to provide a flood warning in the case of pump failure. The alarm system shall be to the satisfaction of Council's Engineer.

### **Basement Parking**

104. A convex mirror is to be provided so that drivers can see up the driveway from within the basement.
105. An intercom device is to be located:
  - i) on the driver's side wall at the top of the driveway to the basement carpark, so that visitors can access the visitor car parking spaces; and
  - ii) within the basement foyer so that disabled persons can contact any unit if the lift is not working.
106. The entry point shall be provided with a suitable communication system to allow the security gate to be opened remotely by the occupants of the building. The width of the access driveway / ramp adjacent to the control device/s shall not restrict access for residents / visitors and shall be in accordance with the Australian Standards.

### **Rainwater Tank**

107. The design of the rainwater tank(s) should allow a horizontal clearance of at least 450mm for pedestrian movement. This tank must not exceed 2.4 metres in height above ground level, including any stand for the tank.

### **Vehicle Cleansing**

108. Concrete trucks and trucks used for the transportation of building materials shall not traffic soil, cement or similar materials onto the road. Hosing down of vehicle tyres shall be conducted in a suitable off-street area where wash water is prevented from entering the stormwater system or adjoining property.

### **Importation of Fill**

109. All imported fill shall be validated in accordance with Council's Contaminated Land Policy to ensure that it is suitable for the proposed land use from a contamination perspective.

### **Additional Information during Demolition / Construction**

110. Any new information which comes to light during demolition / construction works which has the potential to alter previous conclusions about site contamination, shall be notified to Council immediately.

### **Driveways**

111. All new driveways shall be located at least 1.0 metre away from the side boundaries with the area between the driveway and the boundary suitably landscaped.

### **Acoustic Measures**

112. The recommendations provided within the Acoustic Report prepared by Acoustic Logic, Project No. 20170554.1, Reference No. 20170554.1/1007A/R1/MF, Revision 1, dated 10 July 2017, shall be implemented.

### **Remediation Works**

113. The remediation of the subject premises known as No. 11-13 Centenary Road, Merrylands shall be undertaken in accordance with the Remediation Action Plan (RAP) prepared by Douglas Partners, Project No. 71184.06, Revision 2, dated 25 August 2017.
114. During the remediation & construction phase the applicant and all contractors are required to adhere to the General Environmental Management Plan as referenced in the Remediation Action Plan (RAP) prepared by Douglas Partners, Project No. 71184.06, Revision 2, dated 25 August 2017.
115. At the completion of the remediation works program, a validation assessment report shall be prepared by the Environmental Consultant at the completion of the project with reference to OEH (2011) *Contaminated Sites: Guidelines for Consultants Reporting on Contaminated Sites*. The report shall be submitted to Council at the completion of the remediation works programme. The objective is for the validation report to confirm that the site has been remediated to a suitable standard for the proposed redevelopment and occupation and that no related adverse human health and environmental effects have occurred as a result of the works. The validation report shall also include a summary of the information from previous investigations.

## **PRIOR TO ISSUE OF FINAL OCCUPATION CERTIFICATE**

**The following conditions are to be complied with prior to the issue of a final occupation certificate:-**

### **Certificates/Documentary Evidence**

116. A final clearance is to be obtained from Endeavour Energy if such clearance has not previously been issued.
117. A Section 73 Certificate (Sydney Water) must be submitted to the Principal Certifying Authority prior to occupation of the development.
118. A Structural Engineer's certificate from the supervising structural engineer responsible for the design shall be submitted to the Principal Certifying Authority and shall state that all foundation works/reinforced concrete/structural members have been carried out/erected in accordance with the Engineer's requirements and the relevant SAA Codes.

**Note:** Any such certificate is to set forth the extent to which the engineer has relied on relevant specifications, rules, codes of practice or publications in respect of the construction.

119. An Accredited Certifier shall submit to the Principal Certifying Authority a signed checklist as per Appendix A of AS4299-1995 confirming that sixteen (16) units (Units 4, 6, 9, 12, 15, 18, 21, 24, 31, 36, 41, 52, 58, 64, 68 & 69), have achieved the desired level of adaptability (i.e. "Adaptable House Class A or B").

### **Landscaping/Tree Protection**

120. Certification is to be provided to the Principal Certifying Authority (PCA), from the designer of the landscape proposal, that all tree planting/landscape works have been carried out in accordance with the endorsed plan. If Council is the PCA, the certification is to be submitted to Council prior to or at the final landscape inspection. If Council is **not** the PCA, a copy of the certification is to be provided to Council with the Occupation Certificate.
121. Certification is to be provided to the Principal Certifying Authority (PCA) from a suitably qualified and licensed contractor that the specified planter boxes have been waterproofed and drained in accordance with the requirements of the current relevant Australian Standards, any relevant authority regulations and current best work practices. If Council is not the PCA a copy of the certification is to be provided to Council with the Occupation Certificate.
122. Certification is to be provided to the Principal Certifying Authority from a suitably qualified and licensed contractor that the specified fully automated commercial grade irrigation system has been designed and installed to all common planted areas in accordance with the requirements of the current relevant Australian Standards, any relevant authority regulations and current best work practices. If Council is not the PCA, a copy of the certification is to be provided to Council with the Occupation Certificate.
123. Boundary and courtyard fences must be erected and finished in a professional manner.



### **Parking/Driveway**

124. All dwellings/units and associated car parking spaces shall be numbered on site in accordance with numbering on the endorsed plans. These numbers shall also be consistent with any strata plan for the completed development.
125. All resident, visitor and commercial parking spaces shall be sign-posted and line-marked in accordance with Australian Standards 2890.1.2004 and 2890.6.2009.
126. The entry / exit driveway shall be indicated with appropriate signage and line-marking to avoid conflict at the driveway.
127. The driveway shall be sign-posted indicating availability of visitor off-street parking. Spaces reserved for this purpose shall be marked as such.
128. Directional signage shall be designed and provided on site to direct visitors to the residential and commercial visitor parking spaces and the commercial units. The signage shall be positioned in a location which will not impact on vehicle movements or damage the signage, visible to drivers and to be endorsed by a suitably qualified Traffic Practitioner.
129. Directional arrows for internal circulation shall be proximately displayed on the pavement approaches to, and within, the car park area.
130. The vehicle crossing between the street and front boundary shall be constructed of plain concrete with no colour or stencilling.
131. All disabled parking spaces shall be provided with a shared area, bollards and slip resistant surface in accordance with Australian Standard 2890.6.2009.
132. Wheel stops shall be provided at appropriate parking locations and in accordance with AS 2890.1-2004.

### **External Walls and Cladding Flammability**

133. The external walls of the building including attachments must comply with the relevant requirements of the National Construction Code (NCC). Prior to the issue of an Occupation Certificate, the Certifying Authority and Principal Certifying Authority must:
  - (a) Be satisfied that suitable evidence is provided to demonstrate that the products and systems proposed for use or used in the construction of external walls including finishes and claddings such as synthetic or aluminium composite panels comply with the relevant requirements of the NCC; and
  - (b) Ensure that the documentation relied upon in the approval processes include an appropriate level of detail to demonstrate compliance with the NCC as proposed and as built.

## Fire Safety

134. Submission to Council of a Final Fire Safety Certificate pursuant to Clause 170 of the Environmental Planning and Assessment Regulation 2000 in respect of each essential fire or other safety measure listed on the Fire Safety Schedule attached to the Construction Certificate.

### **NOTE:**

1. Such Certificate shall state, pursuant to Clause 80E in relation to each essential fire safety measure mentioned in the certificate:–
  - that the service has been assessed by a properly qualified person (chosen by the owner of the building); and
  - that the service was found to be, when assessed, capable of performing to at least the standard required by the current fire safety schedule for the building for which the certificate is issued.
2. The person who carries out the assessment must inspect and verify the performance of each fire safety measure being assessed, and must test the operation of each new item of equipment installed in the building premises that is included in the current fire safety schedules for the building.
3. The assessment must have been carried out within the three (3) months prior to the date on which the final fire safety certificate is issued.

## On-site Stormwater Detention, Certification and Covenant

135. A copy of the as approved stormwater drainage, On Site Detention plan and Pollution Control Device/s, showing work as executed details shall be submitted to Council. The work as executed plan shall be in accordance with Council's standards and specifications for stormwater drainage and on-site stormwater detention.
136. The Applicant shall furnish to Council 'Works-as-Executed' OSD calculations sheets.
137. A certificate of compliance in accordance with Council's standards and specifications for stormwater drainage, On Site Detention and Pollution Control Device/s shall be issued to the Principal Certifying Authority by a suitably qualified Civil Engineer.
138. A certificate of compliance for the pump out drainage system of the basement level shall be issued to the Principal Certifying Authority by the pump installers stating that the pump out system has been installed to operate in accordance with the Council requirements and approved drawings.
139. Documents giving effect to the creation of a Positive Covenant and Restriction on Use over the as constructed On Site Detention System and Pollution Control Device/s shall be submitted to the authority benefited for approval prior to lodging with the Land and Property Information NSW. The wording of the terms of the Positive Covenant and Restriction On Use shall be in accordance with Council's standards and specifications for stormwater drainage and on-site stormwater detention. The documents shall be approved by the benefiting authority for registration with Land and Property Information NSW.

**Note:** Prior to release of the documents creating the Restriction on Use and Positive Covenant, the benefiting authority shall be satisfied that the as-constructed On Site

Detention System and Pollution Control Device/s is in accordance with the approved drawings and Council requirements.

The Positive Covenant and Restriction on Use documents shall be registered with the Land and Property Information NSW within six (6) months from the date of release by the benefiting authority.

140. A maintenance schedule for the stormwater and On-Site Detention system including a sketch plan of the components forming the sites stormwater and On-Site Detention system shall be submitted. The maintenance schedule shall be prepared by a qualified hydraulic engineer and shall be in accordance with the Upper Parramatta River Catchment Trust requirements.
141. An On-site Storm water Detention plate shall be installed within the detention basin or tank. The plate shall be located in or near the Discharge Control Unit to alert future owners of their obligations to maintain the facility and its restrictions. The wording and plate shall be in accordance with Council's standard requirements. This plate is required to be displayed prominently among the other required signage, as specified in the current Upper Parramatta River Catchment Trust handbook & on the Approved Plans.

#### **Road Works**

142. Any works requiring levels within the road reserve will require the submission of Council's Vehicle Crossing application form.
143. A full width **heavy** duty vehicular crossing shall be provided opposite the vehicular entrance to the site, with a maximum width of 6 metres and a minimum width of 5 metres at the boundary line. These works shall be carried out by a licensed construction contractor at the applicant's expense and shall be in accordance with Council's issued drawings and level sheets.
144. The Applicant shall arrange the removal of any damaged kerb and/or gutter, and repairs of such concrete works along all areas of the site fronting Centenary Road, Wyreema Street and Alderney Street, as directed by Councils engineer. These works shall be carried out by a licenced construction contractor at the applicants cost and shall be in accordance with RMS and Council standards and issued level sheets.
145. The Applicant shall effect the removal of existing and construction of footpath paving to the site frontages in Centenary Road, Wyreema Street and Alderney Street. These works shall be carried out by a licensed construction contractor at the applicant's expense, shall be in accordance with Council's standard drawing SD 8100 & approved design and levels, and address the following:
  - i. A minimum 1.5m wide concrete footpath paving and associated works along all areas of the site fronting Centenary Road, Wyreema Street and Alderney Street.
  - ii. All footpath areas within the road reserve that are not concrete shall be turfed with ST85 Buffalo or 'Sir Walter'.

146. Removal of all redundant vehicular crossings and laybacks along the full road frontage and replacement with kerb and gutter. These works shall be carried out by a licensed construction contractor at the applicant's expense and shall be in accordance with Council's standard drawing number SD-8100.
147. A certificate of compliance for the construction of vehicular crossings, footpath paving, kerb and guttering and roadworks shall be obtained from Council and be submitted to the Principal Certifying Authority.

### **Road Widening**

148. Dedication of a 3.0m x 3.0m splay corner at the intersection of the Centenary Road/Alderney Street and Centenary Road/Wyreema Street boundaries to be effected. No structures (above and below) shall be proposed within the road widening area.

### **House/Street Number**

149. A house/street number must be displayed on all newly developed properties in accordance with Council's "Policy on the Display of House Numbers" available from the Customer Services Counter or Council's website, [www.cumberland.nsw.gov.au](http://www.cumberland.nsw.gov.au).

The street number shall be maintained to 189 Great Western Highway, Mays Hill.

### **Design Verification Statement**

150. In accordance with Environmental Planning and Assessment Regulation 2000 and State Environmental Planning Policy (SEPP) 65 "Design Quality of Residential Apartment Development", the subject development must be undertaken or directed by a "qualified designer" (i.e., a "registered architect" under the Architects Act). In this regard, prior to the issue of an occupation certificate a design verification statement shall be submitted to the Principal Certifying Authority (PCA) assessing the development, upon completion of all works subject of this consent. The PCA shall ensure that the statement prepared by the qualified designer provides the following:-
  - (i) A valid and current chartered architect's certificate number (as issued by the Board of Architects of NSW);
  - (ii) That the completed development achieves the design quality of the development as shown in the plans and specifications submitted and approved with the Construction Certificate, having regard to the design quality principles set out in Part 2 SEPP 65.

### **Noise Compliance Report**

151. A noise compliance report shall be submitted to Council prior to the issuing of the Occupation Certificate. The report shall state that the noise reduction measures detailed within the Acoustic Report prepared by Acoustic Logic, Project No. 20170554.1, Reference No. 20170554.1/1007A/R1/MF, Revision 1, dated 10 July 2017, have been implemented, and confirm that the noise emissions from the premises complies with Council's noise criteria specified in this consent.

### **Restriction as to User and Positive Covenants**

152. Use for Affordable Housing for 10 years: -

For 10 years from the date of the issue of the Occupation Certificate, all units within the development must: -

- (i) Be used for the purposes of affordable housing; and
- (ii) Be managed by a registered community housing provider.

153. Details of the registered community housing provider responsible for the management of the affordable rental housing shall be submitted to the Principal Certifying Authority and Council, prior to the issue of the Occupation Certificate.

154. A restriction as to user must be registered, before the date of the issue of the Occupation Certificate, against the title of the property, in accordance with Section 88E of the Conveyancing Act 1919, to ensure that the requirements of Condition 150, requiring the use of all units within the development, for the purpose of affordable housing, that accommodation will be managed by a registered community housing provider.

Documents giving effect to the creation of a Restriction on Use must be submitted to the Council for approval prior to lodging with Land and Property Information NSW. The terms of the instruments are to be to the satisfaction of Council.

Council is to be named in the instrument as the only party authorised to release, vary or modify the instrument.

Registered title documents showing the covenants and restrictions must be submitted to and approved by Council prior to the issue of any Occupation Certificate.

The restriction to use and any associated documentation must be prepared and registered at the sole cost of the applicant, including the reasonable costs of Council in obtaining legal advice on the restriction terms, the cost and expense of negotiating the terms and conditions of the restriction, producing documents or otherwise facilitating the preparation and registration of the required documents.

155. On the day that the Occupation Certificate is issued, Council is to be notified in writing.

Reason: For Council's records on affordable rental housing to be updated accordingly.

### **General**

156. Documentary evidence and/or certificate of compliance must be submitted to Council to show that all works have been completed in accordance with this Development Consent and its accompanying Construction Certificate.
157. The glass balustrading associated with the balcony areas of the development, facing the public domain, shall be maintained to opaque glass.

## **CONDITIONS RELATING TO USE**

**The following conditions are applicable to the use of the development:-**

### **Safety & Amenity**

158. Where an intruder alarm is installed on the premises it shall be fitted with a timing device in accordance with the requirements of the Protection of the Environment Operations Act 1997.

### **Mechanical Ventilation System – Car Park**

159. Noise and vibration from the use of the (mechanical exhaust ventilation) system shall not exceed the background level by more than 5dB(A) and shall not be audible in any premises of a different occupancy between 10.00pm and 7.00am on weekdays and 10.00pm and 8.00am on weekends and public holidays.

### **Traffic and Parking**

160. At least 68 car parking spaces numbered and line marked in accordance with the endorsed plan, are to be made available at all times for residents, employees and visitors' vehicles only in conjunction with the occupation of the building/premises.
161. All vehicles shall enter and leave the site in a forward direction.
162. The car wash bay shall be a common, independent area, and not serve as a visitor parking space.

### **Refuse & Trade Waste**

163. Waste storage bins must be covered at all times to prevent entry of stormwater or dispersal by wind and must be sealed to prevent leakage.

### **Maintenance of Waste Storage Area**

164. All waste and recycling containers shall be stored in the designated waste storage area. The body corporate shall be responsible for movement of the waste and recycling containers to the footpath for weekly collections, and the return of waste and recycling containers to the waste storage area. The Body Corporate shall clean the waste storage area, dry arrestor pit and waste collection containers.

### **Air Emissions**

165. In the event of Council receiving complaints regarding excessive odour from the garbage bay area, the person(s) in control of the premises shall at their own cost arrange for an environmental investigation to be carried out (by a suitably qualified person) and submit a report to Council specifying the proposed methods for the control of odour emanating from the garbage bay area.

### **Alarms**

166. Where audible intruder alarms are installed in the units by residents, they shall be fitted with a timing device in accordance with the requirements of the Protection of the Environment Operations Act 1997. (Note: Conditions 102 and 103 above, prevents the developer/builder from installing audible alarms).

### **Emergency Procedures**

167. The owner of a building to which an essential fire safety measure is applicable must not fail to maintain each essential fire safety measure in the building premises to a standard not less than that specified in the Fire Safety Schedule.

### **Noise**

168. The operation of the pump from the rainwater tank shall not give rise to an equivalent continuous (LA<sub>eq</sub>) sound pressure level at any point on any residential property greater than 5dB(A) above the existing background LA<sub>90</sub> level (in the absence of the noise under consideration). Council may require an Acoustic Report to be submitted, prepared by a suitably qualified person, to ensure this requirement is met in the event of Council receiving complaints.
169. The operation of all plant and equipment shall not give rise to an equivalent continuous (LA<sub>eq</sub>) sound pressure level at any point on any residential property greater than 5dB(A) above the existing background LA<sub>90</sub> level (in the absence of the noise under consideration).
170. In the event of Council receiving complaints regarding excessive noise, the person(s) in control of the premises shall at their own cost arrange for an acoustic investigation to be carried out (by a suitably qualified person) and submit a report to Council specifying the proposed methods for the control of noise emanating from the premises.
171. Noise and vibration from the use of the air conditioning system (if any installed) shall not exceed the background level by more than 5dB(A) and shall not be audible in any premises of a different occupancy between 10:00pm and 7:00am on weekdays and 10:00pm and 8:00am on weekends and public holidays.

### **Car Wash**

172. Washing of vehicles shall be conducted in a car washbay, which is roofed and bunded to exclude rainwater. The carwash bay shall be regularly cleaned and maintained. Alternative water management and disposal options may be appropriate where water is recycled, minimised or re-used on the site.
173. The car wash bay shall be managed and maintained so that the following requirements are met:
- The Body Corporate or owner should advise all users of the car wash facilities how to operate, maintain and use the equipment so that good housekeeping practices can be adopted at all times.
  - Have clearly visible sign(s) indicating that no degreasing, engine washing or mechanical work is to be undertaken in the car wash bay, informs car wash bay

users of how to use and maintain the system, and encourages users to minimise the use of detergents and water.

### **Lighting**

174. Any lighting on the site shall be designed so as not to cause nuisance to other residences in the area or to motorists on nearby roads, and to ensure no adverse impact on the amenity of the surrounding area by light overspill. All lighting shall comply with AS4282-1997 *Control of the obtrusive effects of outdoor lighting*.

### **Landscaping**

175. Landscaping adjacent to the driveway shall not restrict pedestrian and vehicular visibility in accordance with Australian Standard 2890.1 – 2004. Regular maintenance shall be undertaken to ensure this requirement is satisfied.

### **Use for Affordable Housing**

176. All of the units within the development must be used for the purposes of affordable housing and that accommodation must be managed for the purposes of affordable housing by a registered community housing provider for a period of 10 years from the date of the issue of the Occupation Certificate.

### **General**

177. All privacy measures shall be maintained at all times, throughout the lifetime of the development.



## ADVISORY NOTES

### Other Necessary Approvals

- A. The applicant's attention is drawn to the need to obtain Council's separate approval for any ancillary activity not approved by this consent, including:
- (a) Works, including the pruning or removal of any tree(s) not authorised in the preceding conditions or on the approved plans. Council's Tree Preservation Order protects trees by definition taller than 3.5m or having a trunk circumference exceeding 500mm measured one metre above ground level. If in doubt contact Council's Tree Management Officer.
  - (b) Any fencing located forward of the proposed building and exceeding the limitations specified in Local Environmental Plan 2013, Part 3 *"Exempt and Complying Development"*.
  - (c) The erection of any advertising sign, not being exempt from the need to obtain approval.
  - (d) The installation of any furnace, kilns, steam boiler, chemical plant, sand blast, spray painting booth or the like.

**NOTE:** \* If you carry out building work as an owner builder and sell your home within seven (7) years from the date of completion (date of final occupation certificate), then a Certificate of Insurance must be attached to your Contract of Sale.

- B. Section 97 of the Act provides that an applicant who is dissatisfied with the Council's determination of the Development Application may appeal to the Land and Environment Court within 6 months of the date of determination, or as otherwise prescribed.
- C. Section 82A of the Act provides that an applicant may request, within 6 months of the date of determination of the Development Application, that the Council review its determination (this does not apply to integrated or designated development). A fee is required for this review.

It should also be noted that an application under Section 82A of the Act cannot be reviewed/determined after 6 months of the date of determination. Therefore, the submission of a Section 82A Application must allow sufficient time for Council to complete its review within the prescribed time frame, including the statutory requirement for public notification.

- D. The applicant and Owner are advised that the Commonwealth Disability Discrimination Act 1992 may apply to this particular proposal. Approval of this application does not imply or confer compliance with this Act. Applicants and owners should satisfy themselves as to compliance and make their own enquiries to the Australian Human Rights Commission. Attention is also drawn to the provisions of Parts 2, 3 and 4 of Australian Standard 1428 - Design for Access and Mobility.
- E. A Construction Certificate shall be obtained in accordance with Section 81A (2)(a) of the Act, prior to the commencement of any work on site. Council can provide this service for you.

- F. An Occupation Certificate is to be issued by the Principal Certifying Authority prior to the occupation of the building.

G. DEMOLITION

- (a) Demolition is to be carried out in accordance with AS2601-2001, *Demolition of Structures*.
- (b) Demolition is to be carried out in such a way and with such control measures as are necessary to prevent the occurrence of any dust, noise, runoff or other nuisance.
- (c) All sediment/soil is to be prevented from entering Council's stormwater drainage system.
- (d) The public footpath and roadway is to be protected against damage as a result of demolition activities and is to be kept clean and free of all soil and other materials.
- (e) On completion of demolition the site is to be left in a clean and tidy condition.
- (f) Council has a Tree Management Order which applies to the entire City of Cumberland. No ring-barking, cutting down, topping, lopping, removing, injuring or wilful destruction of any tree or trees exceeding 3.5m in height and 3m in branch spread shall take place without the prior written consent of Council.
- (g) There shall be no burning of any waste, as this is prohibited within the City of Cumberland.
- (h) Demolition material can be recycled saving the environment and also tipping costs. For more information, contact the Environment Protection Authority's Recycling hotline on 9325 5555.
- (i) Public roads shall be kept clean and free of any materials which may fall from vehicles or plant to ensure safety and amenity of the area.

H. BANK GUARANTEES

Bank guarantees will be accepted from list of banks which have at least an "A" rating from Standard and Poors and at least an "A2" or "Prime-1" standard from Moodys Investor Services.

To enable the bank guarantee to be enforceable during an entire project with consideration for delays, **the guarantee must not contain a facility expiry date.**

To get to Standard and Poors [www.standardpoors.com](http://www.standardpoors.com) then from Ratings Action choose Ratings Lists. Then click on Financial Institutions followed by clicking on Financial Institutions Counterparty Ratings List. Go to "**Banks**" and download to Australian Banks.

To get to Moodys [www.moodys.com](http://www.moodys.com) then look up Ratings and then Banking and then Bank Ratings list. It will take you to Bank Credit Research page. Look at the table of contents and choose Global Bank Ratings by Country. Look up Australian Banks.

I. SMOKE DETECTORS

A system of self contained smoke alarms complying with the requirements of AS3786-1993, *Smoke Alarms* or listed in the *Scientific Services Laboratory Register of Accredited Products* being installed in the dwelling, connected to the mains power supply and provided with a standby power supply. Alarms are to be positioned on the ceiling and setback a minimum distance of 300mm from any wall. Alarms are to be placed in the

vicinity of each area containing bedrooms with a minimum of one (1) alarm required for each storey of the dwelling.

#### J. TERMITE PROTECTION

Structural members are to be protected from attacked by subterranean termites in accordance with the requirements of *AS3660.1-2000 Protection of building from subterranean termites* and a durable notice must be affixed within the metre box indicating the type of protection, its date of installation, life expectancy of any chemical barrier used, and system maintenance and inspection requirements. A certificate of compliance of the approved system must be submitted to Council or the Principal Certifying Authority on completion of the system installation. With respect to chemical protection, a pipe system shall be installed beneath the slabs plastic membrane to allow re-application of the chemical border.

#### K. WET AREAS

Wet areas in the dwelling are to be waterproofed in accordance with *AS3740 Waterproofing of wet areas within residential buildings*.

Where Council is the Principal Certifying Authority for the works, the submission of evidence of suitability for the waterproofing product used will be required at the wet area inspection stage. The evidence of suitability is to be in the form of:-

1. A current Certificate of Accreditation for the product.

AND

2. A certificate from the person responsible for the installation of the product advising that the product was applied in accordance with the relevant manufacturers specifications.

**Note:** Any copy of documentary evidence submitted, must be a complete copy of the original report or document.

#### L. LANDINGS

A landing having a minimum length of 750mm and a grade no steeper than 1:50, must be provided where the sill of a threshold of a doorway opens onto a stair that provides a change in floor level or floor to ground level greater than 3 risers or 570mm in accordance with Clause 3.9.1.3 (Stair Construction) of the Building Code of Australia.

#### M. SARKING

To reduce the risk of injury during works to the roof, sarking with fall arresting ability is to be provided to the underside of the roof. Manufacturers specifications for the sarking is to be submitted to Council prior to its installation.

N. MINIMISING WATER USE

Examples of ways water use can be minimised in the car wash facility are:

- the use of a gun type nozzle on the hose that closes when released and
- filter and recycle wash water where possible.

O. CONSTRUCTION/OCCUPATION CERTIFICATE FEES

An administration fee per certificate (in accordance with Council's adopted fees and charges) is payable to Council on lodgement of Construction and Occupation Certificates from Principal Certifying Authorities.

P. SOUND TRANSMISSION AND INSULATION

To ensure the amenity of occupants in multi-residential development (Class 2 and 3 buildings and Class 9c Aged Care buildings), separating walls must be constructed in accordance with Part F5 of the Building Code of Australia.

Q. FIRE SAFETY

Paths of travel a minimum of 1000mm wide in accordance with D1.6 of the Building Code of Australia are to be clearly defined and line marked on the floor prior to occupation.

R. GLAZING CERTIFICATION

A certificate shall be submitted to the Principal Certifying Authority stating that safety glazing has been used in the building in accordance with AS1288 - "Glass in Buildings - Selection and Installation".

S. DIAL BEFORE YOU DIG

Underground assets may exist in the area that is subject to your application. In the interests of health and safety and in order to protect damage to third party assets please contact Dial before you dig at [www.1100.com.au](http://www.1100.com.au) or telephone on 1100 before excavating or erecting structures (This is the law in NSW). If alterations are required to the configuration, size, form or design of the development upon contacting the Dial before You Dig service, an amendment to the development consent (or a new development application) may be necessary. Individuals owe asset owners a duty of care that must be observed when working in the vicinity of plant or assets. It is the individual's responsibility to anticipate and request the nominal location of plant or assets on the relevant property via contacting the Dial before you dig service in advance of any construction or planning activities.

T. TELECOMMUNICATIONS ACT 1997 (COMMONWEALTH)

Telstra (and its authorised contractors) are the only companies that are permitted to conduct works on Telstra's network and assets. Any person interfering with a facility or installation owned by Telstra is committing an offence under the Criminal Code Act 1995 (Cth) and is liable for prosecution.

Furthermore, damage to Telstra's infrastructure may result in interruption to the provision of essential services and significant costs. If you are aware of any works or proposed works which may affect or impact on Telstra's assets in any way, you are required to contact Telstra's Network Integrity Team on Phone Number 1800810443.

U. DIVIDING FENCES

Please be advised that arrangements concerning existing or proposed fences between properties are a civil matter determined by the involved parties under the Dividing Fences Act. You are therefore required to consult with the owners of neighbouring properties if fences are to be removed or constructed.

The Dividing Fences Act is administered by the Department of Lands who can act as a mediator in disputes. For further information please refer to the following information on Council's website:  
[www.holroyd.nsw.gov.au/building\\_and\\_development/local\\_plans\\_and\\_policies/dividing\\_fences](http://www.holroyd.nsw.gov.au/building_and_development/local_plans_and_policies/dividing_fences)

Yours faithfully,

Sohail Faridy  
COORDINATOR DEVELOPMENT ASSESSMENT

