

Reference: 20140076-L02

Date: June 22, 2018

City of Parramatta Council,
126 Church Street, Parramatta NSW 2150

Dear Sir,

RE: Amendment of Council's requirements

SUBJECT PREMISES 2-6 Young Road, Carlingford NSW

DEVELOPMENT APPLICATION DA/964/2017

Regarding to a recent letter from the council, S&G Consultants has amended the below issues:

- 1.) **All pits are numbered as per council requirements.**
- 2.) **Pipe connection in stormwater trunk main is adjusted.**
- 3.) **SWMR is connected to the nearest pit which is right next to it.**
- 4.) **More OSD sections are provided in drawing SW301.**
- 5.) **The Diversion Chamber/HFB is added in any OSDs within the site and the calculation is provided in SW300.**
- 6.) **Underdrains straight to Overflow chamber as per council requirements.**
- 7.) **Overflow weirs/Pipes in side walls of OSD tanks at TWL are also shown in SW301.**

Please do not hesitate to contact us if you have any questions in relation to these updates.