All communications to be addressed to:

Headquarters
15 Carter Street
Lidcombe NSW 2141

Headquarters Locked Bag 17 Granville NSW 2142

Telephone: 1300 NSW RFS e-mail: records@rfs.nsw.gov.au

Facsimile: 8741 5433



The General Manager
The Council of the Shire of Hornsby
PO Box 37
HORNSBY NSW 1630

Your Ref: DA/201/2018 Our Ref: D18/5367 DA18042712832 AS

ATTENTION: Matthew Miles 23 November 2018

Dear Sir/Madam

Integrated Development Application - C, D//367580 B//384707 3/1/1880 A//384707 2/1/1880 1/1/1880 B//337147 E//367580 1//951409 A//337147 9/1/1880 187-203 Peats Ferry Road & 2-6 Dural Street Hornsby NSW 2077

I refer to your correspondence dated 20 April 2018 seeking general terms of approval for the above Integrated Development Application.

The New South Wales Rural Fire Service (NSW RFS) has considered the information submitted. General Terms of Approval, under Division 4.8 of the 'Environmental Planning and Assessment Act 1979', and a Bush Fire Safety Authority, under Section 100B of the 'Rural Fires Act 1997', are now issued subject to the following conditions:

1. A Bush Fire Emergency Management and Evacuation Plan shall be prepared consistent with 'Development Planning- A Guide to Developing a Bush Fire Emergency Management and Evacuation Plan December 2014'.

Asset Protection Zones

The intent of measures is to provide sufficient space and maintain reduced fuel loads so as to ensure radiant heat levels of buildings are below critical limits and to prevent direct flame contact with a building. To achieve this, the following conditions shall apply:

2. At the commencement of building works, and in perpetuity, the entire property shall be managed as an Inner Protection Area (IPA) as outlined within section 4.1.3 and Appendix 5 of 'Planning for Bush Fire Protection 2006' and the NSW Rural Fire Service's document 'Standards for Asset Protection Zones'.

Water and Utilities

ID:112832/106578/5 Page 1 of 2

The intent of measures is to provide adequate services of water for the protection of buildings during and after the passage of a bush fire, and to locate gas and electricity so as not to contribute to the risk of fire to a building. To achieve this, the following conditions shall apply:

- 3. The provision of water, electricity and gas services are to comply with section 4.1.3 of 'Planning for Bush Fire Protection 2006':
 - Fire hydrant spacing, sizing and pressures shall comply with Australian Standard AS 2419.1– 2005 'Fire Hydrant Installations'.
 - Fire hydrants shall not be located within any road carriageway.

Design and Construction

The intent of measures is that buildings are designed and constructed to withstand the potential impacts of bush fire attack. To achieve this, the following conditions shall apply:

- 4. New construction for the residential components of the proposed development shall comply with Sections 3 and 5 (BAL 12.5) Australian Standard AS3959-2009 'Construction of buildings in bush fire-prone areas' or NASH Standard (1.7.14 updated) 'National Standard Steel Framed Construction in Bushfire Areas 2014' as appropriate and section A3.7 Addendum Appendix 3 of 'Planning for Bush Fire Protection 2006'. Residential components are required to be separated from commercial uses of the proposed development by a fire-rated wall achieving an FRL of 60/60/60 for load bearing walls, -/60/60 for non-load bearing walls, -/60/30 for doors and -/60/- for windows.
- 5. The existing childcare centre located on Lot 9, Section 1, DP 1880 (6 Dural Street Hornsby) is required to be upgraded for ember protection. This is to be achieved by enclosing all openings (excluding roof tile spaces) or covering openings with a non-corrosive metal screen mesh with a maximum aperture of 2mm. Where applicable, this includes any sub floor areas, openable windows, vents, weepholes and eaves. External doors are to be fitted with draft excluders.

Landscaping

6. Future landscaping to the site is required to comply with the principles of Appendix 5 of 'Planning for Bush Fire Protection 2006'.

Should you wish to discuss this matter please contact Adam Small on 1300 NSW RFS.

Yours sincerely

Kalpana Varghese

Kalpana Vaghan

Team Leader - Development Assessment and Planning

For general information on bush fire protection please visit www.rfs.nsw.gov.au