

Consultant Advice Notice

From: ADP Consulting
Project: 14 – 24 Stanley Street, Kogarah

Advice No.: 04
Project No.: SYD0471
Date: 24/01/19
Revision: 01

To: **Attention** Mariana Yanes
Company Poly Global

Email
mariana.yanes@polyglobal.com

PKA Acoustic Consultants have identified that acoustic treatment will be required to the ground floor mechanical plantroom.

ADP have made preliminary allowance for acoustic silencers to be provided to each fan within this plantroom.

The final acoustic silencer selection will be nominated by the acoustic consultant to achieve the necessary acoustic attenuation to be nominated in their final acoustic report.

ADP will coordinate the services design during the design phase to incorporate the acoustic requirements outlined in the PKA Acoustic Report.