

Date 25 January, 2019
Reference 11027 R02v1
Project Stanley St (12-24), Kogarah
Contact Mariana Yanes
Email Client Email
Company Poly Global
Address Level 37, Australia Square
264 George St, Sydney, NSW 2000

File *PKA11047 R02v1 Plantroom Acoustic Advice for Council*

Dear Mariana,

Re: Plantroom Acoustic Advice for Council



Our DA Acoustic Report [PKA11047 R01v1 dated 26th April 2018] noted that the mechanical plantroom located on the ground floor has the potential to cause noise impacts to the eastern residential receivers without acoustic treatment or relocation of the plantroom.

We have been advised by Poly Global that the plantroom is constrained to this location therefore acoustic treatment will be required.

ADP Consulting in their letter [Ref: SYD0471 dated 24th January 2019] have stated that they have made allowances for acoustic silencers to be applied to each fan within the plantroom, and that final acoustic recommendations by PKA will be coordinated during detailed design once equipment schedules are available.

We accept ADP allowances regarding the plantroom acoustic treatment and can confirm that the plantroom in its current location will be designed to meet the site-specific noise goals as per Council's requirements

Yours faithfully,

A handwritten signature in black ink, appearing to read 'Joel Parry-Jones'.

Joel Parry-Jones

PKA Acoustic Consulting

PKA ACOUSTIC CONSULTING

PO Box 345 Lane Cove 1595

+612 9460 6824 · admin@pka.com.au · ABN 87 256 407 546

Member Firm of the Association of Australasian Acoustical Consultants