



HR944 - BF1

- 1x125 PVC
- 1x50 PVC
- 0.4-0.7
- 0.8-0.9

Ref: C9

HR94443

HR94444

JOINT DETAIL REPORT
No. HR944 BF1
Map HR944
21 10/12/2011 0.30/0.30 34.2 W OF BVD - 28 OSPNEY CR & RD

WARNING
Ausgrid's plans show the position of assets at the time of installation and may not account for subsequent changes to road alignments, fences or buildings. The plans show no more than the presence or absence of Ausgrid assets in the street.
Persons working near electricity networks must exercise care and will be held responsible for any damage caused.
You must excavate by hand to use vacuum excavation to establish the location of Ausgrid underground cables and associated assets.
Underground: Working near a cable may result in electric shock even if no contact is made. Any work in the vicinity of any cable should only be performed using safe work methods developed in accordance with the recommendations included in WorkCover Code of Practice for Excavation and WorkCover Guide for Work Near Underground Assets.
as well as recommendations of Ausgrid's Network Standard NS156.
Overhead: Do not excavate near poles or towers until the stability of the foundation has been assessed by Ausgrid. Cables or earth conductors may be closer close to substations, poles or towers.
Workers must maintain safe approach distances and follow applicable WorkCover Codes of Practice.
NOTE: 1. You must keep Ausgrid plans on site during excavation works. If the people actually performing the excavation works do not know how to read and interpret Ausgrid's plans, then the work must be directed by a person who knows how to read and interpret the plans. 2. This information includes data from the NSW Digital Cadastral Database for Land and Property Information (c) 2016, used under Creative Commons license version 4.0.

HR9441	HR9442	IR731
HR9443	TR9444	IR732
HS321	HS322	IS111
SN15	SN15	SN15
SN15	SN15	SN15
SN15	SN15	SN15

HR9444GMLA0
Distr + Trans - 54668125
Page 1 of 1
2 Aug 2016
1:502
30 metres
Ausgrid