

Job No. 2016/3570

Thursday, September 19, 2019

Scentre Design and Construction Pty Limited
85 Castlereagh Street
Sydney NSW 2000

Email: cterkalas@scentregroup.com

Attention: Christopher Terkalas

**RE: Westfield Liverpool – Level 2 (Ground)
Egress discharge path to Elizabeth Drive**

We wish to advise that the required aggregate exit width that discharges to the Elizabeth drive forecourt is 3m in total. We wish to confirm that this width is provided from the discharge point to Elizabeth Drive. Furthermore, the path of travel does not pass over the adjoining on the adjoining allotment.

