

Level 1 54 Union Street COOKS HILL NSW 2300

T 02 4926 4811

ENGINEERS

MANAGERS

INFRASTRUCTURE PLANNERS

DEVELOPMENT CONSULTANTS

Stormwater Management Plan for DA

Peppertree Estate, Gundy Road SCONE

Prepared for: Charles David Pty Ltd Document no: NSW202732_R01.02 Revision no: 03



Source: Near Maps





Disclaimer

This Report has been prepared in accordance with the scope of services described in the agreement between ACOR Consultants Pty Ltd and the Client. The Report relies upon data, surveys, measurements and results based on instructions from, and in consultation with, the Client. Except as otherwise stated, ACOR Consultants Pty Ltd has not attempted to verify the accuracy or completeness of any information provided by the Client. If the information is subsequently determined to be false, inaccurate or incomplete then it is possible that changes may be required to the Report. Changes in circumstances or facts, the passage of time, manifestation of latent conditions or impacts of future events may also impact on the accuracy, completeness or currency of the information or material set out in this Report. This Report has been prepared solely for use by the Client, ACOR Consultants Pty Ltd accepts no responsibility for its use by any third parties without the specific authorisation of ACOR Consultants Pty Ltd. ACOR Consultants Pty Ltd reserves the right to alter, amend, discontinue, vary or otherwise change any information, material or service at any time without subsequent notification. All access to, or use of, the information or material is at the user's risk and ACOR Consultants Pty Ltd accepts no responsibility for the results of any actions taken on the basis of information or material provided, nor for its accuracy, completeness or currency. For the reasons outlined above, however, no other warranty or guarantee, whether expressed or implied, is made as to the data, observations and findings expressed in this Report, to the extent permitted by law.

Revisions

Revision	Description	Date	Prepared by	Approved by
01	For Approval	19 August 2021	Ulrika Knight	Josh Rhodes
02	For Approval	18 February 2022	Ulrika Knight	Josh Rhodes
03	For Approval	11 March 2022	Ulrika Knight	Josh Rhodes

COPYRIGHT

This document, including the concepts and information contained within it, are the property of ACOR Consultants Pty Ltd or any of its related or associated entities. Use or copying of this document in whole or in part without the written permission of ACOR Consultants Pty Ltd constitutes an infringement of copyright. No part of this document may be copied, reproduced, adapted, transmitted or stored in a retrieval system in any form or by any means without written permission or unless otherwise permitted under the Copyright Act 1968. Removal or modification of any copyright or other proprietary protection from this document will be a breach of copyright.

© ACOR Consultants Pty Limited

All intellectual property and copyright reserved.

Table of Contents

1	Introd	uction4	ŀ
2	Previo	ous Stormwater Drainage Assessments4	ŀ
	2.1	Location4	ł
	2.2	Topography4	ŀ
	2.3	Existing Land Use and Vegetation	;
	2.4	External Catchments	;
	2.5	Existing Flowpaths and Water Bodies5	,
3	Propo	sed Development5	,
4	Storm	water Quantity Management6	;
	4.1	Objectives6	;
	4.2	Stormwater Conveyance	,
	4.3	Stormwater Detention	,
5	Storm	water Quality Management	\$
	5.1	Objectives	;
	5.2	Operational Phase Water Quality Management13	;
	5.3	Construction Phase Water Quality Management	;
6	Concl	usion19	,
7	FIGUI	RES)

Appendices

Appendix A - DRAINS Modelling Inputs and Results	21
Appendix B - MUSIC Modelling Report	22



1 Introduction

ACOR Consultants have been engaged by Charles David Pty Ltd C/- MM Hyndes Bailey & Co to prepare a Stormwater Management Plan for Development Approval for a residential subdivision development at Lot 2 (DP1169320) Gundy Road, Scone.

The stormwater drainage items addressed in this report include:

- Stormwater conveyance/network;
- Stormwater detention
- Operational water quality management incorporating Water Sensitive Urban Design (WSUD) principles
- Construction water quality management incorporating soil and water management.

2 **Previous Stormwater Drainage Assessments**

The following stormwater drainage assessment have been completed previously for the proposed subdivision development at this site by others:

- Stormwater Drainage Strategy Peppertree Estate Scone by MM Hyndes Bailey dated November 2017
- Stormwater Quality Report by Barker Ryan Steward dated November 2017
- Stormwater Drainage Strategy Supplementary Report 70-80% Impervious Peppertree Estate Scone by MM Hyndes Bailey dated November 2019

The site layout for the proposed subdivision has been revised and as such an updated Stormwater Drainage Management Plan is required and is contained within this report.

Revision 1 of this report was issued on 19 August 2021. A peer review of the Stormwater Management Plan was undertaken by Northrop. Refer to Northrop letter titled *"Review of Stormwater Management Plan at 150 Gundy Road, Scone"*, and dated 19 January 2022 with a reference number NL213311. In response to the peer review, sections of this report have been amended and additional information provided. Revisions 2 of this report was issued on 18 February 2022. A response to the Northrop peer review is contained in ACOR letter dated 18 February 2022.

As noted in Northrop's letter, a detailed two-dimensional flood assessment is to be prepared to suit the proposed subdivision layout. A flood assessment has been undertaken by Torrent Consulting. Refer to report titled *"Flood Impact Assessment for Peppertree Estate, Gundy Road, Scone NSW"* dated 3 March 2022. This report has been updated to incorporate the findings from the flood assessment and reissued as Revision 3.

2.1 Location

The site is located east of Scone at Lot 2 Gundy Road, Scone. The proposed development is bounded by Gundy Road to the north, rural properties to the easy and south, and abuts to the age care facility "Strathearn" to the north west. Refer to Figure 1 for Locality Plan.

2.2 Topography

The existing site comprises of approximately 57 Hectares of gently sloping grasslands. There is a second order stream traversing through the site from east to west. The stream divides the proposed development into a northern section and a southern section.

The northern section of the site grades at approximately 4% from the north east to the south west towards the stream. The levels on site for the northern section range from approximate RL 226m AHD at the north east boundary to RL 214m AHD at the south west boundary at the stream.



Most of the southern section of the site grades at approximately 5% from the south east to the north west towards the stream. There is a crest in the southern section of the site that runs from east to west which means that a small section of the southern area grades to the south west. The levels for the southern section range from approximately RL 243m AHD at the south east boundary to RL 208m AHD at the north west boundary at the stream and RL 215m AHD at the south west boundary.

A farm dam is located within the site at the eastern end of the stream.

Refer to Figure 2 for the existing site topography.

2.3 Existing Land Use and Vegetation

The site in its current condition is mostly cleared grassland with some trees within the stream.

2.4 External Catchments

There is an upstream catchment north east of the site that drains to the culverts under Gundy Road and then feeds the stream through the development site from the east. This catchment is approximately 98 Hectares and is mostly grassland with some trees. The most northern part of this catchment is within the Scone Mountain National Park and has more vegetation than the lower section of the catchment.

There is an upstream catchment to the east of the site that feeds the stream through the development site. This catchment is approximately 53 Hectares and is mostly grassland.

The development site has frontage to Gundy Road. Gundy Road has a grassed swale along both sides of the road. In minor storm events, flows are directed to the west along Gundy Road but in major storm events the flows that cannot be contained within the grassed swale overflow into the development site and are directed south west to the stream traversing through the site.

The upstream external catchments draining through the development site are shown in Figure 3.

2.5 Existing Flowpaths and Water Bodies

There is a second order stream traversing through the site from east to west. This stream is fed from the upstream catchments to the north east under Gundy Road and to the east of the site. The stream is not well defined in places but is generally in good condition with minimal scouring.

A hydraulic analysis was undertaken by MM Hyndes Bailey on the second order stream. The results from the study are detailed in MM Hyndes Bailey report *Stormwater Drainage Strategy Peppertree Estate Scone* dated November 2017, Section 5.

A flood impact assessment for the latest subdivision layout has been completed by Torrent Consulting. The results

There is a farm dam located at the eastern site boundary within the stream. This dam is to remain, but further investigation will be required at the construction certificate stage to ensure that the overflows from the dam for 1% AEP flows are safe and do not impact the proposed residential lots.

3 Proposed Development

The proposed development will consist of three hundred and eighty four (384) residential lots, five (5) public parks and an open space, as well as associated roads and stormwater drainage infrastructure including basins. The subdivision is proposed to be development in sixteen (16) stages. The lot areas and staging details are shown in Table 1.



Development Stage	Lot numbers	Lot areas m ²
1	101 – 121 (21 lots)	637 – 1052
2	201 – 223 (22 lots and a park)	648 – 1650
3	301 – 313 (13 lots)	678 – 1227
4	401 - 418 (18 lots and a park)	703 – 898
5	501 - 514 (13 lots, a restricted land use with basins and a park)	704 – 978
6	601 – 630 (30 lots)	705 – 1055
7	701 – 723 (23 lots)	707 – 982
8	801 – 832 (32 lots)	701 - 1348
9	901 – 927 (27 lots)	706 - 1077
10	1001 – 1036 (36 lots)	708 - 1222
11	1101 – 1121 (21 lots)	701 - 1016
12	1201 – 1235 (35 lots)	709 - 1070
13	1301 – 1326 (24 lots, a park and a basin)	702 - 1373
14	1401 – 1428 (28 lots)	770 - 1277
15	1501 – 1521 (21 lots)	707 - 977
16	1601 – 1621 (20 lots and open space)	704 – 821

Table 1: Lot areas and staging details

Access to the subdivision will be from Gundy Road.

Stages 1, 2 and 3 are located on the northern side of the stream adjacent to Gundy Road.

The remainder of the stages are located on the southern side of the stream. A road crossing with reinforced concrete box culverts is proposed to span the stream to the southern side of the development.

Figure 4 shows the development layout for the subdivision.

4 Stormwater Quantity Management

4.1 Objectives

The objectives of the stormwater quantity management for the site are:

- Provide a stormwater conveyance system in accordance with Australian Rainfall and Runoff's minor/major system philosophy and the requirements of Upper Hunter Shire Council (UHSC). The minor stormwater conveyance system will be designed to convey peak flows from the 20% Annual Exceedance Probability (AEP) storm event and the major stormwater conveyance system will be designed to convey the peak flows from the 1% AEP storm events.
- Provide stormwater detention to reduce the peak flows from the site to or below the current peak runoff from the site.



4.2 Stormwater Conveyance

4.2.1 Minor Storm Event Conveyance

Minor system stormwater conveyance for the development will be a via a traditional pit and pipe system. The minor stormwater system will have the capacity to convey the peak flows from a 20% AEP storm event.

Figures 5 and 6 show a preliminary layout for the stormwater drainage system.

4.2.2 Major Storm Event Conveyance

Major system stormwater conveyance for the proposed development will be via overland flow. This will be via traditional trunk drainage utilising the road carriage way and footpath. The major stormwater system will have the capacity to convey the peak flows from a 1% AEP storm event, containing flows within the road reserve and limiting velocity depth product to or below 0.4 m²/s.

4.3 Stormwater Detention

4.3.1 General

Stormwater detention needs to be provided to ensure that the post development flows from the total site are reduced to the predevelopment flows for AEPs from 20% to 1% so that downstream properties are not impacted by increased flows from this proposed development.

The previous stormwater drainage study only considered the development site in the modelling.

This stormwater drainage study is a full catchment analysis and includes the upstream catchments that drain through the stream traversing through the proposed development.

4.3.2 DRAINS Modelling

DRAINS modelling was undertaken to determine the predeveloped and developed peak flows at the western boundary for a range of AEPs from 20% to 1%, for storm durations ranging from 5 minutes to 6 hours. ARR 2019 procedures were utilised in the DRAINS models.

The available detention volumes from the rainwater tanks which are a requirement of BASIX for each dwelling were not accounted for in the modelling.

The large undeveloped rural catchments were modelled using RAFTS storage routing model within DRAINS. For sub-catchment routing, RAFTS uses the equation:

S = BX . IBFL . PERN . 0.285 A0.52. (1+U)-1.97. Sc-0.50. Q0.715

where BX is a calibration factor similar to RORB's kc, IBFL is a factor for modelling overbank flow, PERN is a factor that adjusts the catchment routing factor to allow for catchment roughness, A is the sub-catchment area (km2), U is the fraction of the catchment that is urbanized, and Sc is the main drainage slope of the sub-catchment.

For routing along stream reaches, RAFTS applies a translation over a nominated time, or performs Muskingum-Cunge routing based on the stream cross-section and roughness.

The proposed developed catchments were modelled using the Initial Loss – Continuing Loss (IL-CL) model. The IL-CL hydrology procedure in DRAINS is an alternative to Horton (ILSAX). Both methods are accepted in the ARR 2019 guidelines and discussed in Book 5 Chapter 3. The IL-CL model and its parameters are set out in Section 3.5.3 of ARR 2019.



4.3.3 Rainfall Data

The Australian Rainfall and Runoff (AR&R) Data Hub was used to obtain data (Storm Losses, Temporal Patterns, BOM IFD Depths, Preburst Depths and Ratios and Interim Climate Change Factors) for the development site. The AR&R Data Hub results are shown in Appendix A.

4.3.4 Fraction Impervious

The fraction impervious to be used in stormwater drainage modelling is outlined with UHSC DRAFT Engineering Guidelines for Subdivisions and Developments Table 5.5 and shown in Table 2.

Land Use	Fraction Impervious
Normal residential lot only	0.6
Normal residential lot including half road	0.65
Half width road reserve	0.8
Public recreation areas	0.4
Open space (natural bushland)	0.35

Table 2: Fraction Impervious for Various Land Use

For the upstream catchments, a fraction impervious of 0.35 was adopted for rural/natural bushland in accordance with Council's standards.

To be conservative in determining the predeveloped and post developed flows at the western boundary, a fraction impervious of zero (0) was adopted for the predeveloped site (existing rural property) and a fraction impervious of 0.75 was adopted for the proposed subdivision in the DRAINS models.

4.3.5 Time of Concentration

Time of concentration for the catchments that are modelled using RAFTS was determined by the program. Catchment information such as area, fraction impervious, catchment slope and a Manning's n value are entered into the Sub-Catchment Data.

The Manning's n values adopted for the modelling are in line with recommendations from Australian Rainfall and Runoff: A Guide to Flood Estimation Table 6.2.2. The relevant land use and the recommended Manning's n range are shown in Table 3.

Land Use Type	Recommended Manning 'n'
Open pervious areas, nominal vegetation (grassed)	0.03 - 0.05
Open pervious areas, moderate vegetation (shrubs)	0.05 - 0.07
Open pervious areas, thick vegetation (trees)	0.07 – 0.12
Waterways/channels – minimal vegetation	0.02 - 0.04
Waterways/channels – vegetated	0.04 - 0.1

Table 3: Land Use Type and Recommended Manning's n

A Manning's n value of 0.05 was adopted for the external catchments (rural/natural bushland).

A Manning's n value of 0.04 was adopted for the predevelopment site catchment (rural grassed).

A Manning's n value of 0.04 was adopted for the stream traversing through the development site (waterways with minimal vegetation and trees).



The minimum time of concentration adopted for the developed catchments utilising the Initial Loss – Continuing Loss Model are 5 minutes for the impervious catchments and 10 minutes for pervious catchments. This is the time of concentration for lot runoff. Additional flow travel times were added to the developed catchments in accordance with Queensland Urban Drainage Manual Section 4.6.7.

4.3.6 Predeveloped Peak Discharge

The peak discharge for the predeveloped catchments in accordance with Figure 3 are shown in Table 4.

The two upstream catchment (EXTL A and B) and Site A catchment all discharge at the western boundary of the site. Site B catchment discharges at the south west boundary of the site.

Catabrant Nama	Area (Ha)	Predeveloped Peak Discharge m ³ /s (AEP)				
Catchment Name	Area (Ha)	20%	10%	5%	2%	1%
EXTL A	97.773	12.9	17.3	20.8	25.9	30.3
EXTL B	52.601	6.11	7.5	9.39	12.1	14.5
SITE A	48.752	2.3	3.07	3.89	4.89	602
Peak discharge at west boundary		20.9	25.4	31.8	40.3	47.6
SITE B	9.217	0.523	0.737	0.921	1.18	1.42
Peak discharge at south west boundary		0.523	0.737	0.921	1.18	1.42

Table 4:	Predevel	oped Ca	tchment	Flows

The DRAINS input data and results are contained in Appendix A.

4.3.7 Post Development Peak Discharge

The details for catchments EXTL A and EXTL B are as per the predeveloped model and the flows are the same.

Catchment Site A has been divided into catchments to represent the existing stream traversing the site, and the subdivision development at relevant discharge points. Refer to Figure 7 for the post development catchment plan.

The proposed road crossing the existing stream was also incorporated into the DRAINS model. Reinforced concrete box culverts (RCBC) were modelled as detailed below:

- Top of road RL 216.5
- Pavement thickness allowed for 500mm
- 2400x900 RCBC 6 culverts required
- Invert of RCBC RL214.85
- Length of culverts 30m

The peak discharge for the post developed catchments at the western boundary and the south west boundary are shown in Table 5.

Storm Event (AEP)	Post Developed Peak Discharge m ³ /s (AEP)	
	At west boundary	At south west boundary
20%	20.4	1.05
10%	25.6	1.25
5%	31.6	1.44

Table 5:	Post	develo	oped	Peak	Flows
----------	------	--------	------	------	-------



Storm Event (AEP)	Post Developed Peak Discharge m ³ /s (AEP)	
	At west boundary	At south west boundary
2%	40.3	1.73
1%	47.7	1.95

The DRAINS input data and results are contained in Appendix A.

4.3.8 Post versus Predeveloped Peak Discharge

The comparison of the predeveloped and post developed peak flows at the western boundary are shown in Table 6.

Storm Event	Peak Discharge at West	CDischarge at Western Boundary m ³ /s (AEP)		
(AEP)	EP) Predeveloped Post developed		Difference %	
20%	20.9	20.4	-2.4%	
10%	25.4	25.6	0.8%	
5%	31.8	31.6	-0.6%	
2%	40.3	40.3	0.0%	
1%	47.6	47.7	0.2%	

Table 6: Post versus Predeveloped Peak Flows at Western Boundary

The comparison of the predeveloped and post developed peak flows at the south west boundary are shown in Table 7.

Table 7: Post versus Predeveloped Peak Flows at South West Boundary

Storm Event			
(AEP)	Predeveloped Post developed		Difference %
20%	0.523	1.05	101%
10%	0.737	1.25	70%
5%	0.921	1.44	56%
2%	1.180	1.73	47%
1%	1.420	1.95	37%

4.3.9 Detention Basins

It is a standard requirement for most councils including UHSC, that stormwater detention be provided to ensure that the post developed from are reduced to the predeveloped flows for AEPs from 20% to 1% so that downstream properties are not impacted by increased flows from this proposed development.

The stormwater drainage modelling undertaken is a catchment wide analysis and includes the upstream catchments running through the site as well as the proposed development. As the proposed development is at the downstream end of the overall catchment draining to the western boundary of the site, the flow travel times from each catchment are important.

Generally, with this sort of catchment configuration, the post development flows are found to only increase marginally or not at all. As the post developed catchment times of concentrations are shorter, the flows from the



developed catchment have already travelled downstream before the flows from the larger undeveloped upstream catchment have arrived downstream.

This is evident in the post developed peak flows draining to the western boundary via the existing stream shown in Table 6. The post developed peak flows are below the predeveloped peak flows for all storm events except for 10% AEP. The increase in flows for the 10% AEP is less than 1% which is within the accuracy of the stormwater drainage modelling and will have minimal impact downstream. Therefore, no detention basins are required to reduce the post developed flows at the western boundary.

With the catchment configuration for this site, providing detention at the downstream end of the catchment will only increase the flows at the western boundary as the travel flow times for the developed catchments are lengthened due to the detention basin. This will result in the flows discharging from the basin aligning with the large upstream flows and increasing the overall peak flows at the western boundary.

As detailed above, approximately 9.2 hectares of the southern catchment of the site currently drains to the south west. With the proposed development, this area will be reduced to approximately 4.9 hectares.

As can be seen from Table 7, the post developed flows have increased compared to the predeveloped flows due to the increased fraction impervious of 75% for the proposed development.

As there is no downstream development that can be impacted by this minor flow increase, a detention basin to reduce the flows will not be provided at this location. This strategy was previously agreed to by council.

4.3.10 Impact of Climate Change on Catchment Flows

The impact of climate change on the catchment flows was assessed in accordance with the Interim Climate Change Factors provided by the AR&R Data Hub. A Climate Change Rainfall Multiplier of 1.2 was utilised in the DRAINS predeveloped and post developed models.

The comparison of the predeveloped and post developed peak flows including the effects of climate change at the western boundary are shown in Table 8.

Storm Event	Peak Discharge at Weste		
(AEP)	Predeveloped Post developed		Difference %
20%	26.300	26.500	0.8%
10%	33.700	32.800	-2.7%
5%	41.400	40.200	-2.9%
2%	51.800	51.100	-1.4%
1%	60.300	60.100	-0.3%

Table 8: Post versus Predeveloped Peak Flows at Western Boundary

As can be seen from Table 8, the post developed flows due to the impact of climate change are generally still below the predeveloped flows except for the major storm events where they are only marginally higher.

The comparison of the predeveloped and post developed peak flows including the effects of climate change at the south west boundary are shown in Table 9.

Table 9: Post versus	Predeveloped I	Peak Flows at	South West	Boundary
----------------------	----------------	---------------	------------	----------

Storm Event	Peak Discharge at South V		
(AEP)	Predeveloped	Difference %	
20%	0.734	1.26	72%



Storm Event	Peak Discharge at South V		
(AEP) Predeveloped Post developed		Post developed	Difference %
10%	0.989	1.5	52%
5%	1.220	1.73	42%
2%	1.540	2.08	35%
1%	1.840	2.35	28%

As can be seen from Table 9, the percentage difference between the predeveloped and post developed flows due to the impact of climate change have been reduced.

4.3.11 Comparison of Peak Flows

The modelled pre-developed peak flows discharging at the western boundary through the existing stream have been compared to the previous drainage study *Stormwater Drainage Strategy Peppertree Estate Scone* by MM Hyndes Bailey dated November 2017.

The comparison of the peak flows are presented in Table 10 below.

Storm Event	Predeveloped Peak Flows at Western Boundary m ³ /s (AEP)				
(AEP)	From MM Hyndes Bailey report dated November 2017	From this Drainage Study			
20%	6.56	20.9			
5%	14.8	31.8			
1%	29.8	47.6			

The stormwater drainage modelling undertaken as part of this drainage study to determine the peak flows discharging at the western boundary are in accordance with AR&R 2019 and utilised the RAFTS storage routing model for the large rural catchments upstream and for the existing catchment conditions for the development site.

The stormwater drainage modelling undertaken by MM Hyndes Bailey utilised the Regional Flood Frequency model in accordance with AR&R 2016.

The difference in the peak flows from the previous drainage study and the current drainage study is due to the following:

- Updated standard being utilised for modelling AR&R 2019
- Modelling methodology RAFTS storage routing model versus Regional Flood Frequency model
- Catchment data inputs division of catchments, time of concentration, catchment parameters, catchment lag times etc.

The DRAINS input data and results are contained in Appendix A.



5 Stormwater Quality Management

5.1 Objectives

The objectives of the Stormwater Quality for the site are:

- Meet the water quality objectives of Upper Hunter Shire Council (UHSC) for the operational phase of the site by using best practice stormwater treatment measures.
- The strategy for stormwater quality management as detailed in the report prepared by Barker Ryan Stewart *Stormwater Quality Report* dated November 2017 has been approved by Council, and states:

"Consultation was undertaken with Council to set a water quality target that would meet the objectives of the UHSC DCP, that is 'to ensure that stormwater generated from development does not result in pollution of water courses or receiving waters'. Mathew Pringle, Director of Environmental and Community Services advised that the pre-development forested condition of the site would be a suitable guide and an acceptable target for this development."

5.2 Operational Phase Water Quality Management

5.2.1 General

To meet the water quality requirements of UHSC, a range of water quality improvement devices will be required.

The proposed water quality improvement devices for the site will include:

- rainwater tanks
- Ecosol GPTs
- bioretention basins

The above water quality improvement devices act as a treatment train, progressively reducing pollutants as they pass through each one.

5.2.2 Stormwater Quality Modelling

5.2.2.1 Introduction

The MUSIC model version 6.3 was used to assess the pollutant generation from the development and the performance of the stormwater quality treatment train.

5.2.2.2 Rainfall Data and Evaporation Data

The rainfall data and evapotranspiration data collected from the Liddell Power Station was used in line with the previous MUSIC modelling undertaken by Barker Ryan Stewart (as discussed above).

5.2.2.3 Soil Types

As detailed in the Barker Ryan Steward report, the soil profile at the development site is composed of heavy clay underlain by coarse light medium clay. This information was obtained from *"The Soils Essential Report – NSW Soil and Land Information System for Scone High School"*.

5.2.2.4 Catchments

The catchments for the MUSIC modelling are the same as the catchment used in the DRAINS modelling discussed above. Refer to Figure 7 for the post development catchment plan.

The catchments for the MUSIC modelling were subdivided into road areas, roof areas and remaining lot areas as detailed in Table 11.



Catchment	CAT 1	CAT 2	CAT 3 & 6	CAT 4
Number of lots	70	56	223	35
Lot areas (Ha)	3.83	3.54	12.41	2.52
Roof areas (Ha)	1.75	1.40	5.78	0.88
Road areas (Ha)	1.67	2.59	6.43	1.10
Total catchment area (Ha)	7.25	7.53	24.32	4.49

Table 11: MUSIC Modelling Catchments

A fraction impervious of 80% was adopted for the roads.

The residential lots were divided up into roof areas and remaining lot areas. It was assumed that for an average size lot (800m²) with a fraction impervious of 75% and a roof area is 250m², the remaining lot is 550m² with a fraction impervious of 64%. Therefore, conservatively a fraction impervious of 65% was adopted for lots (excluding roof area).

In line with UHSC advice, the pre-existing (forest) catchment was model in MUSIC to compare the mean annual pollutants loads with the post developed catchment.

Currently the site is used for farming/agriculture, so this catchment type was also model in MUSIC for comparison.

5.2.2.5 MUSIC Model Source Inputs

The source data for the MUSIC model was adopted from the Sydney Catchment Authority (SCA) MUSIC Manual in line with the modelling undertaken by Barker Ryan Stewart.

Soil Parameter	Value
Rainfall Threshold (mm/day)	Roofs 0.3 / Roads 1.5 / Land uses 1.0
Soil Storage Capacity (mm)	90
Initial Storage (% of Capacity)	25
Field Capacity	58
Infiltration Capacity Coefficient – a	135
Infiltration Capacity Coefficient – b	4
Groundwater Initial Depth (mm)	10
Groundwater Daily Recharge Rate (%)	10
Groundwater Daily Base Flow (%)	10
Groundwater Daily Deep Seepage Rate (%)	0

Table 12: MUSIC Source Node Soil Properties

5.2.2.6 Catchments Pollutant Mean Concentrations

The pollutant Event Mean Concentration (EMC) values were adopted from SCA MUSIC Manual for both the base flows and storm flows. The base flow values are shown in Table 13 and the storm flow values are shown in Table 14 for various catchment types.



	Base Flow Pollutant Event Mean Concentration Values					
	TSS (log 10)		TP (lo	TP (log 10)		og 10)
Catchment Type	Mean	Std. Dev	Mean	Std. Dev	Mean	Std. Dev
Forest	0.78	0.13	-1.52	0.13	-0.52	0.13
Agriculture	1.30	0.13	-1.05	0.13	0.04	0.13
Road (mixed)	1.10	0.17	-0.82	0.19	0.32	0.12
Roof	0	0	0	0	0	0
Residential lots	1.20	0.17	-0.85	0.19	0.11	0.12

Table 13: Base Flow Pollutant Event Mean Concentration Values

Table 14: Storm Flow Pollutant Event Mean Concentration Values

	Storm Flow Pollutant Event Mean Concentration Values					
	TSS (TSS (log 10) TP (log 10)		TN (log 10)		
Catchment Type	Mean	Std. Dev	Mean	Std. Dev	Mean	Std. Dev
Forest	1.60	0.20	-1.10	0.22	-0.05	0.24
Agriculture	2.15	0.31	-0.22	0.3	0.48	0.26
Road (mixed)	2.20	0.32	-0.45	0.25	0.42	0.19
Roof	1.30	3.20	-0.89	0.25	0.30	0.19
Residential lots	2.15	0.32	-0.60	0.25	0.30	0.19

5.2.2.7 MUSIC Model Treatment Train

The stormwater quality treatment train consist of three parts; rainwater tanks, Ecosol GPTs and bioretention basins. A schematic of the MUSIC model is shown in Appendix B.

A brief description on each treatment measure is listed below.

• Rainwater Tanks - Rainwater tanks receive water from the roof area of each lot. A 3kL rainwater tank was assumed for each standard residential lot. Water captured in the rainwater tanks is expected to be reused for toilet flushing, clothes washing, hot water and garden irrigation. An average of 4 persons was assumed for each house. The reuse per house was adopted from SCA MUSIC Manual Table 5.4. The reuse adopted for each lot is shown in Table 15.

Rainwater Reuse				
Internal (kL/yr/dwelling)	343			
External (kL/yr/dwelling)	55			
Total (kL/yr/dwelling)	398			

Table 15: Rainwater	Tank Reuse (per lot)
---------------------	--------------	----------

• Ecosol GPTs are proposed to be installed at all pipe outlets. The GPTs remove gross pollutants, sediment and attached nutrients. The MUSIC node for the GPT was provided by Ecosol. The removal efficiencies have been confirmed via independent testing. An equivalent product could be used. The



flows to the GPT will be limited to the 50% of the peak 63.2% AEP storm in accordance with SCA MUSIC Manual Table 5.5. Table 16 shows the removal efficiencies of the Ecosol GPT.

Table 16. ECOSOI GPT Removal Elliciencies	Table 16:	Ecosol GPT	Removal	Efficiencies
---	-----------	------------	---------	--------------

Gross Pollutant Removal (%)	TSS Removal (%)	TP Removal (%)	TN Removal (%)
98	61	29	1

Bioretention Basins are the final part of the treatment train for this development. Three bioretention basin
are proposed to be provided. Bioretention systems remove sediments (TSS) as well as nutrients (TN and
TP) from the stormwater. The bioretention basin consists of a shallow dry basin with deep rooted
vegetation and grass on the surface, over an infiltration/filtration area and an underdrain area.

Vegetation in the bioretention basins will be in accordance with Upper Hunter Shire Council requirements.

To avoid potential salinity problems, an impermeable HDPE liner is to be provided in the bioretention basins to prevent any water infiltrating into the surrounding basin areas.

The MUSIC inputs for the four bioretention basins are shown in Table 17.

	Basin 1	Basin 2	Basin 3	Basin 4
Extended Detention Depth (m)	0.3	0.3	0.3	0.3
Surface Area (m2)	1800	480	5000	480
Filter Area (m2)	1500	400	4500	400
Unlined Filter Material (m)	80	80	80	80
Saturated Hydraulic Conductivity (mm/hr)	100	100	100	100
Filter Depth (m)	0.4	0.4	0.4	0.4
TN Content of Filter Media (mg/kg)	800	800	800	800
Orthophosphate of Filter Media (mg/kg)	55	55	55	55
Exfiltration Rate (mm/hr)	0	0	0	0
Base Lined	Yes	Yes	Yes	Yes
Vegetation Removing Plants	Yes	Yes	Yes	Yes
Under Drain Present	Yes	Yes	Yes	Yes

Table 17: Bioretention Basin MUSIC Model Inputs

5.2.2.8 Stormwater Quality Modelling Results

The mean annual pollutant loads from the MUSIC model for the pre-existing site (forest), predeveloped site (agricultural) and the post developed site (residential subdivision) are shown in Table 18.



	Mean Annual Pollutant Loads					
	Pre-existing Forest	Predeveloped Agricultural	Post developed Residential Subdivision			
TSS (kg/yr.)	3320	13700	1270			
TP (kg/yr.)	6.75	57.3	12.6			
TN (kg/yr.)	77.3	268	104			
Gross Pollutants (kg/yr.)	3120	3120	497			

Table 18: Mean Annual Pollutant Loads

For the post developed (residential subdivision), the Mean Annual Pollutant Loads for TSS have been reduced below the pre-existing conditions (forest), but the TP and TN could not be reduced with the proposed treatment train.

The Mean Annual Loads for the post developed site have been reduced to below the predeveloped site conditions (agriculture) as shown in Table 18.

Most councils within the Hunter provide targets for the pollutant reductions for TSS, TP and TN. For example, the reductions in the average annual loads for Maitland Council are 85% for TSS, 45% for TP and 45% for TN.

Table 19 below shows the reductions achieved in the average annual loads for the total proposed development, and hence the effectiveness of the proposed treatment train. The percentage reductions are higher than required for most councils in the Hunter.

	Source Mean Annual Load	Residual Mean Annual Load	% Developed Reduction
TSS (kg/yr.)	17100	1270	92.6
TP (kg/yr.)	34.2	12.6	63.3
TN (kg/yr.)	288	104	63.8
Gross Pollutants (kg/yr.)	4650	497	89.3

Table 19: MUSIC Model Treatment Train Effectiveness - Total Site

Table 20 below shows the reductions achieved in the average annual loads for the proposed development at the western boundary outlet, and hence the effectiveness of the proposed treatment train. The percentage reductions are higher than required for most councils in the Hunter.

Table 20: MUSIC Mod	el Treatment Trair	Fffectiveness — At	Western F	Roundary	Outlet
			VVC3lCIII L	Journaary	Juliel

	Source Mean Annual Load	Residual Mean Annual Load	% Developed Reduction
TSS (kg/yr.)	15300	1160	92.4
TP (kg/yr.)	30.7	11.3	63.4
TN (kg/yr.)	259	92.7	64.2
Gross Pollutants (kg/yr.)	4210	497	88.2



Table 21 below shows the reductions achieved in the average annual loads for the proposed development at the south west boundary outlet, and hence the effectiveness of the proposed treatment train. The percentage reductions are higher than required for most councils in the Hunter.

	Source Mean Annual Load	Residual Mean Annual Load	% Developed Reduction
TSS (kg/yr.)	1780	105	94.1
TP (kg/yr.)	3.51	1.3	62.8
TN (kg/yr.)	28.9	11.3	60.9
Gross Pollutants (kg/yr.)	437	0	100

Table 21: MUSIC Model Treatment Train Effectiveness – At South West Boundary Outlet

The results of the MUSIC modelling show that the proposed water quality treatments sufficiently reduce the pollutants to an acceptable level. The MUSIC modelling summary report detailing the inputs and results are shown in Appendix B.

5.3 Construction Phase Water Quality Management

5.3.1 General

During the construction phase of the development, an Erosion and Sediment Control Plan will be implemented to minimise the water quality impacts. The erosion and sediment controls will be in accordance with Landcom's Managing Urban Stormwater: Soils and Construction Volume 1, 4th Edition (Landcom, 2004) and the requirements of UHSC. Erosion and sediment controls will be required preconstruction, during construction and post construction until the site is stabilized. The expected erosion and sediment control measures will include stabilized site access, sediment fence, gully pit sediment barriers, rock outlet scour protection and a temporary sediment basin. Erosion and sediment control plans will be provided for the development at the Construction Certificate stage.

5.3.2 Pre-Construction Erosion and Sediment Control

Due to the topography of the site, the preconstruction erosion and sediment controls will be limited to stabilized site access, sediment fence and a temporary sediment basin until the initial bulk earthworks is undertaken. The proposed water quality basins will be used as a sediment basin while construction is being undertaken.

5.3.3 During Construction Erosion and Sediment Control

During the construction phase of the development, the erosion and sediment controls will consist of installed sediment fence, a constructed sediment basin, gully pit sediment barriers and permanent rock outlet scour protection.

Regular inspection and maintenance of the erosion and sediment controls is required during the construction process.

5.3.4 Post Construction Erosion and Sediment Control

The contractor/developer will be responsible for the maintenance of the erosion and sediment control devices from the practical completion of the works for a minimum of 6 months or until stabilization has occurred to the satisfaction of Council.

It is standard practice to delay the construction of the bioretention filtration media in the basin until a significant proportion of the contributing lots are built on and established.



6 Conclusion

The catchment wide modelling undertaken using DRAINS has shown that stormwater detention is not required for the proposed development. Due to the large upstream catchments draining through the existing stream traversing the development site, the post developed flows at the downstream boundary are generally below the predeveloped flows. The proposed installation of the reinforced box culverts under the road crossing between the northern and southern sections of the subdivision also provide some control to the post development flows downstream.

The MUSIC modelling undertaken has shown that the proposed treatment train of rainwater tanks, GPTs and bioretention basins has sufficiently reduced the mean annual pollutants loads from the proposed development. The bioretention basin configuration, levels and inlet/outlet details will need to be confirmed at the Construction Certificate design stage.

During the construction phase of the development, an Erosion and Sediment Control Plan will be implemented to minimise the water quality impacts. Erosion and Sediment Control Plans and details will need to be prepared at the Construction Certificate design stage.



7 **FIGURES**



SC/	ALE 1:2500 @ A1 ALE 1:5000 @ A3	0	25	50	100	150	200	250 metres		
C COPY	RIGHT of this desig st not be used, mod	n and p dified, r	olan is t reprodu	he property iced or copie	of ACOR Consu ed wholly or in p	ltants Pty Ltd, AC part without writ	N 079 306 246 ten permission	ABN 40 079 306 246, al from ACOR Consultants	l rights reserved. S Pty Ltd.	
This drawin	g has been assigned an	electron	iic code t	hat signifies the	drawing has been	checked and approve	d by: NAME&CI	REDENTIALS		
С	BASIN 3 MOVED								11.0	03.22
В	ISSUED FOR APP	ROVA	L						19.0	08.21
А	ISSUED FOR CLI	ENT RE	EVIEW						21.0	03.21

			North
.03.22	ADS	UK	
9.08.21	ADS	UK	
.03.21	ADS	UK	K 1 7
Date	Drawn	Approved	
		20cm	4

CHARLES DAVID PTY LTD



ACOR Consultants Pty Ltd Level 1, 54 Union Street Cooks Hill, Newcastle NSW 2300 T +61 2 4926 4811 Cooks Hill, Newcastle NSW 2300 T +61 2 4926 4811 Cooks Hill, Newcastle NSW 2300 C + 61 2 4926 4811 C + 61 2 4926 4811

DO NOT REPRODUCE IN GREYSCALE

NOT FOR CONSTRUCTION

Drawing Title LOCALITY PLAN

Drawn	Date	Scale	A1	Q.A. Check		Date
ADS	MAR 2021	1:2500		UK	12	2.03.21
Designed	Project No.			Dwg. No.		Issue
UK	NSV	V2027	32	FIGURE 1		С



		5	
DO NOT REPRODUCE	E IN GREYS	SCALE NOT FOR CO	ONSTRUCTION
R MANAGEMENT PLAN	EXISTING SIT	E TOPOGRAPHY	O.A. Charle Prote
	ADS Designed	Date Scale A1 MAR 2021 1:2500 1:2500 Project No. NISW/202722 1:2500	U.A. CRECK Date UK 12.03.21 Dwg. No. Issue

Issue C



CCALE 1-5000 @ 41	0	50	100	200	300	400	500 metres
SCALE 1:5000 @ A1	The second second	and the second second					-
SCALE 1:10000 @ A3							-
COPYRIGHT of this design	n and pl	lan is th	e property of A	COR Consultants	Ptv Ltd. ACN 0	79 306 246 ABN	40 079 306 246. a

all rights re and plan is the property of ACOR Consultants Pty Ltd, ACN 079 306 246 ABN 40 079 306 246, all rights fied, reproduced or copied wholly or in part without written permission from ACOR Consultants Pty Ltc

This drawin	wing has been assigned an electronic code that signifies the drawing has been checked and approved by: NAME&CRI	DENTIALS	
С	BASIN 3 MOVED		
В	ISSUED FOR APPROVAL		
А	ISSUED FOR CLIENT REVIEW		
C B A	BASIN 3 MOVED ISSUED FOR APPROVAL ISSUED FOR CLIENT REVIEW		

			IVOLUT
11.03.22	ADS	UK	
19.08.21	ADS	UK	
21.03.21	ADS	UK	۲ (
Date	Drawn	Approved	
		20cm	-

CHARLES DAVID PTY LTD



ACOR Consultants Pty Ltd Level 1, 54 Union Street Cooks Hill, Newcastle NSW 2300 T +61 2 4926 4811 Cooks Hill, Newcastle NSW 2300 T +61 2 4926 4811 Cooks Hill, Newcastle NSW 2300 C + 61 2 4926 4811 C + 61 2 4926 4811



Drawing Title PREDEVELOPED CATCHMENT PLAN

Drawn	Date	Scale	A1	Q.A. Check		Date
ADS	MAR 2021	1:2500		UK	12	2.03.21
Designed	Project No.			Dwg. No.		Issue
UK	NSV	V2027	32	FIGURE 3		С



This dra	ving has been assigned an electronic code that signifies the drawing has been checked and approved by: NAME&CREDENTIALS					Client	
D	BASIN 3 MOVED	11.03.22	ADS	UK	North	CHARLES DAVID PTY LTD	I A .
C	RE-ISSUED FOR APPROVAL	15.02.22	ADS	UK			
В	LOT BOUNDARIES UPDATED, ISSUED FOR CLIENT REVIEW	19.08.21	ADS	UK			
A	ISSUED FOR CLIENT REVIEW	21.03.21	ADS	UK] []]		
Issue	Description	Date	Drawn	Approved	$1 \setminus $		
4	1 tcm at full size			20cm			CONSULTA





le le	It must	t not be used, modified, reproduced or copied wholly or in part without written permission from ACOR Consultants Fty Ltd.	eu.						
Th	is drawing	has been assigned an electronic code that signifies the drawing has been checked and approved by: NAME&CREDENTIALS					Client	ACOR Consultants Pty Ltd	Project
	DI	BASIN 3 MOVED	11.03.22	2 ADS	UK	North	CHARLES DAVID PTY LTD	Level 1, 54 Union Street	STORMWATE
	C	RE-ISSUED FOR APPROVAL	15.02.22	2 ADS	UK			Cooks Hill, Newcastle NSW 2300	
	B	ISSUED FOR APPROVAL	19.08.21	1 ADS	UK			T +61 2 4926 4811	
	A	NOT ISSUED	-	-	-] []]			LOT 2, DP1169320
Is	ue	Description	Date	Drawn	Approved	$ \setminus /$			GUNDY ROAD, SCONE
1	P	Icm al full size	-		20cm		CONSU	JANTS ENGINEERS MANAGERS INFRASTRUCTURE PLANNERS DEVELOPMENT CONSULTANTS	



CONSULTANTS

A NOT ISSUED

Description

Date

DO NOT REPRODUCE	E IN GREYS	SCALE	NOT FOR CO	ONSTRUCT	10
NAGEMENT PLAN	Drawing Title STORMWATE	R MANAGEMEN	NT PLAN		
	Drawn ADS	Date MAR 2021	Scale A1 1:1000	Q.A. Check UK	1

Designed UK

LOT 2, DP1169320

GUNDY ROAD, SCONE

Issue D

Dwg. No

NSW202732 FIGURE 6



Drawn	Date	Scale	A1	Q.A. Check		Date
ADS	MAR 2021	1:1000		UK	12	2.03.21
Designed	Project No.			Dwg. No.		Issue
UK	NSV	V2027	32	FIGURE 7		D



Appendix A - DRAINS Modelling Inputs and Results

Australian Rainfall & Runoff Data Hub - Results

Input Data

Longitude	150.881
Latitude	-32.061
Selected Regions (clear)	
River Region	show
ARF Parameters	show
Storm Losses	show
Temporal Patterns	show
Areal Temporal Patterns	show
BOM IFDs	show
Median Preburst Depths and Ratios	show
10% Preburst Depths	show
25% Preburst Depths	show
75% Preburst Depths	show
90% Preburst Depths	show
Interim Climate Change Factors	show
Probability Neutral Burst Initial Loss (./nsw_specific)	show
Baseflow Factors	show

show





Data

River Region

Division	South East Coast (NSW)	
River Number	10	
River Name	Hunter River	
Layer Info		
Time Accessed	28 April 2021 11:17AM	
Version	2016_v1	

ARF Parameters

$$egin{aligned} ARF &= Min \left\{ 1, \left[1-a \left(Area^b - c \mathrm{log}_{10} Duration
ight) Duration^{-d}
ight. \ &+ eArea^f Duration^g \left(0.3 + \mathrm{log}_{10} AEP
ight)
ight. \ &+ h10^{iArea rac{Duration}{1440}} \left(0.3 + \mathrm{log}_{10} AEP
ight)
ight]
ight\} \end{aligned}$$

Zone	а	b	С	d	е	f	g	h	i
SE Coast	0.06	0.361	0.0	0.317	8.11e-05	0.651	0.0	0.0	0.0

Short Duration ARF

$$egin{aligned} ARF &= Min \left[1, 1 - 0.287 \left(Area^{0.265} - 0.439 ext{log}_{10}(Duration)
ight) . Duration^{-0.366} \ &+ 2.26 ext{ x } 10^{-3} ext{ x } Area^{0.226} . Duration^{0.125} \left(0.3 + ext{log}_{10}(AEP)
ight) \ &+ 0.0141 ext{ x } Area^{0.213} ext{ x } 10^{-0.021} rac{(Duration - 180)^2}{1440} \left(0.3 + ext{log}_{10}(AEP)
ight)
ight] \end{aligned}$$

Layer Info

Time Accessed	28 April 2021 11:17AM

Version

2016_v1

Storm Losses

Note: Burst Loss = Storm Loss - Preburst

Note: These losses are only for rural use and are **NOT FOR DIRECT USE** in urban areas

Note: As this point is in NSW the advice provided on losses and pre-burst on the NSW Specific Tab of the ARR Data Hub (./nsw_specific) is to be considered. In NSW losses are derived considering a hierarchy of approaches depending on the available loss information. The continuing storm loss information from the ARR Datahub provided below should only be used where relevant under the loss hierarchy (level 5) and where used is to be multiplied by the factor of 0.4.

ID		1819.0
Storm Initial Losses (mn	n)	34.0
Storm Continuing Losse	₂s (mm/h)	1.5
Layer Info		
Time Accessed	28 April 2021 11:17AM	1
Version	2016_v1	
Temporal Patterns D	Download (.zip) (static/temporal_pati	terns/TP/ECsouth.zip)
code	ECsouth	
Label	East Coast South	
Layer Info		
Time Accessed	28 April 2021 11:17AM	1
Version	2016_v2	
Areal Temporal Patte (./static/temporal_pat	rns Download (.zip) terns/Areal/Areal_ECsouth.zip)	
code	ECsouth	
arealabel	East Coast South	
Layer Info		
Time Accessed	28 April 2021 11:17AM	1

BOM IFDs

Click here (http://www.bom.gov.au/water/designRainfalls/revised-ifd/? year=2016&coordinate_type=dd&latitude=-32.061&longitude=150.881&sdmin=true&sdhr=true&sdday=true&user_label=) to obtain the IFD depths for catchment centroid from the BoM website

Layer Info

Time Accessed

28 April 2021 11:17AM

Median Preburst Depths and Ratios

Values are of the format depth (ratio) with depth in mm

min (h)\AEP(%)	50	20	10	5	2	1
60 (1.0)	0.8	0.9	1.0	1.0	0.8	0.7
	(0.039)	(0.031)	(0.028)	(0.025)	(0.018)	(0.014)
90 (1.5)	0.2	0.4	0.4	0.5	0.4	0.3
	(0.009)	(0.011)	(0.012)	(0.012)	(0.008)	(0.006)
120 (2.0)	1.1	0.8	0.6	0.4	0.5	0.5
	(0.042)	(0.023)	(0.014)	(0.008)	(0.009)	(0.009)
180 (3.0)	1.9	1.4	1.0	0.7	0.5	0.5
	(0.063)	(0.034)	(0.022)	(0.012)	(0.009)	(0.007)
360 (6.0)	0.2	2.4	3.8	5.2	6.5	7.5
	(0.005)	(0.048)	(0.066)	(0.079)	(0.084)	(0.086)
720 (12.0)	0.0	0.7	1.1	1.5	4.6	6.8
	(0.000)	(0.010)	(0.015)	(0.018)	(0.045)	(0.060)
1080 (18.0)	0.0	1.6	2.6	3.6	7.6	10.6
	(0.000)	(0.021)	(0.030)	(0.036)	(0.064)	(0.079)
1440 (24.0)	0.0	0.5	0.8	1.0	6.8	11.1
	(0.000)	(0.005)	(0.008)	(0.009)	(0.050)	(0.072)
2160 (36.0)	0.0	0.5	0.8	1.1	3.0	4.4
	(0.000)	(0.005)	(0.007)	(0.008)	(0.019)	(0.024)
2880 (48.0)	0.0	0.0	0.0	0.0	0.0	0.0
	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)
4320 (72.0)	0.0	0.0	0.0	0.0	0.0	0.0
	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)

Time Accessed	28 April 2021 11:17AM
Version	2018_v1
Note	Preburst interpolation methods for catchment wide preburst has been slightly altered. Point values remain unchanged.

10% Preburst Depths

Values are of the format depth (ratio) with depth in mm

min (h)\AEP(%)	50	20	10	5	2	1
60 (1.0)	0.0	0.0	0.0	0.0	0.0	0.0
	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)
90 (1.5)	0.0	0.0	0.0	0.0	0.0	0.0
	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)
120 (2.0)	0.0	0.0	0.0	0.0	0.0	0.0
	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)
180 (3.0)	0.0	0.0	0.0	0.0	0.0	0.0
	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)
360 (6.0)	0.0	0.0	0.0	0.0	0.0	0.0
	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)
720 (12.0)	0.0	0.0	0.0	0.0	0.0	0.0
	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)
1080 (18.0)	0.0	0.0	0.0	0.0	0.0	0.0
	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)
1440 (24.0)	0.0	0.0	0.0	0.0	0.0	0.0
	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)
2160 (36.0)	0.0	0.0	0.0	0.0	0.0	0.0
	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)
2880 (48.0)	0.0	0.0	0.0	0.0	0.0	0.0
	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)
4320 (72.0)	0.0	0.0	0.0	0.0	0.0	0.0
	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)

Layer Info

 Time
 28 April 2021 11:17AM

 Accessed
 Control

Version	2018_v1
Note	Preburst interpolation methods for catchment wide preburst has been slightly altered. Point values remain unchanged.

25% Preburst Depths

Values are of the format depth (ratio) with depth in mm

min (h)\AEP(%)	50	20	10	5	2	1
60 (1.0)	0.0	0.0	0.0	0.0	0.0	0.0
	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)
90 (1.5)	0.0	0.0	0.0	0.0	0.0	0.0
	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)
120 (2.0)	0.0	0.0	0.0	0.0	0.0	0.0
	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)
180 (3.0)	0.0	0.0	0.0	0.0	0.0	0.0
	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)
360 (6.0)	0.0	0.0	0.0	0.0	0.0	0.0
	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)
720 (12.0)	0.0	0.0	0.0	0.0	0.0	0.0
	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)
1080 (18.0)	0.0	0.0	0.0	0.0	0.0	0.0
	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)
1440 (24.0)	0.0	0.0	0.0	0.0	0.0	0.0
	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)
2160 (36.0)	0.0	0.0	0.0	0.0	0.0	0.0
	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)
2880 (48.0)	0.0	0.0	0.0	0.0	0.0	0.0
	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)
4320 (72.0)	0.0	0.0	0.0	0.0	0.0	0.0
	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)	(0.000)

Time Accessed	28 April 2021 11:17AM
Version	2018_v1

Note Preburst interpolation methods for catchment wide preburst has been slightly altered. Point values remain unchanged.

75% Preburst Depths

Values are of the format depth (ratio) with depth in mm

min (h)\AEP(%)	50	20	10	5	2	1
60 (1.0)	12.6	13.3	13.8	14.2	10.0	6.8
	(0.582)	(0.458)	(0.402)	(0.360)	(0.215)	(0.131)
90 (1.5)	13.7	12.2	11.2	10.2	11.6	12.6
	(0.558)	(0.374)	(0.292)	(0.233)	(0.224)	(0.218)
120 (2.0)	12.6	12.7	12.8	12.9	15.7	17.7
	(0.471)	(0.360)	(0.310)	(0.273)	(0.282)	(0.286)
180 (3.0)	12.8	14.3	15.3	16.2	15.5	14.9
	(0.424)	(0.360)	(0.330)	(0.306)	(0.250)	(0.216)
360 (6.0)	8.9	15.5	19.9	24.1	37.3	47.2
	(0.236)	(0.315)	(0.346)	(0.366)	(0.483)	(0.546)
720 (12.0)	10.6	18.2	23.2	28.0	30.1	31.6
	(0.221)	(0.288)	(0.313)	(0.328)	(0.298)	(0.278)
1080 (18.0)	1.5	11.8	18.5	25.0	37.8	47.3
	(0.028)	(0.159)	(0.213)	(0.249)	(0.315)	(0.349)
1440 (24.0)	1.6	7.3	11.1	14.8	27.5	37.1
	(0.027)	(0.089)	(0.114)	(0.130)	(0.203)	(0.241)
2160 (36.0)	0.0	4.9	8.1	11.2	16.9	21.1
	(0.000)	(0.051)	(0.071)	(0.084)	(0.105)	(0.116)
2880 (48.0)	0.0	2.5	4.2	5.8	7.6	8.9
	(0.000)	(0.024)	(0.033)	(0.039)	(0.042)	(0.044)
4320 (72.0)	0.0	0.2	0.4	0.5	2.8	4.5
	(0.000)	(0.002)	(0.003)	(0.003)	(0.014)	(0.019)

Time Accessed	28 April 2021 11:17AM
Version	2018_v1
Note	Preburst interpolation methods for catchment wide preburst has been slightly altered. Point values remain unchanged.

90% Preburst Depths

Values are of the format depth (ratio) with depth in mm

min (h)\AEP(%)	50	20	10	5	2	1
60 (1.0)	29.9	35.3	38.8	42.2	35.3	30.2
	(1.378)	(1.214)	(1.133)	(1.070)	(0.760)	(0.579)
90 (1.5)	32.3	35.9	38.3	40.6	40.1	39.7
	(1.315)	(1.101)	(1.000)	(0.924)	(0.776)	(0.688)
120 (2.0)	36.5	39.2	41.0	42.7	50.9	57.0
	(1.367)	(1.110)	(0.991)	(0.901)	(0.916)	(0.920)
180 (3.0)	33.2	36.1	38.0	39.8	58.8	72.9
	(1.101)	(0.910)	(0.820)	(0.751)	(0.947)	(1.054)
360 (6.0)	28.3	36.9	42.6	48.1	76.9	98.4
	(0.751)	(0.749)	(0.741)	(0.730)	(0.994)	(1.138)
720 (12.0)	24.0	48.3	64.5	79.9	71.5	65.2
	(0.500)	(0.765)	(0.870)	(0.937)	(0.707)	(0.573)
1080 (18.0)	15.4	32.1	43.2	53.8	87.2	112.2
	(0.279)	(0.435)	(0.496)	(0.534)	(0.727)	(0.828)
1440 (24.0)	15.6	28.8	37.6	45.9	66.2	81.3
	(0.255)	(0.350)	(0.385)	(0.406)	(0.488)	(0.529)
2160 (36.0)	15.3	28.5	37.1	45.5	55.0	62.1
	(0.219)	(0.297)	(0.325)	(0.342)	(0.343)	(0.341)
2880 (48.0)	0.2	9.9	16.3	22.4	33.0	40.8
	(0.002)	(0.093)	(0.129)	(0.152)	(0.185)	(0.201)
4320 (72.0)	2.1	6.6	9.5	12.3	22.4	29.9
	(0.025)	(0.056)	(0.067)	(0.074)	(0.111)	(0.129)

Time Accessed	28 April 2021 11:17AM
Version	2018_v1
Note	Preburst interpolation methods for catchment wide preburst has been slightly altered. Point values remain unchanged.

Interim Climate Change Factors

	RCP 4.5	RCP6	RCP 8.5
2030	0.869 (4.3%)	0.783 (3.9%)	0.983 (4.9%)
2040	1.057 (5.3%)	1.014 (5.1%)	1.349 (6.8%)
2050	1.272 (6.4%)	1.236 (6.2%)	1.773 (9.0%)
2060	1.488 (7.5%)	1.458 (7.4%)	2.237 (11.5%)
2070	1.676 (8.5%)	1.691 (8.6%)	2.722 (14.2%)
2080	1.810 (9.2%)	1.944 (9.9%)	3.209 (16.9%)
2090	1.862 (9.5%)	2.227 (11.5%)	3.679 (19.7%)

Layer Info

Time Accessed	28 April 2021 11:18AM
Version	2019_v1
Note	ARR recommends the use of RCP4.5 and RCP 8.5 values. These have been updated to the values

that can be found on the climate change in Australia website.

Probability Neutral Burst Initial Loss

min (h)\AEP(%)	50.0	20.0	10.0	5.0	2.0	1.0
60 (1.0)	21.5	11.3	10.3	10.6	10.8	10.1
90 (1.5)	21.4	11.8	10.9	11.5	11.5	9.5
120 (2.0)	20.9	11.9	11.1	11.4	10.3	8.3
180 (3.0)	20.9	12.7	11.5	12.0	10.1	9.1
360 (6.0)	21.8	13.9	11.6	11.0	9.6	4.3
720 (12.0)	22.3	15.0	13.3	12.7	11.7	7.8
1080 (18.0)	25.3	18.0	16.0	14.1	12.4	6.1
1440 (24.0)	25.7	19.6	18.7	17.8	14.4	8.4
2160 (36.0)	26.7	20.8	20.2	19.2	18.0	8.9
2880 (48.0)	29.8	25.1	24.1	25.9	21.5	11.6
4320 (72.0)	30.1	26.3	26.7	29.9	24.4	15.2

Layer Info

Time Accessed	28 April 2021 11:18AM
Version	2018_v1
Note	As this point is in NSW the advice provided on losses and pre-burst on the NSW Specific Tab of the ARR Data Hub (./nsw_specific) is to be considered. In NSW losses are derived considering a hierarchy of approaches depending on the available loss information. Probability neutral burst initial loss values for NSW are to be used in place of the standard initial loss and pre-burst as per the losses hierarchy.

Baseflow Factors

Downstream	9596		
Area (km2)	782.601152		
Catchment Number	9422		
Volume Factor	0.168431		
Peak Factor	0.02334		
Layer Info			
Time Accessed	28 April 2021 11:18AM		
Version	2016_v1		
Download TXT (downloads/fa902ff3-4ff8-4c9e-b95a-5fecb90d8ccd.txt)			
Download JSON (downloads/d3	30aa547-b72d-4ea2-9267-8a585922734d.json)		
Generating PDF (downloads/e	ee57cd19-1454-4809-bcd3-c6dfb3f41e88.pdf)		

DRAINS PREDEVELOPED SCHEMATICS







DRAINS POST DEVELOPED SCHEMATICS



























Appendix B - MUSIC Modelling Report

\\192.168.2.1\Synergy\Projects\NSW20\NSW202732\Reports\CIV\NSW202732_R01.03_Stormwater Management Report.docx

SCONE SUBDIVISION NSW202732 MUSIC MODEL SCHEMATIC - 11 MARCH 2022



SCONE SUBDIVISION NSW202732 MUSIC MODEL REPORT - 11 MARCH 2022

Source nodes Location, PreDev - Forest - West - 48.752 ha, Area 1 - Road - 1.67 ha, Area 1 - Roof - 1.75 ha, Area 1 - Lot - 3.834 ha, Area 2 - Road - 2.585 ha, Area 3 - Road - 6.336 ha, Area 3 - Roof (to GPT) - 4.875ha, Area 2 - Roof - 1.4 ha, Area 3 - Lot (to GPT) - 10.172ha, Area 2 - Lot - 3.541ha, Area 4 - Lot -2.516 ha, Area 4 - Roof - 0.875 ha, Area 4 - Road - 1.097ha, Agricultural -West - 48.752 ha, Area 2 - Park/Open Space - 0.445ha, Area 3 - Park -1.076ha, Area 4 - Park/Open Space - 0.455ha, PreDev - Forest - South West -9.217 ha, Agricultural - South West - 9.217 ha, Undeveloped - 12.312ha, Area 3 - Roof - 0.7ha, Area 3 - Lot - 2.239ha ID,1,2,3,4,7,8,9,10,11,12,19,20,21,27,33,34,36,39,40,41,42,44 Node Type, ForestSourceNode, UrbanSourceNode, UrbanSourceNode, UrbanSourceNode, Urb anSourceNode, UrbanSourceNode, UrbanSourceNode, UrbanSourceNode, UrbanSourceN ode, UrbanSourceNode, UrbanSourceNode, UrbanSourceNode, UrbanSourceNode, Agric ulturalSourceNode,UrbanSourceNode,UrbanSourceNode,UrbanSourceNode,ForestS ourceNode, AgriculturalSourceNode, ForestSourceNode, UrbanSourceNode, UrbanSo urceNode Zoning Surface Type,,Mixed,Roof,Residential,Mixed,Mixed,Roof,Roof,Residential,Residentia l, Residential, Roof, Mixed, , Mixed, Mixed, Mixed, , , , Roof, Residential Total Area (ha),48.752,1.67,1.75,3.834,2.585,6.336,4.875,1.4,10.172,3.541,2.516,0.87 5,1.097,48.752,0.445,1.076,0.455,9.217,9.217,9.217,0.7,2.239 Area Impervious (ha),16.9031188059702,1.33219888059701,1.75,2.47579119402985,2.0718582089 5522,5.05437850746269,4.875,1.4,6.64520059701493,2.29993235074627,1.64366 149253731,0.875,0.879237313432836,16.843088358209,0.177219589552239,0.428 512985074627,0.181202052238806,3.1956852238806,3.18433593283582,3.1956852 238806,0.7,1.46270194029851 Area Pervious (ha),31.8488811940299,0.337801119402985,0,1.35820880597015,0.513141791044 776,1.28162149253731,0,0,3.52679940298508,1.24106764925373,0.872338507462 686,0,0.217762686567164,31.908911641791,0.267780410447761,0.6474870149253 73,0.273797947761194,6.0213147761194,6.03266406716418,6.0213147761194,0,0 .776298059701493 Field Capacity Pervious Area Infiltration Capacity coefficient -,135,135,135,135 Pervious Area Infiltration Capacity exponent b,4,4,3.5,1,4,4,3.5,3.5,1,1,1,4,4,4,1,1,1,4,4,4,3.5,1 Impervious Area Rainfall Threshold (mm/day),1,1,0.3,1,1,1,0.3,0.3,1,1,1,0.3,1,1,1,1,1,1,1,1,1,0.3,1 Pervious Area Soil Storage Capacity Pervious Area Soil Initial Storage (% of 25 Groundwater Initial Depth Groundwater Daily Recharge Rate

Groundwater Daily Baseflow Rate Groundwater Daily Deep Seepage Rate Stormflow Total Suspended Solids Mean (log mg/L),1.6,2.2,1.3,2.15,2.2,2.2,1.3,1.3,2.15,2.15,2.15,1.3,2.2,2.15,2.2,2. 2,2.2,1.6,2.15,1.6,1.3,2.15 Stormflow Total Suspended Solids Standard Deviation (log 1,0.32,0.32,0.32,0.2,0.31,0.2,0.32,0.32 Stormflow Total Suspended Solids Estimation Method, Stochastic, Stocha tic, Stochastic, Stochastic, Stochastic, Stochastic, Stochastic, Sto chastic, Stochastic, Stochastic Stormflow Total Suspended Solids Serial Stormflow Total Phosphorus Mean (log mg/L), -1.1, -0.45, -0.89, -0.6, -0.45, -0.45,-0.89,-0.89,-0.6,-0.6,-0.6,-0.89,-0.45,-0.22,-0.45,-0.45,-0.45,-1.1,-0.22,-1.1,-0.89,-0.6 Stormflow Total Phosphorus Standard Deviation (log 3,0.25,0.25,0.25,0.22,0.3,0.22,0.25,0.25 Stormflow Total Phosphorus Estimation Method, Stochastic, Stocha tic, Stochastic, Stochastic, Stochastic, Stochastic, Stochastic, Sto chastic, Stochastic, Stochastic Stormflow Total Phosphorus Serial Stormflow Total Nitrogen Mean (log mg/L),-0.05, 0.42, 0.3, 0.3, 0.42, 0.42, 0.3, 0.3, 0.3, 0.3, 0.3, 0.3, 0.42, 0.48, 0.42, 0.4 .42,-0.05,0.48,-0.05,0.3,0.3 Stormflow Total Nitrogen Standard Deviation (log 26,0.19,0.19,0.19,0.24,0.26,0.24,0.19,0.19 Stormflow Total Nitrogen Estimation Method, Stochastic, Stocha tic, Stochastic, Stochastic, Stochastic, Stochastic, Stochastic, Sto chastic, Stochastic, Stochastic Stormflow Total Nitrogen Serial Baseflow Total Suspended Solids Mean (log mg/L),0.78,1.1,0,1.2,1.1,1.1,0,0,1.2,1.2,1.2,0,1.1,1.3,1.1,1.1,1.1,0.78,1 .3,0.78,0,1.2 Baseflow Total Suspended Solids Standard Deviation (log ,0.17,0.13,0.13,0.13,0,0.17 Baseflow Total Suspended Solids Estimation Method, Stochastic, Stocha tic, Stochastic, Stochastic, Stochastic, Stochastic, Stochastic, Sto chastic, Stochastic, Stochastic Baseflow Total Suspended Solids Serial

Baseflow Total Phosphorus Mean (log mg/L), -1.52, -0.82, 0, -0.85, -0.82, -0.82,0,0,-0.85,-0.85,-0.85,0,-0.82,-1.05,-0.82,-0.82,-0.82,-1.52,-1.05,-1.52,0,-0.85 Baseflow Total Phosphorus Standard Deviation (log ,0.19,0.13,0.13,0.13,0,0.19 Baseflow Total Phosphorus Estimation Method, Stochastic, Stocha tic, Stochastic, Stochastic, Stochastic, Stochastic, Stochastic, Sto chastic, Stochastic, Stochastic Baseflow Total Phosphorus Serial Baseflow Total Nitrogen Mean (log mg/L), -0.52,0.32,0,0.11,0.32,0.32,0,0,0.11,0.11,0.11,0,0.32,0.04,0.32,0.32,0.32, -0.52,0.04,-0.52,0,0.11 Baseflow Total Nitrogen Standard Deviation (log ,0.12,0.13,0.13,0.13,0,0.12 Baseflow Total Nitrogen Estimation Method, Stochastic, Stocha tic, Stochastic, Stochastic, Stochastic, Stochastic, Stochastic, Sto chastic, Stochastic, Stochastic Baseflow Total Nitrogen Serial Flow based constituent generation -ff,Off,Off,Off,Off,Off Flow based constituent generation - base flow column, , , , , , , , , , , , Flow based constituent generation - pervious flow column, , , , , , , , , Flow based constituent generation - impervious flow column, , , , , , , , OUT - Mean Annual Flow (ML/yr), 63.6, 4.36, 6.19, 8.25, 6.75, 16.6, 17.2, 4.95, 21.9, 7.62, 5.42, 3.09, 2.87, 63.6,0.610,1.47,0.623,12.0,12.0,12.0,2.47,4.82 OUT - TSS Mean Annual Load (kg/yr), 2.80E3, 903, 164, 1.48E3, 1.40E3, 3.47E3, 447, 130, 4.02E3, 1.39E3, 982, 80. 9,597,11.5E3,120,288,122,526,2.17E3,526,65.1,883 OUT - TP Mean Annual Load (kg/yr), 5.67, 1.82, 0.943, 2.44, 2.83, 6.89, 2.61, 0.757, 6.48, 2.23, 1.58, 0.466, 1. 20,48.2,0.247,0.608,0.253,1.08,9.11,1.07,0.376,1.41 OUT - TN Mean Annual Load (kg/yr),64.9,12.6,13.6,18.1,19.5,47.7,37.7,10.8,47.6,16.6,11.9,6.78,8.41, 225,1.74,4.23,1.78,12.4,42.6,12.4,5.43,10.6 OUT - Gross Pollutant Mean Annual Load (kg/yr), 2.63E3, 154, 207, 314, 239, 585, 576, 165, 832, 290, 206, 103, 101, 2.63E3, 26. 4,63.9,27.0,497,497,497,82.7,183 Rain In (ML/yr),180.955,6.19863,6.49556,14.2309,9.59486,23.5177,18.0948,5.19646,3 7.756,13.1433,9.33878,3.24778,4.0718,180.955,1.65173,3.99385,1.68885,34.2 112,34.2112,34.2112,2.59823,8.3106

ET Loss (ML/yr),117.47,1.83636,0.308961,5.98082,2.84251,6.96727,0.860687,0.247169 ,15.8677,5.52374,3.9248,0.154481,1.20628,117.47,1.04318,2.52238,1.06662,2 2.2088,22.2088,22.2088,0.123584,3.49271 Baseflow Out (ML/yr),1.02218,0.0107737,0,0.1272,0.0166767,0.0408757,0,0,0.337475,0.117 479,0.083473,0,0.00707713,1.02218,0.0296695,0.0717401,0.0303362,0.193252, 0.193252,0.193252,0,0.0742829 Imp. Stormflow Out (ML/yr),54.5053,4.26761,6.1866,7.96057,6.60586,16.1914,17.2341,4.94929,21 .1202,7.3522,5.22399,3.0933,2.80334,54.5053,0.568589,1.37483,0.581366,10. 3047,10.3047,10.3047,2.47465,4.64885 Perv. Stormflow Out (ML/yr),8.06286,0.0849826,0,0.166739,0.131545,0.322425,0,0,0.442375,0.153 996,0.10942,0,0.0558239,8.06286,0.0115587,0.0279486,0.0118184,1.52436,1.5 2436,1.52436,0,0.097373 Total Stormflow Out (ML/yr), 62.5682, 4.35259, 6.1866, 8.1273, 6.7374, 16.5138, 17.2341, 4.94929, 21.5 626,7.5062,5.33341,3.0933,2.85916,62.5682,0.580147,1.40278,0.593184,11.82 91,11.8291,11.8291,2.47465,4.74622 Total Outflow (ML/yr), 63.5904, 4.36337, 6.1866, 8.2545, 6.75408, 16.5547, 17.2341, 4.94929, 21. 9,7.62368,5.41688,3.0933,2.86624,63.5904,0.609817,1.47452,0.62352,12.0223 ,12.0223,12.0223,2.47465,4.82051 Change in Soil Storage (ML/yr),-0.105562,-0.00111261,0,-0.00447016,-0.00172223,-0.00422131,0,0,-0.0118598,-0.00412854,-0.00293346,0,-0.000730873,-0.105562,-0.00126145,-0.00305017,-0.00128981,-0.0199575,-0.0199575,-0.0199575,0,-0.0026105 TSS Baseflow Out (kg/yr), 6.43499, 0.14668, 0, 2.17759, 0.226612, 0.556325, 0, 0, 5.75981, 2.01346, 1 .42744,0,0.096455,21.3184,0.402929,0.97527,0.413113,1.2154,4.03043,1.2182 3,0,1.27075 TSS Total Stormflow Out (kg/yr),2792.42,902.601,164.101,1479.93,1400.29,3467.86,447.265,129.582,4 013.68,1387.73,980.772,80.933,596.717,11480.8,119.655,286.615,121.544,524 .438,2170.55,524.66,65.1453,881.898 TSS Total Outflow (kg/yr),2798.85,902.748,164.101,1482.11,1400.52,3468.42,447.265,129.582,4 019.44,1389.74,982.2,80.933,596.813,11502.1,120.058,287.59,121.957,525.65 3,2174.58,525.879,65.1453,883.169 TP Baseflow Out (kg/yr),0.0323165,0.00179412,0,0.0197937,0.00277694,0.00680462,0,0,0.0524 272,0.0182572,0.0129896,0,0.00117881,0.0953331,0.0049463,0.0119475,0.0050 5181,0.00610962,0.0180236,0.00610005,0,0.0115733 TP Total Stormflow Out (kg/yr), 5.63595, 1.81959, 0.942972, 2.42117, 2.82498, 6.8875, 2.60886, 0.756703, 6.43206,2.21493,1.57104,0.466459,1.2009,48.1072,0.241754,0.596219,0.24838 2,1.0753,9.0951,1.06238,0.375533,1.40003 TP Total Outflow (kg/yr), 5.66827, 1.82139, 0.942972, 2.44096, 2.82776, 6.8943, 2.60886, 0.756703, 6.48449,2.23319,1.58403,0.466459,1.20208,48.2026,0.246701,0.608166,0.2534 34,1.08141,9.11312,1.06848,0.375533,1.4116 TN Baseflow Out (kg/yr),0.322507,0.0233755,0,0.170337,0.0361534,0.0886602,0,0,0.451771,0. 157124,0.111768,0,0.0153554,1.17194,0.0644269,0.156011,0.0657409,0.061126 1,0.221565,0.061027,0,0.0993506

TN Total Stormflow Out (kg/yr), 64.5723, 12.541, 13.6482, 17.9775, 19.4903, 47.646, 37.7198, 10.8278, 47. 105, 16.464, 11.8024, 6.78198, 8.39245, 224.112, 1.67876, 4.0701, 1.71751, 12.3095 ,42.3704,12.3139,5.42832,10.4767 TN Total Outflow (kg/yr),64.8948,12.5644,13.6482,18.1478,19.5265,47.7347,37.7198,10.8278,4 7.5568,16.6212,11.9141,6.78198,8.40781,225.284,1.74319,4.22611,1.78326,12 .3706,42.592,12.3749,5.42832,10.5761 GP Total Outflow (kg/yr), 2629.29, 154.151, 206.707, 313.958, 238.611, 584.851, 575.826, 165.366, 8 32.961,289.964,206.029,103.353,101.26,2629.29,26.4839,64.0374,27.079,497. 091,497.091,497.091,82.6828,183.347 No Imported Data Source nodes USTM treatment nodes Location, Area 1 - RWT (70 Lots), Area 3 - RWT (195 Lots), Area 2 - RWT (56 Lots), Area 4 - RWT (34 Lots), Bioretention 2 - 400m2, Bioretention 1 -1500m2, Bioretention 3 - 4500m2, Bioretention 4 - 400m2, Area 3 - RWT (28 Lots) ID, 5, 13, 14, 22, 23, 24, 26, 35, 43 Node Type, RainWaterTankNode, RainWaterTankNode, RainWaterTankNode, RainWaterTankN ode, BioRetentionNodeV4, BioRetentionNodeV4, BioRetentionNodeV4, BioRetention NodeV4, RainWaterTankNode Lo-flow bypass rate (cum/sec),0,0,0,0,0,0,0,0,0 Hi-flow bypass rate (cum/sec),0.35,0.975,0.28,0.175,100,100,100,100,0.14 Inlet pond volume, 0, 0, 0, 0, , , , , 0 Area (sqm), 126, 351, 100.8, 63, 480, 1800, 5000, 480, 50.4 Initial Volume (m^3),0,0,0,0, , , , ,0 Extended detention depth (m), 0.05, 0.05, 0.05, 0.05, 0.3, 0.3, 0.3, 0.3, 0.05 Number of Rainwater tanks, 70, 195, 56, 35, , , , , 28 Permanent Pool Volume (cubic metres), 210, 585, 168, 105, , , , , 84 Proportion vegetated, 0, 0, 0, 0, , , , , 0 Equivalent Pipe Diameter (mm),837,1396,748,592, , , , ,529 Overflow weir width (m), 10, 10, 10, 10, 5, 5, 5, 5, 10 Notional Detention Time (hrs), 4.79E-3, 4.80E-3, 4.80E-3, 4.79E-3, , , , ,4.80E-3 Orifice Discharge Coefficient, 0.6, 0.6, 0.6, 0.6, , , , , 0.6 Number of CSTR Cells, 2, 2, 2, 2, 3, 3, 3, 3, 2 Total Suspended Solids - k (m/yr),400,400,400,400,8000,8000,8000,8000,400 Total Suspended Solids - C* (mg/L), 12, 12, 12, 12, 20, 20, 20, 20, 12 Total Suspended Solids - C** (mg/L),12,12,12,12, , , , , ,12 Total Phosphorus - k (m/yr),300,300,300,300,6000,6000,6000,300 Total Phosphorus - C* (mg/L), 0.13, 0.13, 0.13, 0.13, 0.13, 0.13, 0.13, 0.13, 0.13 Total Phosphorus - C** (mg/L),0.13,0.13,0.13,0.13, , , , ,0.13 Total Nitrogen - k (m/yr),40,40,40,40,500,500,500,500,40 Total Nitrogen - C** (mg/L), 1.4, 1.4, 1.4, 1.4, 1.4, , , , , , 1.4 Threshold Hydraulic Loading for C** (m/yr),3500,3500,3500,3500, , , , ,3500 Horizontal Flow Coefficient, , , , , 3,3,3,3, Reuse Enabled, On, On, On, On, Off, Off, Off, Off, On Max drawdown height Annual Demand Enabled, On, On, On, On, Off, Off, Off, Off, On Annual Demand Value (ML/year),24.01,66.885,19.208,12.005, , , , , 9.604

```
Annual Demand Distribution, PET, PET, PET, PET, , , , , PET
Annual Demand Monthly Distribution: Jan, , , , , , , ,
Annual Demand Monthly Distribution: Feb, , , , , , , , ,
Annual Demand Monthly Distribution: Mar, , , , , , , ,
Annual Demand Monthly Distribution: Apr, , , , , , , , ,
Annual Demand Monthly Distribution: May, , , , , , , , ,
Annual Demand Monthly Distribution: Jun, , , , , , , ,
Annual Demand Monthly Distribution: Jul, , , , , , ,
Annual Demand Monthly Distribution: Aug, , , , , , , , ,
Annual Demand Monthly Distribution: Sep, , , , , , , ,
Annual Demand Monthly Distribution: Oct, , , , , , , , ,
Annual Demand Monthly Distribution: Nov, , , , , , , , ,
Annual Demand Monthly Distribution: Dec, , , , , ,
Daily Demand Enabled, On, On, On, Off, Off, Off, Off, On
Daily Demand Value (ML/day),0.0658,0.1833,0.05264,0.0329, , , , ,0.02632
Custom Demand Time Series File, , , , , , , , ,
Custom Demand Time Series Units, , , , , , , , ,
Filter area (sqm), , , , ,400,1500,4500,400,
Filter perimeter (m), , , , , 80,80,80,80,
Filter depth (m), , , , , 0.4,0.4,0.4,0.4,
Infiltration Media Porosity, , , , ,0.35,0.35,0.35,0.35,
Length (m), , , , , , , , ,
Bed slope, , , , , , , , ,
Base Width (m), , , , , , , , ,
Top width (m), , , , , , , , , ,
Vegetation height (m), , , , , , , , , ,
Vegetation Type, , , , , Vegetated with Effective Nutrient Removal
Plants, Vegetated with Effective Nutrient Removal Plants, Vegetated with
Effective Nutrient Removal Plants, Vegetated with Effective Nutrient
Removal Plants,
Total Nitrogen Content in Filter (mg/kg), , , , ,800,800,800,800,
Orthophosphate Content in Filter (mg/kg), , , , ,55,55,55,55,
Is Base Lined?, , , , ,Yes,Yes,Yes,Yes,
Is Underdrain Present?, , , , , Yes,Yes,Yes,Yes,
Is Submerged Zone Present?, , , , , No, No, No, No,
Submerged Zone Depth (m), , , ,
B for Media Soil Texture, -9999, -9999, -9999, -9999, 13, 13, 13, 13, -9999
Proportion of upstream impervious area treated, , , , , , , , ,
Exfiltration Rate (mm/hr),0,0,0,0,0,0,0,0,0
Evaporative Loss as % of PET, 0, 0, 0, 0, 100, 100, 100, 0
Depth in metres below the drain pipe, , , , , , , ,
TSS A Coefficient, , , , , , , , ,
TSS B Coefficient, , , , , , , , ,
TP A Coefficient, , , , , , , , ,
TP B Coefficient, , , , , , , , ,
TN A Coefficient, , , , , , , , ,
TN B Coefficient, , , , ,
Sfc, , , , ,0.61,0.61,0.61,0.61,
s*, , , , ,0.37,0.37,0.37,0.37,
Sw, , , , ,0.11,0.11,0.11,0.11,
Sh, , , , ,0.05,0.05,0.05,0.05,
Emax (m/day), , , , ,0.008,0.008,0.008,0.008,
Ew (m/day), , , , ,0.001,0.001,0.001,0.001,
IN - Mean Annual Flow
(ML/yr), 6.19, 17.2, 4.95, 3.09, 16.4, 14.4, 50.5, 9.80, 2.47
```

```
IN - TSS Mean Annual Load
(kg/yr),164,447,130,80.9,1.29E3,1.04E3,4.38E3,708,65.1
IN - TP Mean Annual Load
(kg/yr),0.943,2.61,0.757,0.466,4.04,3.30,12.3,2.29,0.376
IN - TN Mean Annual Load
(kg/yr), 13.6, 37.7, 10.8, 6.78, 41.0, 34.6, 122, 24.0, 5.43
IN - Gross Pollutant Mean Annual Load
(kg/yr),207,576,165,103,27.4,20.5,261,10.6,82.7
OUT - Mean Annual Flow
(ML/yr),1.79,5.00,1.43,0.895,15.8,12.3,44.0,9.18,0.719
OUT - TSS Mean Annual Load
(kg/yr),44.6,120,35.2,21.8,312,63.2,262,105,17.5
OUT - TP Mean Annual Load
(kg/yr),0.267,0.746,0.217,0.133,2.40,1.70,6.09,1.30,0.108
OUT - TN Mean Annual Load
(kg/yr), 3.93, 10.8, 3.11, 1.95, 22.8, 12.4, 45.1, 11.3, 1.57
OUT - Gross Pollutant Mean Annual Load
(kg/yr),0.317,0.884,0.254,0.159,0.00,0.00,0.00,0.00,0.127
Flow In
(ML/yr), 6.18488, 17.2366, 4.94944, 3.09244, 16.4062, 14.4, 50.4224, 9.79164, 2.47
472
ET Loss (ML/yr),0,0,0,0,0.633733,2.10171,6.44906,0.618908,0
Infiltration Loss (ML/yr),0,0,0,0,0,0,0,0,0,0
Low Flow Bypass Out (ML/yr),0,0,0,0,0,0,0,0,0
High Flow Bypass Out
(ML/yr),0.0167255,0.0465925,0.0133804,0.00836276,0,0,0,0,0.00669019
Orifice / Filter Out
(ML/yr),1.7718,4.95502,1.41722,0.885523,9.99002,11.6644,41.0755,7.0919,0.
710719
Weir Out
(ML/yr),0.00176905,0.00248043,0.00163281,0.00126354,5.77641,0.624385,2.87
475,2.07828,0.00113043
Transfer Function Out (ML/yr),0,0,0,0,0,0,0,0,0
Reuse Supplied (ML/yr),4.39749,12.2333,3.51896,2.19874,0,0,0,0,1.75709
Reuse Requested (ML/yr), 47.9198, 134.731, 38.6567, 23.9598, 0, 0, 0, 0, 19.3284
% Reuse Demand Met, 9.17678, 9.07985, 9.1031, 9.17678, 0, 0, 0, 0, 9.09076
% Load
Reduction, 71.0537, 70.9681, 71.0626, 71.0536, 3.8993, 14.6613, 12.8359, 6.34684,
70.9648
TSS Flow In
(kg/yr),164.101,447.264,129.582,80.9329,1284.58,1043.61,4378.09,707.664,6
5.1453
TSS ET Loss (kg/yr),0,0,0,0,0,0,0,0,0
TSS Infiltration Loss (kg/yr),0,0,0,0,0,0,0,0,0,0
TSS Low Flow Bypass Out (kg/yr),0,0,0,0,0,0,0,0,0
TSS High Flow Bypass Out
(kg/yr),0.581529,1.20301,0.344959,0.189699,0,0,0,0,0.123662
TSS Orifice / Filter Out
(kg/yr),44.021,118.785,34.8514,21.6159,30.488,38.6256,134.608,22.1019,17.
3734
TSS Weir Out
(kg/yr),0.0458145,0.0484331,0.0469075,0.0311611,281.12,24.5501,126.764,83
.2976,0.0265104
TSS Transfer Function Out (kg/yr),0,0,0,0,0,0,0,0,0
TSS Reuse Supplied
(kg/yr),82.1827,226.185,65.1551,40.6953,0,0,0,0,32.8063
TSS Reuse Requested (kg/yr),0,0,0,0,0,0,0,0,0
TSS % Reuse Demand Met,0,0,0,0,0,0,0,0,0
```

```
TSS % Load
Reduction, 72.7921, 73.162, 72.8024, 73.0186, 75.7425, 93.9464, 94.03, 85.106, 73.
1008
TP Flow In
(kg/yr),0.942972,2.60886,0.756702,0.466461,4.04058,3.30118,12.329,2.28321
,0.375533
TP ET Loss (kg/yr),0,0,0,0,0,0,0,0,0
TP Infiltration Loss (kg/yr),0,0,0,0,0,0,0,0,0
TP Low Flow Bypass Out (kg/yr),0,0,0,0,0,0,0,0,0
TP High Flow Bypass Out
(kg/yr),0.00205676,0.00496639,0.00334392,0.00111868,0,0,0,0,0.0007378
TP Orifice / Filter Out
(kg/yr),0.264458,0.740414,0.213137,0.132109,1.32707,1.59054,5.58159,0.948
267,0.106927
TP Weir Out
(kg/yr),0.000226609,0.000351341,0.00024353,0.000201461,1.06969,0.103399,0
.497606,0.354044,0.000196742
TP Transfer Function Out (kg/yr),0,0,0,0,0,0,0,0,0,0
TP Reuse Supplied
(kg/yr),0.624846,1.73127,0.500093,0.310249,0,0,0,0,0.248281
TP Reuse Requested (kg/yr),0,0,0,0,0,0,0,0,0
TP % Reuse Demand Met, 0, 0, 0, 0, 0, 0, 0, 0, 0
TP % Load
Reduction, 71.7128, 71.4155, 71.3594, 71.3955, 40.6825, 48.6868, 50.6919, 42.9613
,71.2778
TN Flow In
(kg/yr), 13.6482, 37.7199, 10.8278, 6.78198, 40.9219, 34.5894, 122.236, 24.0101, 5
.42832
TN ET Loss (kg/yr),0,0,0,0,0,0,0,0,0
TN Infiltration Loss (kg/yr),0,0,0,0,0,0,0,0,0
TN Low Flow Bypass Out (kg/yr),0,0,0,0,0,0,0,0,0
TN High Flow Bypass Out
(kg/yr),0.0402317,0.106112,0.0276316,0.0239036,0,0,0,0,0.0181307
TN Orifice / Filter Out
(kg/yr), 3.89021, 10.6673, 3.07546, 1.92492, 9.09596, 10.9607, 38.7302, 6.45646, 1
.54997
TN Weir Out
(kg/yr),0.00412665,0.00534827,0.00368439,0.00301864,13.7041,1.4002,6.3465
2,4.83329,0.00233108
TN Transfer Function Out (kg/yr),0,0,0,0,0,0,0,0,0,0
TN Reuse Supplied (kg/yr),9.30246,25.7276,7.39597,4.62292,0,0,0,0,3.68201
TN Reuse Requested (kg/yr),0,0,0,0,0,0,0,0,0,0
TN % Reuse Demand Met, 0, 0, 0, 0, 0, 0, 0, 0, 0
TN % Load
Reduction, 71.1716, 71.4244, 71.3075, 71.2201, 44.2841, 64.2638, 63.1231, 52.9792
,71.0697
GP Flow In
(kg/yr),206.707,575.827,165.366,103.353,27.3972,20.4569,261.172,10.6175,8
2.6829
GP ET Loss (kg/yr),0,0,0,0,0,0,0,0,0
GP Infiltration Loss (kg/yr),0,0,0,0,0,0,0,0,0
GP Low Flow Bypass Out (kg/yr),0,0,0,0,0,0,0,0,0
GP High Flow Bypass Out
(kg/yr), 0.31747, 0.884383, 0.253976, 0.158735, 0, 0, 0, 0, 0.126988
GP Orifice / Filter Out (kg/yr),0,0,0,0,0,0,0,0,0
GP Weir Out (kg/yr),0,0,0,0,0,0,0,0,0
GP Transfer Function Out (kg/yr),0,0,0,0,0,0,0,0,0,0
GP Reuse Supplied (kg/yr),0,0,0,0,0,0,0,0,0
```

GP Reuse Requested (kg/yr),0,0,0,0,0,0,0,0,0 GP % Reuse Demand Met, 0, 0, 0, 0, 0, 0, 0, 0, 0 GP % Load Reduction, 99.8464, 99.8464, 99.8464, 99.8464, 100, 100, 100, 100, 99.8464 PET Scaling Factor, , , , ,2.1,2.1,2.1,2.1, Generic treatment nodes Location, Ecosol GPT- TFR Low Flow- 4750 , Ecosol GPT- TFR Low Flow- 4750 , Ecosol GPT- TFR Low Flow- 4750 , Ecosol GPT- TFR Low Flow- 41200 ID,29,30,31,32 Node Type, GPTNode, GPTNode, GPTNode, GPTNode Lo-flow bypass rate (cum/sec),0,0,0,0 Hi-flow bypass rate (cum/sec), 0.219, 0.219, 0.219, 0.561 Flow Transfer Function Input (cum/sec), 0, 0, 0, 0 Output (cum/sec),0,0,0,0 Input (cum/sec), 10, 10, 10, 10 Output (cum/sec), 10, 10, 10, 10 Input (cum/sec), , , , Output (cum/sec), , , , Input (cum/sec), , , , Output (cum/sec), , , , Input (cum/sec), , , , Output (cum/sec), , , , Input (cum/sec), , , , Output (cum/sec), , , , Input (cum/sec), , , , Output (cum/sec), , , , Input (cum/sec), , , , Output (cum/sec), , , , Input (cum/sec), , , , Output (cum/sec), , , , Input (cum/sec), , , , Output (cum/sec), , , , Gross Pollutant Transfer Function Enabled, True, True, True, True Input (kg/ML),0,0,0,0 Output (kg/ML),0,0,0,0 Input (kg/ML),1000,1000,1000,1000 Output (kg/ML),20,20,20,20 Input (kg/ML), , , , Output (kg/ML), , , , Input (kg/ML), , , , Output (kg/ML), , , , Input (kg/ML), , , , Output (kg/ML), , , , Input (kg/ML), , , , Output (kg/ML), , , , Input (kg/ML), , , , Output (kg/ML), , , , Input (kg/ML), , , , Output (kg/ML), , , , Input (kg/ML), , , , Output (kg/ML), , , , Input (kg/ML), , , , Output (kg/ML), , , , Total Nitrogen Transfer Function Enabled, True, True, True, True

```
Input (mg/L),0,0,0,0
Output (mg/L),0,0,0,0
Input (mg/L),1000,1000,1000,1000
Output (mg/L),999,999,999,999
Input (mg/L), , , ,
Output (mg/L), , , ,
Input (mg/L), , , ,
Output (mg/L), , , ,
Input (mg/L), , , ,
Output (mg/L), , , ,
Input (mg/L), , , ,
Output (mg/L), , , ,
Input (mg/L), , , ,
Output (mg/L), , , ,
Input (mg/L), , , ,
Output (mg/L), , , ,
Input (mg/L), , , ,
Output (mg/L), , , ,
Input (mg/L), , , ,
Output (mg/L), , , ,
Total Phosphorus Transfer Function
Enabled, True, True, True, True
Input (mg/L),0,0,0,0
Output (mg/L),0,0,0,0
Input (mg/L),1000,1000,1000,1000
Output (mg/L),710,710,710,710
Input (mg/L), , , ,
Output (mg/L), , , ,
Input (mg/L), , , ,
Output (mg/L), , , ,
Input (mg/L), , , ,
Output (mg/L), , , ,
Input (mg/L), , , ,
Output (mg/L), , , ,
Input (mg/L), , , ,
Output (mg/L), , , ,
Input (mg/L), , , ,
Output (mg/L), , , ,
Input (mg/L), , , ,
Output (mg/L), , , ,
Input (mg/L), , , ,
Output (mg/L), , , ,
Total Suspended Solids Transfer Function
Enabled, True, True, True, True
Input (mg/L),0,0,0,0
Output (mg/L),0,0,0,0
Input (mg/L),1000,1000,1000,1000
Output (mg/L), 390, 390, 390, 390
Input (mg/L), , , ,
Output (mg/L), , , ,
Input (mg/L), , , ,
Output (mg/L), , , ,
Input (mg/L), , , ,
Output (mg/L), , , ,
Input (mg/L), , , ,
Output (mg/L), , , ,
Input (mg/L), , , ,
Output (mg/L), , , ,
```

```
Input (mg/L), , , ,
Output (mg/L), , , ,
Input (mg/L), , , ,
Output (mg/L), , , ,
Input (mg/L), , , ,
Output (mg/L), , , ,
TSS Flow based Efficiency Enabled, Off, Off, Off, Off
TSS Flow based Efficiency, , , ,
TP Flow based Efficiency Enabled, Off, Off, Off, Off
TP Flow based Efficiency, , , ,
TN Flow based Efficiency Enabled, Off, Off, Off, Off
TN Flow based Efficiency, , , ,
GP Flow based Efficiency Enabled, Off, Off, Off, Off
GP Flow based Efficiency, , , ,
IN - Mean Annual Flow (ML/yr), 9.80, 16.4, 14.4, 44.9
IN - TSS Mean Annual Load (kg/yr), 1.72E3, 2.95E3, 2.43E3, 7.90E3
IN - TP Mean Annual Load (kg/yr), 3.17, 5.52, 4.53, 14.7
IN - TN Mean Annual Load (kg/yr), 24.1, 41.0, 34.6, 110
IN - Gross Pollutant Mean Annual Load (kg/yr), 334, 555, 468, 1.48E3
OUT - Mean Annual Flow (ML/yr), 9.80, 16.4, 14.4, 44.9
OUT - TSS Mean Annual Load (kg/yr),708,1.29E3,1.04E3,3.48E3
OUT - TP Mean Annual Load (kg/yr), 2.29, 4.04, 3.30, 10.8
OUT - TN Mean Annual Load (kg/yr),24.0,41.0,34.6,110
OUT - Gross Pollutant Mean Annual Load (kg/yr),10.6,27.4,20.5,77.9
Flow In (ML/yr), 9.79164, 16.4062, 14.4, 44.889
ET Loss (ML/yr),0,0,0,0
Infiltration Loss (ML/yr),0,0,0,0
Low Flow Bypass Out (ML/yr),0,0,0,0
High Flow Bypass Out (ML/yr), 0.375913, 1.28435, 1.00622, 3.90678
Orifice / Filter Out (ML/yr),0,0,0,0
Weir Out (ML/yr),0,0,0,0
Transfer Function Out (ML/yr), 9.41683, 15.1232, 13.3939, 40.9845
Reuse Supplied (ML/yr),0,0,0,0
Reuse Requested (ML/yr),0,0,0,0
% Reuse Demand Met, 0, 0, 0, 0
% Load Reduction, -0.0112504, -0.00876077, -0.00100612, -0.00509199
TSS Flow In (kg/yr),1721.42,2943.57,2427.93,7890.07
TSS ET Loss (kg/yr),0,0,0,0
TSS Infiltration Loss (kg/yr),0,0,0,0
TSS Low Flow Bypass Out (kg/yr),0,0,0,0
TSS High Flow Bypass Out (kg/yr),59.4763,223.947,158.605,657.643
TSS Orifice / Filter Out (kg/yr),0,0,0,0
TSS Weir Out (kg/yr),0,0,0,0
TSS Transfer Function Out (kg/yr),648.188,1060.72,885.013,2820.79
TSS Reuse Supplied (kg/yr),0,0,0,0
TSS Reuse Requested (kg/yr),0,0,0,0
TSS % Reuse Demand Met,0,0,0,0
TSS % Load Reduction, 58.8907, 56.357, 57.0161, 55.9137
TP Flow In (kg/yr), 3.17006, 5.51917, 4.52554, 14.7202
TP ET Loss (kg/yr),0,0,0,0
TP Infiltration Loss (kg/yr),0,0,0,0
TP Low Flow Bypass Out (kg/yr),0,0,0,0
TP High Flow Bypass Out (kg/yr),0.112017,0.419757,0.304265,1.24247
TP Orifice / Filter Out (kg/yr),0,0,0,0
TP Weir Out (kg/yr),0,0,0,0
TP Transfer Function Out (kg/yr),2.17131,3.62111,2.99724,9.56958
TP Reuse Supplied (kg/yr),0,0,0,0
TP Reuse Requested (kg/yr),0,0,0,0
```

```
TP % Reuse Demand Met, 0, 0, 0, 0
TP % Load Reduction, 27.9723, 26.7848, 27.0473, 26.5496
TN Flow In (kg/yr),24.0331,40.9595,34.6216,110.195
TN ET Loss (kg/yr),0,0,0,0
TN Infiltration Loss (kg/yr),0,0,0,0
TN Low Flow Bypass Out (kg/yr),0,0,0,0
TN High Flow Bypass Out (kg/yr), 0.946028, 3.24972, 2.41618, 9.18184
TN Orifice / Filter Out (kg/yr),0,0,0,0
TN Weir Out (kg/yr),0,0,0,0
TN Transfer Function Out (kg/yr),23.0652,37.6723,32.1748,100.925
TN Reuse Supplied (kg/yr),0,0,0,0
TN Reuse Requested (kg/yr),0,0,0,0
TN % Reuse Demand Met,0,0,0,0
TN % Load Reduction, 0.091103, 0.091533, 0.0885066, 0.0800778
GP Flow In (kg/yr), 334.26, 554.96, 468.117, 1481.68
GP ET Loss (kg/yr),0,0,0,0
GP Infiltration Loss (kg/yr),0,0,0,0
GP Low Flow Bypass Out (kg/yr),0,0,0,0
GP High Flow Bypass Out (kg/yr),4.09198,16.8988,11.5081,49.981
GP Orifice / Filter Out (kg/yr),0,0,0,0
GP Weir Out (kg/yr),0,0,0,0
GP Transfer Function Out (kg/yr), 6.52563, 10.5005, 8.94777, 27.8952
GP Reuse Supplied (kg/yr),0,0,0,0
GP Reuse Requested (kg/yr),0,0,0,0
GP % Reuse Demand Met, 0, 0, 0, 0
GP % Load Reduction, 98.7758, 96.9549, 97.5416, 96.6267
Other nodes
Location, Post-Development Node, Junction - Area 1 - 7.254ha, Junction -
Area 2 - 7.971ha, Junction - Area 3 - 25.489ha, Junction - Area 4 -
4.943ha, Pre-Development Node, Predeveloped - Agricultural, Post-Developed -
Junction - South west outlet, Post Developed - Junction - West Outlet
ID, 6, 15, 16, 17, 18, 25, 28, 37, 38
Node
Type, PostDevelopmentNode, JunctionNode, JunctionNode, JunctionNode, JunctionN
ode, PreDevelopmentNode, JunctionNode, JunctionNode, JunctionNode
IN - Mean Annual Flow
(ML/yr), 93.3, 14.4, 16.4, 44.9, 9.80, 75.6, 75.6, 9.18, 84.1
IN - TSS Mean Annual Load
(kg/yr),1.27E3,2.43E3,2.95E3,7.90E3,1.72E3,3.32E3,13.7E3,105,1.16E3
IN - TP Mean Annual Load
(kg/yr), 12.6, 4.53, 5.52, 14.7, 3.17, 6.75, 57.3, 1.30, 11.3
IN - TN Mean Annual Load
(kg/yr),104,34.6,41.0,110,24.1,77.3,268,11.3,92.7
IN - Gross Pollutant Mean Annual Load
(kg/yr),497,468,555,1.48E3,334,3.12E3,3.12E3,0.00,497
OUT - Mean Annual Flow
(ML/yr),93.3,14.4,16.4,44.9,9.80,75.6,75.6,9.18,84.1
OUT - TSS Mean Annual Load
(kg/yr),1.27E3,2.43E3,2.95E3,7.90E3,1.72E3,3.32E3,13.7E3,105,1.16E3
OUT - TP Mean Annual Load
(kg/yr), 12.6, 4.53, 5.52, 14.7, 3.17, 6.75, 57.3, 1.30, 11.3
OUT - TN Mean Annual Load
(kg/yr),104,34.6,41.0,110,24.1,77.3,268,11.3,92.7
OUT - Gross Pollutant Mean Annual Load
(kg/yr),497,468,555,1.48E3,334,3.12E3,3.12E3,0.00,497
% Load Reduction, 26.7, 23.4, 17.6, 21.4, 18.3, 51.5E-12, 51.5E-12, 23.5, 27.0
TSS % Load Reduction, 92.6, 4.69, 3.10, 3.98, 3.32, -410E-15, 625E-15, 94.1, 92.4
```

TN % Load Reduction, 63.8, 21.9, 15.8, 19.6, 16.7, 2.56E-12, 5.77E-12, 60.9, 64.2 TP % Load Reduction, 63.3, 13.0, 8.90, 11.2, 9.50, -5.00E-12, -4.49E-12,62.8,63.4 GP % Load Reduction, 89.3, 30.6, 22.9, 28.0, 23.6, 4.50E-12, 4.50E-12, 100, 88.2 Links Location, Drainage Link, Drainage Link Source node ID, 10, 14, 7, 12, 3, 2, 4, 5, 9, 11, 13, 8, 19, 20, 22, 1, 27, 18, 16, 15, 17, 32, 30, 31, 33, 34, 36, 21, 29, 35, 26, 23, 24, 39, 40, 38, 37, 41, 42, 43, 44 Target node ID, 14, 16, 16, 16, 5, 15, 15, 15, 13, 17, 17, 17, 18, 22, 18, 25, 28, 29, 30, 31, 32, 26, 23, 24 ,16,17,18,18,35,37,38,38,38,25,28,6,6,38,43,26,26 Muskingum-Cunge Routing, Not Routed, Not Routed . IN - Mean Annual Flow (ML/yr), 4.95, 1.43, 6.75, 7.62, 6.19, 4.36, 8.25, 1.79, 17.2, 21.9, 5.00, 16.6, 5.42, 3.09,0.895,63.6,63.6,9.80,16.4,14.4,44.9,44.9,16.4,14.4,0.610,1.47,0.623, 2.87,9.80,9.18,44.0,15.8,12.3,12.0,12.0,84.1,9.18,12.0,2.47,0.719,4.82 IN - TSS Mean Annual Load (kg/yr),130,35.2,1.40E3,1.39E3,164,903,1.48E3,44.6,447,4.02E3,120,3.47E3, 982,80.9,21.8,2.80E3,11.5E3,1.72E3,2.95E3,2.43E3,7.90E3,3.48E3,1.29E3,1.0 4E3,120,288,122,597,708,105,262,312,63.2,526,2.17E3,1.16E3,105,526,65.1,1 7.5,883 IN - TP Mean Annual Load (kg/yr),0.757,0.217,2.83,2.23,0.943,1.82,2.44,0.267,2.61,6.48,0.746,6.89, 1.58,0.466,0.133,5.67,48.2,3.17,5.52,4.53,14.7,10.8,4.04,3.30,0.247,0.608 ,0.253,1.20,2.29,1.30,6.09,2.40,1.70,1.08,9.11,11.3,1.30,1.07,0.376,0.108 ,1.41 IN - TN Mean Annual Load (kg/yr),10.8,3.11,19.5,16.6,13.6,12.6,18.1,3.93,37.7,47.6,10.8,47.7,11.9, 6.78,1.95,64.9,225,24.1,41.0,34.6,110,110,41.0,34.6,1.74,4.23,1.78,8.41,2 4.0,11.3,45.1,22.8,12.4,12.4,42.6,92.7,11.3,12.4,5.43,1.57,10.6 IN - Gross Pollutant Mean Annual Load (kg/yr),165,0.254,239,290,207,154,314,0.317,576,832,0.884,585,206,103,0.1 59,2.63E3,2.63E3,334,555,468,1.48E3,77.9,27.4,20.5,26.4,63.9,27.0,101,10. 6,0.00,0.00,0.00,0.00,497,497,497,0.00,497,82.7,0.127,183 OUT - Mean Annual Flow (ML/yr), 4.95, 1.43, 6.75, 7.62, 6.19, 4.36, 8.25, 1.79, 17.2, 21.9, 5.00, 16.6, 5.42, 3.09,0.895,63.6,63.6,9.80,16.4,14.4,44.9,44.9,16.4,14.4,0.610,1.47,0.623, 2.87,9.80,9.18,44.0,15.8,12.3,12.0,12.0,84.1,9.18,12.0,2.47,0.719,4.82

OUT - TSS Mean Annual Load (kg/yr),130,35.2,1.40E3,1.39E3,164,903,1.48E3,44.6,447,4.02E3,120,3.47E3, 982,80.9,21.8,2.80E3,11.5E3,1.72E3,2.95E3,2.43E3,7.90E3,3.48E3,1.29E3,1.0 4E3,120,288,122,597,708,105,262,312,63.2,526,2.17E3,1.16E3,105,526,65.1,1 7.5,883 OUT - TP Mean Annual Load (kg/yr),0.757,0.217,2.83,2.23,0.943,1.82,2.44,0.267,2.61,6.48,0.746,6.89, 1.58,0.466,0.133,5.67,48.2,3.17,5.52,4.53,14.7,10.8,4.04,3.30,0.247,0.608 ,0.253,1.20,2.29,1.30,6.09,2.40,1.70,1.08,9.11,11.3,1.30,1.07,0.376,0.108 ,1.41 OUT - TN Mean Annual Load (kg/yr),10.8,3.11,19.5,16.6,13.6,12.6,18.1,3.93,37.7,47.6,10.8,47.7,11.9, 6.78,1.95,64.9,225,24.1,41.0,34.6,110,110,41.0,34.6,1.74,4.23,1.78,8.41,2 4.0,11.3,45.1,22.8,12.4,12.4,42.6,92.7,11.3,12.4,5.43,1.57,10.6 OUT - Gross Pollutant Mean Annual Load (kg/yr),165,0.254,239,290,207,154,314,0.317,576,832,0.884,585,206,103,0.1 59,2.63E3,2.63E3,334,555,468,1.48E3,77.9,27.4,20.5,26.4,63.9,27.0,101,10. 6,0.00,0.00,0.00,0.00,497,497,497,0.00,497,82.7,0.127,183 Catchment Details Catchment Name, NSW202732 DA MUSIC - LIDELL DATA UK1 090222 Timestep, 6 Minutes Start Date, 23/08/1964 End Date, 31/03/1995 11:54:00 PM Rainfall Station, 61212 LIDDELL ET Station, User-defined monthly PET Mean Annual Rainfall (mm), 372

Mean Annual ET (mm), 1606