

Maitland City Council PO Box 220 MAITLAND NSW 2320

Your reference: CNR-34282 DA/2021/1702 Our reference: DA20220120000726-Original-1

ATTENTION: Brian Gibson Date: Wednesday 25 May 2022

Dear Sir/Madam,

Integrated Development Application s100B - SFPP - Child Care Centre 20 Heritage Drive Chisholm NSW 2322, 1//DP1224700

I refer to your correspondence dated 20/01/2022 seeking general terms of approval for the above Integrated Development Application.

The New South Wales Rural Fire Service (NSW RFS) has considered the information submitted. General Terms of Approval, under Division 4.8 of the Environmental Planning and Assessment Act 1979, and a Bush Fire Safety Authority, under section 100B of the Rural Fires Act 1997, are now issued subject to the following conditions:

Asset Protection Zones

Intent of measures: to provide suitable building design, construction and sufficient space to ensure that radiant heat levels do not exceed critical limits for firefighters and other emergency services personnel undertaking operations, including supporting or evacuating occupants.

1. From the start of building works and in perpetuity, the entire property must be managed as an inner protection area (IPA) in accordance with the requirements of Appendix 4 of Planning for Bush Fire Protection 2019. When establishing and maintaining an IPA, the following requirements apply:

- Tree canopy cover be less than 15% at maturity;
- Trees at maturity are not touching or overhang the building;
- Lower limbs are removed up to a height of 2m above the ground;
- Tree canopies are separated by 2 to 5m;
- Preference is given to smooth-barked and evergreen trees;
- Large discontinuities or gaps in vegetation are provided to slow down or break the progress of fire towards buildings;
- Shrubs are not located under trees;
- Shrubs do not form more than 10% of ground cover;
- Clumps of shrubs are separated from exposed windows and doors by a distance of at least twice the height of the vegetation.
- Grass to be kept mown (as a guide grass should be kept to no more than 100mm in height);

1

- Leaves and vegetation debris are removed; and
- NSW Rural Fire Service's document Standards for asset protection zones.
- 2. Landscaping for the entire property must comply with Appendix 4 of *Planning for Bush Fire Protection 2019*. In this regard, the following principles are to be incorporated:
 - A minimum 1 metre wide area (or to the property boundary where the setbacks are less than 1 metre), suitable for pedestrian traffic, must be provided around the immediate curtilage of the building;
 - Planting is limited in the immediate vicinity of the building;
 - Planting does not provide a continuous canopy to the building (i.e. trees or shrubs are isolated or located in small clusters);
 - Landscape species are chosen to ensure tree canopy cover is less than 15% (IPA), and less than 30% (OPA) at maturity and trees do no touch or overhang buildings;
 - Avoid species with rough fibrous bark, or which retain/shed bark in long strips or retain dead material in their canopies;
 - Use smooth bark species of trees species which generally do not spread fire up the bark into the crown;
 - Avoid planting of deciduous species that may increase fuel at surface/ ground level (i.e. leaf litter);
 - Avoid climbing species to walls and pergolas;
 - Locate combustible materials such as woodchips/mulch, flammable fuel stores away from the building;
 - Locate combustible structures such as garden sheds, pergolas and materials such as timber garden furniture away from the building; and
 - Low flammability vegetation species are used.

Construction Standards

Intent of measures: to provide suitable building design, construction and sufficient space to ensure that radiant heat levels do not exceed critical limits for firefighters and other emergency services personnel undertaking operations, including supporting or evacuating occupants.

- 3. Construction must comply with the recommendations of the bush fire report prepared by Newcastle Bushfire Consulting, dated 30 November 2021.
- 4. Any new Class 10b structures (except for the childcare centre) as defined per the *National Construction Code* must be non-combustible.

Water and Utility Services

Intent of measures: to provide adequate services of water for the protection of buildings during and after the passage of a bush fire, and to locate gas and electricity so as not to contribute to the risk of fire to a building.

5. The provision of water, electricity and gas shall comply with Table 6.8c of *Planning for Bush Fire Protection* 2019.

Emergency and Evacuation Planning Assessment

Intent of measures: to provide suitable emergency and evacuation arrangements for occupants of SFPP developments.

6. A Bush Fire Emergency Management and Evacuation Plan for the shopping centre must be prepared consistently with the NSW RFS document: A Guide to Developing a Bush Fire Emergency Management and Evacuation Plan.

For any queries regarding this correspondence, please contact Simon Derevnin on 1300 NSW RFS.

Yours sincerely,

Alastair Patton
Supervisor Development Assessment & Plan
Built & Natural Environment



BUSH FIRE SAFETY AUTHORITY

SFPP - Child Care Centre 20 Heritage Drive Chisholm NSW 2322, 1//DP1224700 RFS Reference: DA20220120000726-Original-1

Your Reference: CNR-34282 DA/2021/1702

This Bush Fire Safety Authority is issued on behalf of the Commissioner of the NSW Rural Fire Service under s100b of the Rural Fires Act (1997) subject to the attached General Terms of Approval.

This authority confirms that, subject to the General Terms of Approval being met, the proposed development will meet the NSW Rural Fire Service requirements for Bush Fire Safety under *s100b* of the Rural Fires Act 1997.

Alastair Patton

Supervisor Development Assessment & Plan Built & Natural Environment

Wednesday 25 May 2022