

05 August 2022

Kate Macdonald
Cox Architecture
70 George St
The Rocks NSW 2000

Dear Kate,

Subject: NAPL ACE TERMINAL EXPANSION – WATER QUALITY TARGETS

1. INTRODUCTION

This letter provides a clarification of the proposed carpark scope of works and seeks acceptance that additional and new water quality assessment or targets is not required.

2. RECOMMENDATION TO ADOPT EXISTING STORMWATER INFRASTRUCTURE

The works proposed for the re-purposing of existing short stay to the premium car park includes the reconfiguration of some parking bays, relocation of the entry/exits and inclusion of Photovoltaic and pedestrian canopies. These changes also provide an overall reduction of the original car park footprint due to the reduction to the short stay carpark.

The stormwater strategy for the carpark is to maintain and reconnect into the existing stormwater infrastructure. We recommend that the existing stormwater management system, which treats the existing carpark, should remain suitable to receive and manage the stormwater since no additional impervious carpark area is being constructed.

Yours faithfully

Peter Forder
Principal Engineer
BEng CPEng NER FIEAust
Hatch